

ATTACHMENT 2

AUTHORIZATION TO OPERATE (ATO)
 UNDER PDEQ CLASS II GENERAL AIR QUALITY OPERATING PERMIT #6096
 For
 NESHAP GASOLINE DISPENSING FACILITIES



I. FACILITY INFORMATION:

Business Name: COSTCO WHOLESALE
 Facility Name: COSTCO GASOLINE (LOC. 431)
 Responsible Official: Mr. Dennis Bock
 Source Location: 3901 W. Costco Drive; Marana, AZ 85741

II. AUTHORIZED EQUIPMENT:

ATO #	TANK				SUBMERGED FILL DEVICE		VAPOR BALANCE SYSTEM	
	ID	VOLUME	MANUFACTURE DATE	INSTALLATION DATE	INSTALLATION DATE	TANK BOTTOM CLEARANCE	TYPE	INSTALLATION DATE
1513-01	1	30,000	≤1/10/08	≤11/9/06	≤11/9/06	≤6"	Dual Point	≤12/15/09
1513-02	2	30,000	≤1/10/08	≤11/9/06	≤11/9/06	≤6"	Dual Point	≤12/15/09
1513-03	3	30,000	≤1/10/08	≤11/9/06	≤11/9/06	≤6"	Dual Point	≤12/15/09

III. THROUGHPUT LIMITATION (Facility-wide)

Maximum Yearly Throughput (gallons*): 13,850,000

*Gallons, as used in this document, shall mean net gallons defined as the volume of gasoline corrected to a reference temperature of 60 degrees Fahrenheit.

Rupesh Patel, Air Permit Manager, PDEQ

ATO Issue Date:	October 18, 2015
ATO Expiration Date:	October 17, 2020