# ATTACHMENT 2

## AUTHORIZATION TO OPERATE (ATO)

UNDER PDEQ GENERAL AIR QUALITY CONTROL PERMIT FOR NSPS GENERATORS/ ENGINES

(As required by Title 49, Chapter 3, Article 2, Section 49-480, Arizona Revised Statutes)

I. FACILITY INFORMATION:

Business Name: CLPF-MMIC-DASCO-TUCSON, MOB, LP
Facility Name: EL DORADO MEDICAL CENTER
Responsible Official: MONA DEANE
Contact: BILL BRIGHTMORE
Source Location: 1400 N. WILMOT RD, SUITE 158
TUCSON, AZ 85712

II. AUTHORIZED EQUIPMENT: EMERGENCY

| ATO # | Manufacturer | Model # | Serial Number/ ID number | Maximum Rated Capacity (HP) | Allowable Hours of Operation[1] | Model year/ Applicability Date[2] | Allowable Fuel(s) |
|---|---|---|---|---|---|---|---|
| 1582-01 | Kohler | 6081TF001 | RG6081T142286 | 181 | 100 | 2000 | Diesel |
| 1582-02 | Detroit | 8VF145665 | XF3803695 | 503 | 100 | 1991 | Diesel |
| 1582-03 | Caterpillar | C15 | FSE2813 | 536 | 100 | 2009 | Diesel |

[1]Allowable hours of operation for emergency generators are limited to maintenance testing and readiness checks. There is no limit on hours of operation during true emergencies.
[2]The most recent date of order, manufacture, reconstruction, or modification.

November 21, 2013
SIGNATURE ATO ISSUE DATE

June 30, 2018
EXPIRATION DATE

Scott Porter, Environmental Quality Manager, PDEQ
TITLE

## III. SUPPLEMENTAL REQUIREMENTS

The following requirements apply in addition to the *Specific Conditions, Additional Permit Conditions and Attachment(s):*

| ATO # | Applicable NSPS Attachment(s) | NOx (g/hphr) | NMHC (g/hphr) | NMHC+NOx (g/hphr) | CO (g/hphr) | PM (g/hphr) | Certified Emissions Life (term, date) |
|---|---|---|---|---|---|---|---|
| 1582-03 | Post Model 2007 | --- | --- | 3.0 | 2.6 | 0.15 | 8,000 hours or 10 years, whichever comes first |

## IV. OTHER EQUIPMENT

The equipment listed below has been evaluated and determined not to currently require an air quality permit. In addition, the equipment is not subject to any federal standards.

| Equipment | Model # | Serial Number/ ID number | Maximum Rated Capacity (MMBTU) | Allowable Hours of Operation[1] | Model year/ Applicability Date[2] | Allowable Fuel(s) |
|---|---|---|---|---|---|---|
| BOILER | PARKER | 156703/Model 105-150 | 6.3 | N/A | 1998 | Natural Gas |
| BOILER | PARKER | 156704/Model 105-150 | 6.3 | N/A | 1998 | Natural Gas |

November 21, 2013
SIGNATURE ATO ISSUE DATE

June 30, 2018
EXPIRATION DATE

Scott Porter, Environmental Quality Manager, PDEQ
TITLE