

ATTACHMENT 2

AUTHORIZATION TO OPERATE (ATO)
UNDER PDEQ GENERAL AIR QUALITY CONTROL PERMIT FOR NSPS GENERATORS/ ENGINES
 (As required by Title 49, Chapter 3, Article 2, Section 49-480, Arizona Revised Statutes)

I. FACILITY INFORMATION:

Business Name: PIMA COUNTY REGIONAL WASTEWATER RECLAMATION DEPARTMENT
 Facility Name: CORONA DE TUCSON WASTEWATER RECLAMATION FACILITY
 Responsible Official: JEFF PREVATT
 Contact: KEN WEBER
 Source Location: 1100 W. SAHUARITA ROAD
 TUCSON, AZ 85735

II. AUTHORIZED EQUIPMENT: EMERGENCY

ATO #	Manufacturer	Model #	Serial Number/ ID number	Maximum Rated Capacity (HP)	Allowable Hours of Operation ¹	Model year/ Applicability Date ²	Allowable Fuel(s)
3302-01	Cummins	QST30-G5	K060988685	1490	100	12/1/2006	Diesel

¹Allowable hours of operation for emergency generators are limited to maintenance testing and readiness checks. There is no limit on hours of operation during true emergencies.

²The most recent date of order, manufacture, reconstruction, or modification.

III. SUPPLEMENTAL REQUIREMENTS

The following requirements apply in addition to the *Specific Conditions, Additional Permit Conditions and Attachment(s)*:

ATO #	Applicable NSPS Attachment(s)	NOx (g/hp-hr)	NMHC (g/hp-hr)	NMHC+NOx (g/hp-hr)	CO (g/hp-hr)	PM (g/hp-hr)	Certified Emissions Life (term, date)
3302-01	Pre-2007 Emergency	6.9	1.0	---	8.5	0.40	8,000 hours or 10 years, whichever comes first.



 SIGNATURE

August 27, 2013
 ATO ISSUE DATE

June 30, 2018
 EXPIRATION DATE

Mukonde Chama, P.E., Air Permits Manager, PDEQ
 TITLE