

ATTACHMENT 2

**AUTHORIZATION TO OPERATE (ATO)
UNDER PDEQ CLASS II GENERAL AIR QUALITY OPERATING PERMIT
For
NSPS GENERATOR(S)/ ENGINES**



I. FACILITY INFORMATION:

Business Name: Sahuarita Water Company LLC.
Facility Name: Well 23
Responsible Official: Geoff Caron (General Manager)
Contact Person: Louie Valencia (Plant Manager)
Source Location: 15304 S Avenida Mitla, Sahuarita, AZ, 85629

II. AUTHORIZED EQUIPMENT: Emergency Generators

ATO #	Manufacturer	Model	ID/Serial Number	Maximum Rated Capacity	Allowable Hrs of Operation ¹	Manufacture Date ²	Allowable Fuel(s)
3313-01	Generac Power Systems, Inc.	SD400	2094930 Booster #1 Generator	537 HP 400 kW	100	09/06/2007	Diesel
3313-02	Cummins	DSHAD-7091274	E080180832 Booster #2 Generator	364 HP 230 kW	100	03/19/2008	Diesel
3313-03	Caterpillar	C-15	EE13735 NAP00391 Well 23 Generator	671 HP 500kW	100	08/19/2014	Diesel

¹ Allowable hours of operation for emergency generators are limited to maintenance testing and readiness checks. There is no limit on hours of operation during true emergencies.

² The most recent date of order, manufacture, reconstruction, or modification.

Rupesh Patel, Air Permit Manager, PDEQ

ATO Issue Date:	July 01, 2013
ATO Revised:	January 23, 2015
ATO Expiration Date:	June 30, 2018

ATTACHMENT 2

**AUTHORIZATION TO OPERATE (ATO)
UNDER PDEQ CLASS II GENERAL AIR QUALITY OPERATING PERMIT
For
NSPS GENERATOR(S)/ ENGINES**



III. SUPPLEMENTAL REQUIREMENTS:

The following requirements apply in addition to the *Specific Conditions, Additional Permit Requirements and Attachment(s): 2*

ATO #	Applicable NSPS Attachment(s)	NO _x (g/hp-hr)	NMHC (g/hp-hr)	NMHC+NO _x (g/hp-hr)	CO (g/hp-hr)	PM (g/hp-hr)	Certified Emissions Life (term, date)
3313-01	Attachment 5 Post Model 2007	---	---	3.0	2.6	0.15	8000 hours or 10 years, whichever comes first.
3313-02	Attachment 5 Post Model 2007	---	---	3.0	2.6	0.15	8000 hours or 10 years, whichever comes first.
3313-03	Attachment 5 Post Model 2007	---	---	3.0	2.6	0.15	8000 hours or 10 years, whichever comes first.

Rupesh Patel, Air Permit Manager, PDEQ

ATO Issue Date:	July 01, 2013
ATO Revised:	January 23, 2015
ATO Expiration Date:	June 30, 2018