

**ATTACHMENT 2**

**AUTHORIZATION TO OPERATE (ATO)**  
**UNDER PDEQ GENERAL AIR QUALITY CONTROL PERMIT FOR NSPS GENERATORS/ ENGINES**  
 (As required by Title 49, Chapter 3, Article 2, Section 49-480, Arizona Revised Statutes)

**I. FACILITY INFORMATION:**

Business Name: SYMANTEC  
 Facility Name: SYMANTEC  
 Responsible Official: MIKE WELLIVER  
 Contact: CARL VON OGDEN  
 Source Location: 3701 E. COLUMBIA ST., TUCSON, AZ 85714

**II. AUTHORIZED EQUIPMENT: EMERGENCY**

| ATO #   | Manufacturer | Model #  | Serial Number/ ID number | Maximum Rated Capacity (HP) | Allowable Hours of Operation <sup>1</sup> | Model year/ Applicability Date <sup>2</sup> | Allowable Fuel(s) |
|---------|--------------|----------|--------------------------|-----------------------------|---|---|-------------------|
| 6020-01 | Cummins      | QSK60-G6 | 33172877 (3A)            | 2923 (2180KW)               | 100                                       | March 2008                                  | Diesel            |
| 6020-02 | Cummins      | QSK60-G6 | 33173425 (3B)            | 2923 (2180KW)               | 100                                       | April 2008                                  | Diesel            |
| 6020-03 | Cummins      | QSK60-G6 | 33173329 (3C)            | 2923 (2180KW)               | 100                                       | April 2008                                  | Diesel            |
| 6020-04 | Cummins      | QSK60-G6 | 33171340 (3D)            | 2923 (2180KW)               | 100                                       | November 2008                               | Diesel            |
| 6020-05 | Cummins      | QSK60-G6 | 33174138 (3R)            | 2923 (2180KW)               | 100                                       | June 2008                                   | Diesel            |
| 6020-06 | Caterpillar  | 3516     | ZAP 00234                | 2000 KW                     | 100                                       | 2006  | Diesel            |
| 6020-07 | Caterpillar  | 3516     | ZAP 00238                | 2000 KW                     | 100                                       | 2006  | Diesel            |

<sup>1</sup> Allowable hours of operation for emergency generators are limited to maintenance testing and readiness checks. There is no limit on hours of operation during true emergencies.

<sup>2</sup> The most recent date of order, manufacture, reconstruction, or modification.

|                      |               |
|----------------------|---------------|
| ATO Issue Date:      | 9/2/2014      |
| ATO Revised:         | N/A           |
| ATO Expiration Date: | June 30, 2018 |



Scott Porter, Environmental Quality Manager, PDEQ

**ATTACHMENT 2**

**AUTHORIZATION TO OPERATE (ATO)  
UNDER PDEQ CLASS II GENERAL AIR QUALITY OPERATING PERMIT  
For  
NSPS GENERATOR(S)/ ENGINES**



II. AUTHORIZED EQUIPMENT (Cont'd) : EMERGENCY

| ATO #   | Manufacturer | Model # | Serial Number/ ID number | Maximum Rated Capacity (HP) | Allowable Hours of Operation <sup>1</sup> | Model year/ Applicability Date <sup>2</sup> | Allowable Fuel(s) |
|---------|--------------|---------|--------------------------|-----------------------------|---|---|-------------------|
| 6020-08 | Caterpillar  | 3516-B  | 6HNO 1255                | 2180 KW                     | 100                                       | 2003  | Diesel            |
| 6020-09 | Caterpillar  | 3516-B  | 6HNO 1262                | 2180 KW                     | 100                                       | 2003  | Diesel            |

<sup>1</sup> Allowable hours of operation for emergency generators are limited to maintenance testing and readiness checks. There is no limit on hours of operation during true emergencies.

<sup>2</sup> The most recent date of order, manufacture, reconstruction, or modification.

III. SUPPLEMENTAL REQUIREMENTS

The following requirements apply to the NSPS emergency engines in addition to the *Specific Conditions, Attachment 1 and Attachment 2*:

| ATO #        | Applicable NSPS Attachment(s) | NOx (g/hphr) | NMHC (g/hphr) | NMHC+NOx (g/hphr) | CO (g/hphr) | PM (g/hphr) | Certified Emissions Life (term, date)           |
|--------------|-------------------------------|--------------|---------------|-------------------|-------------|-------------|---|
| 6020-01 - 05 | Post Model 2007               |              |               | 4.8               | 2.6         | 0.15        | 8,000 hours or 10 years, whichever comes first. |
| 6020-06 & 07 | Pre Model 2007                | 6.9          | 1.0           |                   | 8.5         | 0.40        | 8,000 hours or 10 years, whichever comes first. |

  
\_\_\_\_\_  
Scott Porter, Environmental Quality Manager, PDEQ

|                      |               |
|----------------------|---------------|
| ATO Issue Date:      | 9/2/2014      |
| ATO Revised:         | N/A           |
| ATO Expiration Date: | June 30, 2018 |