

ATTACHMENT 2

AUTHORIZATION TO OPERATE (ATO)
UNDER GENERAL AIR QUALITY CONTROL PERMIT FOR NSPS GENERATORS/ ENGINES
 (As required by Title 49, Chapter 3, Article 2, Section 49-480, Arizona Revised Statutes)

I. FACILITY INFORMATION:

Business Name: SANOFI-AVENTIS
 Facility Name: SANOFI-AVENTIS
 Responsible Official: KEN WERTMAN
 Contact: KIM STONE
 Source Location: 2090 E. INNOVATION PARK DRIVE
 ORO VALLEY, AZ 85755

II. AUTHORIZED EQUIPMENT: EMERGENCY

ATO #	Manufacturer	Model #	Serial Number/ ID number	Maximum Rated Capacity (HP)	Allowable Hours of Operation	Model year/ Applicability Date ¹	Allowable Fuel(s)
6023	Cummins	1750DQAA	J070113783	2346.75	100	May 2007	Diesel

¹The most recent date of order, manufacture, reconstruction, or modification.

III. SUPPLEMENTAL REQUIREMENTS

The following requirements apply in addition to the *Specific Conditions, Attachment 1 and Attachment 5*:

ATO #	Applicable NSPS Attachment(s)	NOx (g/hphr)	NMHC (g/hphr)	NMHC+NOx (g/hphr)	CO (g/hphr)	PM (g/hphr)	Certified Emissions Life (term, date)
6023	Post Model 2007	---	---	4.8	2.6	0.15	8,000 hours or 10 years, whichever comes first



SIGNATURE

August 30, 2013

ISSUE DATE

June 30, 2018

EXPIRATION DATE

Mukonde Chama, P.E., Air Permits Manager, PDEQ
 TITLE