ATTACHMENT 2

AUTHORIZATION TO OPERATE (ATO)

UNDER PDEQ GENERAL AIR QUALITY CONTROL PERMIT FOR NSPS GENERATORS/ ENGINES

(As required by Title 49, Chapter 3, Article 2, Section 49-480, Arizona Revised Statutes)

I. FACILITY INFORMATION:

Business Name: DIRECTV Operations LLC
Facility Name: DIRECTV Southwest Uplink Facility (SWUF)
Responsible Official: Mr. Robert Levin
Contact: Mr. Robert Levin
Source Location: 9608 E. Old Vail Rd, Rita Ranch Commerce Center
Tucson, AZ 85747

II. AUTHORIZED EQUIPMENT: EMERGENCY

ATO #	Manufacturer	Model #	Serial Number/ ID number	Maximum Rated Capacity (HP)	Allowable Hours of Operation	Model year/ Applicability Date[1]	Allowable Fuel(s)
6100-1P	Kohler Power Systems	1000REO2V	2118776	1495	100	9/2006	diesel
6100-2P	Kohler Power Systems	1000REO2V	2118778	1495	100	9/2006	diesel

[1]The most recent date of order, manufacture, reconstruction, or modification.

III. SUPPLEMENTAL REQUIREMENTS

The following requirements apply in addition to the *Specific Conditions, Attachment 1 and Attachment 2*:

ATO #	Applicable NSPS Attachment(s)	NOx (g/hphr)	NMHC (g/hphr)	NMHC+NOx (g/hphr)	CO (g/hphr)	PM (g/hphr)	Certified Emissions Life (term, date)
6100-1P	Pre-2007, Emergency Attachment 4	6.9	1.0	---	8.5	0.40	8,000 hours or 10 years, whichever comes first
6100-2P	Pre-2007, Emergency Attachment 4	6.9	1.0	---	8.5	0.40	8,000 hours or 10 years, whichever comes first

September 5, 2013
SIGNATURE ATO ISSUE DATE

June 30, 2018
EXPIRATION DATE

Mukonde Chama, P.E., Air Permits Manager, PDEQ
TITLE