

**ATTACHMENT 2**

**AUTHORIZATION TO OPERATE (ATO)**  
**UNDER PDEQ GENERAL AIR QUALITY CONTROL PERMIT FOR NSPS GENERATORS/ ENGINES**  
 (As required by Title 49, Chapter 3, Article 2, Section 49-480, Arizona Revised Statutes)

**I. FACILITY INFORMATION:**

Business Name: US BORDER PATROL, TUCSON SECTOR  
 Facility Name: AJO BORDER PATROL STATION  
 Responsible Official: ZACHARY EVANS  
 Contact: ZACHARY EVANS  
 Source Location: 850 N. HIGHWAY 85  
 WHY, AZ 85321

**II. AUTHORIZED EQUIPMENT: EMERGENCY**

ATO #	Manufacturer	Model #	Serial Number/ ID number	Maximum Rated Capacity (HP)	Allowable Hours of Operation <sup>1</sup>	Model year/ Applicability Date <sup>2</sup>	Allowable Fuel(s)
6137-01	KOHLER	100REOZDD	3024706	1341	100	2011	DIESEL

<sup>1</sup>Allowable hours of operation for emergency generators are limited to maintenance testing and readiness checks. There is no limit on hours of operation during true emergencies.

<sup>2</sup>The most recent date of order, manufacture, reconstruction, or modification.

**III. SUPPLEMENTAL REQUIREMENTS**

The following requirements apply in addition to the *Specific Conditions, Additional Permit Conditions and Attachment(s): 2*:

ATO #	Applicable NSPS Attachment(s)	NOx (g/hphr)	NMHC (g/hphr)	NMHC+NOx (g/hphr)	CO (g/hphr)	PM (g/hphr)	Certified Emissions Life (term, date)
6137-01	Post Model 2007	---	---	4.8	2.6	0.15	8000 hours or 10 years, whichever comes first



December 9, 2013  
 SIGNATURE ATO ISSUE DATE

June 30, 2018  
 EXPIRATION DATE

Scott Porter, Environmental Quality Manager, PDEQ  
 TITLE