Pima County Department of Environmental Quality

ATTACHMENT 2

AUTHORIZATION TO OPERATE (ATO)
UNDER PDEQ GENERAL AIR QUALITY CONTROL PERMIT FOR NSPS GENERATORS/ ENGINES
(As required by Title 49, Chapter 3, Article 2, Section 49-480, Arizona Revised Statutes)

I. FACILITY INFORMATION:

Business/Facility Name: Oro Valley Police Department
Responsible Official: Lt. John Teachout
Contact: Lt. John Teachout, Police Lieutenant
Source Location: 11000 N La Canada, Oro Valley, AZ 85737

II. AUTHORIZED EQUIPMENT: EMERGENCY GENERATOR

ATO #	Manufacturer	Model #	Serial Number/ ID number	Maximum Rated Capacity (HP)	Allowable Hours of Operation[1]	Model year/ Applicability Date[2]	Allowable Fuel(s)
6155	Cummins	QSL9-G7	F130515369	464	100	2013	Diesel

[1]Allowable hours of operation for emergency generators are limited to maintenance testing and readiness checks. There is no limit on hours of operation during true emergencies.
[2]The most recent date of order, manufacture, reconstruction, or modification.

III. SUPPLEMENTAL REQUIREMENTS

The following requirements apply in addition to the *Specific Conditions, Additional Permit Conditions and Attachment(s): 2*:

ATO #	Applicable NSPS Attachment(s)	NOx (g/hphr)	NMHC (g/hphr)	NMHC+NOx (g/hphr)	CO (g/hphr)	PM (g/hphr)	Useful Life (term, date)
6155	Post Model 2007	--	--	3.0	2.6	0.15	8,000 hours or 10 years, whichever comes first

July 10, 2013 — June 30, 2018
SIGNATURE — ATO ISSUE DATE — EXPIRATION DATE

Mukonde Chama, P.E., Air Permits Manager, PDEQ
TITLE