

ATTACHMENT 2

**AUTHORIZATION TO OPERATE (ATO)
UNDER PDEQ CLASS II GENERAL AIR QUALITY OPERATING PERMIT
For
NSPS GENERATOR(S)/ ENGINES**



I. FACILITY INFORMATION:

Business Name: U.S. Department of Homeland Security (DHS)
Facility Name: Custom and Border Protection Housing
Responsible Official: Mr. Robin Coachman, Sr.
Source Location: 55 Sahuaro Housing Complex, Ajo, Arizona, 85321

II. AUTHORIZED EQUIPMENT: Emergency Generators

ATO #	Manufacturer	Model	ID/Serial Number	Maximum Rated Capacity	Allowable Hrs of Operation ¹	Manufacture Date ²	Allowable Fuel(s)
6162-1	Cummins	250DQDAA	E120340597	464 BHP	100	7/5/2012	Diesel
6162-2	Cummins	250DQDAA	E120340598	464 BHP	100	7/5/2012	Diesel

¹ Allowable hours of operation for emergency generators are limited to maintenance testing and readiness checks. There is no limit on hours of operation during true emergencies.

² The most recent date of order, manufacture, reconstruction, or modification.

III. SUPPLEMENTAL REQUIREMENTS:

The following requirements apply in addition to the *Specific Conditions, Additional Permit Requirements and Attachment(s): 5*

ATO #	Applicable NSPS Attachment(s)	NO _x (g/hp-hr)	NMHC (g/hp-hr)	NMHC+NO _x (g/hp-hr)	CO (g/hp-hr)	PM (g/hp-hr)	Certified Emissions Life (term, date)
6162-1 6162-2	Post Model 2007	--	--	3.0	2.6	0.15	8,000 hours or 10 years, whichever comes first.



Scott Porter, Environmental Quality Manager, PDEQ

ATO Issue Date:	April 28, 2014
ATO Revised:	N/A
ATO Expiration Date:	June 30, 2018