

ATTACHMENT 2

AUTHORIZATION TO OPERATE (ATO)
UNDER PDEQ GENERAL AIR QUALITY CONTROL PERMIT FOR NON-NSPS GENERATORS
 (As required by Title 49, Chapter 3, Article 2, Section 49-480, Arizona Revised Statutes)

I. FACILITY INFORMATION:

Business Name: GENERAL/SERVICES ADMINISTRATION
 Facility Name: EVO A. DECONCINI COURTHOUSE
 Responsible Official: WENDY WILLIAMSON
 Contact: WENDY WILLIAMSON
 Source Location: 405 W. CONGRESS, TUCSON, AZ 85701

II. AUTHORIZED EQUIPMENT:

ATO #	Manufacturer	Model	Serial Number/ ID number	Maximum Rated Capacity of Equipment	Allowable Hours of Operation ¹	Manufacture Date ²	Allowable Fuel(s)
1094-01	KOHLER	750ROZD	395954	1170	500 Maintenance/ Testing Unlimited Emergency	1997	Diesel

¹Allowable hours of operation for emergency generators are limited to maintenance testing and readiness checks. There is no limit on hours of operation during true emergencies.

²The most recent date of order, manufacture, reconstruction, or modification.



SIGNATURE

January 5, 2012
 ATO ISSUE DATE

October 8, 2013
 ATO AMENDED

January 4, 2017
 EXPIRATION DATE

Mukonde Chama, P.E., Air Permits Supervisor, PDEQ
 TITLE