

ATTACHMENT 2

AUTHORIZATION TO OPERATE (ATO)
UNDER PDEQ GENERAL AIR QUALITY CONTROL PERMIT FOR NON-NSPS GENERATORS
 (As required by Title 49, Chapter 3, Article 2, Section 49-480, Arizona Revised Statutes)

I. FACILITY INFORMATION:

Business Name: CENTRAL ARIZONA WATER CONSERVATION DISTRICT
 Facility Name: TWIN PEAKS OFFICE COMPLEX AND PUMPING PLANT
 Responsible Official: THOMAS E. CURRY
 Contact: GREG HAHN
 Source Location: 10900 W. TWIN PEAKS ROAD, MARANA, AZ 85653

II. AUTHORIZED EQUIPMENT:

ATO #	Manufacturer	Model	Serial Number/ ID number	Maximum Rated Capacity of Equipment	Allowable Hours of Operation ¹	Manufacture Date ²	Allowable Fuel(s)
185-01	CUMMINS	855 NTA	11499268	536	500 Maintenance/ Testing Unlimited Emergency	10/26/1998	Diesel
185-02	CUMMINS	855 NTA	30371267	535	500 Maintenance/ Testing Unlimited Emergency	7/23/20004	Diesel

¹Allowable hours of operation for emergency generators are limited to maintenance testing and readiness checks. There is no limit on hours of operation during true emergencies.

²The most recent date of order, manufacture, reconstruction, or modification.



SIGNATURE

January 5, 2012
 ATO ISSUE DATE

January 4, 2017
 EXPIRATION DATE

Mukonde Chama, P.E., Air Permits Supervisor, PDEQ
 TITLE