

**ATTACHMENT 2**

**AUTHORIZATION TO OPERATE (ATO)**  
**UNDER PDEQ GENERAL AIR QUALITY CONTROL PERMIT FOR NON-NSPS GENERATORS**  
 (As required by Title 49, Chapter 3, Article 2, Section 49-480, Arizona Revised Statutes)

**I. FACILITY INFORMATION:**

Business Name: MCI  
 Facility Name: VERIZON BUSNIESS  
 Responsible Official: TODD HARRIS  
 Contact: TODD HARRIS  
 Source Location: 75 E. ALAMEDA, TUCSON, AZ 85701

**II. AUTHORIZED EQUIPMENT:**

| ATO #   | Manufacturer    | Model    | Serial Number/<br>ID number | Maximum Rated<br>Capacity of<br>Equipment | Allowable Hours of<br>Operation <sup>1</sup>          | Manufacture<br>Date <sup>2</sup> | Allowable Fuel(s) |
|---------|-----------------|----------|-----------------------------|---|---|----------------------------------|-------------------|
| 1880-01 | CUMMINS<br>ONAN | KTA19-G4 | D980719599                  | 775                                       | 500 Maintenance/<br>Testing<br>Unlimited<br>Emergency | 1/1/1999                         | Diesel            |

<sup>1</sup>Allowable hours of operation for emergency generators are limited to maintenance testing and readiness checks. There is no limit on hours of operation during true emergencies.

<sup>2</sup>The most recent date of order, manufacture, reconstruction, or modification.



SIGNATURE

January 5, 2012  
 ATO ISSUE DATE

January 4, 2017  
 EXPIRATION DATE

Mukonde Chama, P.E., Air Permits Supervisor, PDEQ  
 TITLE