

**ATTACHMENT 2**

**AUTHORIZATION TO OPERATE (ATO)**  
**UNDER PDEQ GENERAL AIR QUALITY CONTROL PERMIT FOR NON-NSPS GENERATORS**  
 (As required by Title 49, Chapter 3, Article 2, Section 49-480, Arizona Revised Statutes)

**I. FACILITY INFORMATION:**

Business Name: CITY OF TUCSON, DEPARTMENT OF INFORMATION TECHNOLOGY  
 Facility Name: CITY OF TUCSON, DEPARTMENT OF INFORMATION TECHNOLOGY  
 Responsible Official: DIANE TENTSCHERT  
 Contact: LARRY ARMSTRONG  
 Source Location: 481 W. PASEO REDONDO RD, TUCSON, AZ 85701

**II. AUTHORIZED EQUIPMENT:**

ATO #	Manufacturer	Model	Serial Number/ ID number	Maximum Rated Capacity of Equipment	Allowable Hours of Operation <sup>1</sup>	Manufacture Date <sup>2</sup>	Allowable Fuel(s)
2136-01	CATERPILLAR	3412	81Z22180	993	500 Maintenance/ Testing Unlimited Emergency	1/1/1997	Diesel

<sup>1</sup>Allowable hours of operation for emergency generators are limited to maintenance testing and readiness checks. There is no limit on hours of operation during true emergencies.

<sup>2</sup>The most recent date of order, manufacture, reconstruction, or modification.



SIGNATURE

January 5, 2012  
 ATO ISSUE DATE

January 4, 2017  
 EXPIRATION DATE

Mukonde Chama, P.E., Air Permits Supervisor, PDEQ  
 TITLE