

ATTACHMENT 2

AUTHORIZATION TO OPERATE (ATO)
UNDER PDEQ GENERAL AIR QUALITY CONTROL PERMIT FOR NON-NSPS GENERATORS
 (As required by Title 49, Chapter 3, Article 2, Section 49-480, Arizona Revised Statutes)

I. FACILITY INFORMATION:

Business Name: TRICO ELECTRIC COOPERATIVE INC.
 Facility Name: GEORGE P. DAVIES GENERATING STATION
 Responsible Official: RON BROWN
 Contact: CHRIS FLEENOR
 Source Location: 13860 N. LOMA LINDA, MT. LEMMON, AZ 85653-0930

II. AUTHORIZED EQUIPMENT:

ATO #	Manufacturer	Model	Serial Number/ ID number	Maximum Rated Capacity of Equipment	Allowable Hours of Operation ¹	Manufacture Date ²	Allowable Fuel(s)
2198-01	GENERAC	SD1635	WA-521477- 1099	2162	500 Maintenance/ Testing Unlimited Emergency	8/1/2000	Diesel

¹Allowable hours of operation for emergency generators are limited to maintenance testing and readiness checks. There is no limit on hours of operation during true emergencies.

²The most recent date of order, manufacture, reconstruction, or modification.



SIGNATURE

January 5, 2012
 ATO ISSUE DATE

January 4, 2017
 EXPIRATION DATE

Mukonde Chama, P.E., Air Permits Supervisor, PDEQ
 TITLE