

**ATTACHMENT 2**

**AUTHORIZATION TO OPERATE (ATO)**  
**UNDER PDEQ GENERAL AIR QUALITY CONTROL PERMIT FOR NON-NSPS GENERATORS**  
 (As required by Title 49, Chapter 3, Article 2, Section 49-480, Arizona Revised Statutes)

**I. FACILITY INFORMATION:**

Business Name: FEDERAL AVIATION ADMINISTRATION-DMA TRACON  
 Facility Name: FAA TUCSON TRACON  
 Responsible Official: TERRI FRECKLETON  
 Contact: PEARY POLLEY  
 Source Location: 4445 PHOENIX ST BLDG 4816, TUCSON, AZ 85708

**II. AUTHORIZED EQUIPMENT:**

ATO #	Manufacturer	Model	Serial Number/ ID number	Maximum Rated Capacity of Equipment	Allowable Hours of Operation <sup>1</sup>	Manufacture Date <sup>2</sup>	Allowable Fuel(s)
3008-01	DETROIT DIESEL	6063MK35	06RO734714	490	500 Maintenance/ Testing Unlimited Emergency	5/1/2004	Diesel

<sup>1</sup>Allowable hours of operation for emergency generators are limited to maintenance testing and readiness checks. There is no limit on hours of operation during true emergencies.

<sup>2</sup>The most recent date of order, manufacture, reconstruction, or modification.



SIGNATURE

January 5, 2012  
 ATO ISSUE DATE

October 8, 2013  
 ATO AMENDED

January 4, 2017  
 EXPIRATION DATE

Mukonde Chama, P.E., Air Permits Supervisor, PDEQ  
 TITLE