

**ATTACHMENT 2**

**AUTHORIZATION TO OPERATE (ATO)**  
 UNDER PDEQ GENERAL AIR QUALITY CONTROL PERMIT FOR NON-NSPS GENERATORS  
 (As required by Title 49, Chapter 3, Article 2, Section 49-480, Arizona Revised Statutes)

**I. FACILITY INFORMATION:**

Business Name: CITIGROUP, UNIVERSITY SCIENCE & TECH PARK  
 Facility Name: CITIGROUP  
 Responsible Official: DAVID TINCOMBE  
 Contact: DAVID TINCOMBE  
 Source Location: 9060 S. RITA RD, TUCSON, AZ 85747

**II. AUTHORIZED EQUIPMENT:**

ATO #	Manufacturer	Model	Serial Number/ ID number	Maximum Rated Capacity of Equipment	Allowable Hours of Operation <sup>1</sup>	Manufacture Date <sup>2</sup>	Allowable Fuel(s)
3044-01	CATERPILLAR	3508B	CNB01066	1465	500 Maintenance/ Testing Unlimited Emergency	1/1/2004	Diesel

<sup>1</sup>Allowable hours of operation for emergency generators are limited to maintenance testing and readiness checks. There is no limit on hours of operation during true emergencies.

<sup>2</sup>The most recent date of order, manufacture, reconstruction, or modification.



SIGNATURE

January 5, 2012  
 ATO ISSUE DATE

January 4, 2017  
 EXPIRATION DATE

Mukonde Chama, P.E., Air Permits Supervisor, PDEQ  
 TITLE