

**ATTACHMENT 2**

**AUTHORIZATION TO OPERATE (ATO)**  
**UNDER PDEQ GENERAL AIR QUALITY CONTROL PERMIT FOR CLASS III GENERATORS**  
 (As required by Title 49, Chapter 3, Article 2, Section 49-480, Arizona Revised Statutes)

**I. FACILITY INFORMATION:**

Business Name: CORNERSTONE HOSPITAL OF SE ARIZONA, LLC  
 Facility Name: LTAC - HOSPITAL  
 Responsible Official: LOUISE CASSIDY  
 Contact: BETTY CAMPBELL  
 Source Location: 7220 E. ROSEWOOD STREET

**II. AUTHORIZED EQUIPMENT: EMERGENCY**

ATO #	Manufacturer	Model	Serial Number/ ID number	Maximum Rated Capacity of Equipment	Allowable Hours of Operation <sup>1</sup>	Manufacture Date <sup>2</sup>	Allowable Fuel(s)
314-01	DETROIT DIESEL	572RSL2032A- L000W	TE3375962	415KW	100	1987	Diesel

<sup>1</sup>Allowable hours of operation for emergency generators are limited to maintenance testing and readiness checks. There is no limit on hours of operation during true emergencies.

<sup>2</sup>The most recent date of order, manufacture, reconstruction, or modification.



SIGNATURE

February 5, 2014  
 ATO ISSUE DATE

January 4, 2017  
 EXPIRATION DATE

Scott Porter, Environmental Quality Manager, PDEQ  
 TITLE

IV. OTHER EQUIPMENT

The equipment listed below has been evaluated and determined not to currently require an air quality permit. In addition, the equipment is not subject to any federal standards.

Equipment	Model #	Serial Number/ ID number	Maximum Rated Capacity (MMBTU)	Allowable Hours of Operation <sup>1</sup>	Model year/ Applicability Date <sup>2</sup>	Allowable Fuel(s)
WATER HEATER	PVI 72125A-MXG	72P125A-MXG	0106117845	N/A	2006	Natural Gas
WATER HEATER	PVI 72125A-MXG	72P125-MXG	0106117846	N/A	2006	Natural Gas



*P. Scott Porter*

SIGNATURE

February 5, 2014  
ATO ISSUE DATE

January 4, 2017  
EXPIRATION DATE

Scott Porter, Environmental Quality Manager, PDEQ  
TITLE