

**AUTHORIZATION TO OPERATE (ATO)
UNDER PDEQ CLASS III GENERAL AIR QUALITY OPERATING PERMIT
For
Non NSPS/ Non NESHAP GENERATOR(S)**



I. FACILITY INFORMATION:

Business Name: ORO VALLEY HOSPITAL
 Facility Name: ORO VALLEY HOSPITAL
 Responsible Official: CHARLES SPENCER
 Source Location: 1551 E. TANGERINE ROAD, ORO VALLEY, AZ 85755

II. AUTHORIZED EQUIPMENT: EMERGENCY

ATO #	Manufacturer	Model	ID/Serial Number	Maximum Rated Capacity	Allowable Hrs of Operation ¹	Manufacture Date ²	Allowable Fuel(s)
3198-01	Caterpillar	3412	AFN00764	1180 HP	100	Pre-2006	Diesel
3198-02	Caterpillar	3412	AFN00765	1180 HP	100	Pre-2006	Diesel

¹ Allowable hours of operation for emergency generators are limited to maintenance testing and readiness checks. There is no limit on hours of operation during true emergencies.

² The most recent date of order, manufacture, reconstruction, or modification.

III. OTHER EQUIPMENT

The equipment listed below was provided in the application and has been evaluated and determined not to otherwise require an air quality permit. In addition, the equipment is not subject to any federal standards.

Equipment	Manufacturer	Model	Serial Number/ Unique ID	Maximum Rated Capacity	Allowable Fuel(s)	Date of Manufacture	Date of Installation
Boiler	Aerco	BMK-2.0 GWB	G-04-0141	2.0 MMBtu	Natural Gas	-	11/2004

ATO Issue Date:	August 12, 2014
ATO Revised:	N/A
ATO Expiration Date:	January 4, 2017


 Scott Porter, Environmental Quality Manager, PDEQ

**AUTHORIZATION TO OPERATE (ATO)
 UNDER PDEQ CLASS III GENERAL AIR QUALITY OPERATING PERMIT
 For
 Non NSPS/ Non NESHAP GENERATOR(S)**



III. OTHER EQUIPMENT (Continued)

Equipment	Manufacturer	Model	Serial Number/ Unique ID	Maximum Rated Capacity	Allowable Fuel(s)	Date of Manufacture	Date of Installation
Boiler	Aerco	BMK-2.0 GWB	G-04-0142	2.0 MMBtu	Natural Gas	-	11/2004
Boiler	Aerco	BMK-2.0 GWB	G-04-0143	2.0 MMBtu	Natural Gas	-	11/2004
Boiler	Aerco	BMK-2.0 GWB	G-04-0144	2.0 MMBtu	Natural Gas	-	11/2004
Water Heater	Aerco	KC-1000	G-04-139	1.0 MMBtu	Natural Gas	-	11/2004
Water Heater	Aerco	KC-1000	G-04-139	1.0 MMBtu	Natural Gas	-	11/2004
Storage Tank	ConVault	N/A	N/A	5200	Diesel		11/2004

ATO Issue Date:	August 12, 2014
ATO Revised:	N/A
ATO Expiration Date:	January 4, 2017


 Scott Porter, Environmental Quality Manager, PDEQ