

**AUTHORIZATION TO OPERATE (ATO)  
 UNDER PDEQ CLASS III GENERAL AIR QUALITY OPERATING PERMIT  
 For  
 Non NSPS/ Non NESHAP GENERATOR(S)**



**I. FACILITY INFORMATION:**

Business Name: TUCSON LOT 4, LLC/SUNQUEST  
 Facility Name: TUCSON LOT 4, LLC/SUNQUEST  
 Responsible Official: ELIZABETH JOHNSON  
 Source Location: 250 S. WILLIAMS CR, TUCSON, AZ 85711

**II. AUTHORIZED EQUIPMENT: EMERGENCY**

| ATO #   | Manufacturer | Model | ID/Serial Number | Maximum Rated Capacity | Allowable Hrs of Operation <sup>1</sup> | Manufacture Date <sup>2</sup> | Allowable Fuel(s) |
|---------|--------------|-------|------------------|------------------------|---|-------------------------------|-------------------|
| 3226-01 | GENERAC      | SD350 | 2087431          | 528                    | 100                                     | 2/2006                        | DIESEL            |

<sup>1</sup> Allowable hours of operation for emergency generators are limited to maintenance testing and readiness checks. There is no limit on hours of operation during true emergencies.

<sup>2</sup> The most recent date of order, manufacture, reconstruction, or modification.

|                      |                 |
|----------------------|-----------------|
| ATO Issue Date:      | August 14, 2014 |
| ATO Revised:         | N/A             |
| ATO Expiration Date: | January 4, 2017 |

  
 \_\_\_\_\_  
 Scott Porter, Environmental Quality Manager, PDEQ