ATTACHMENT 2

AUTHORIZATION TO OPERATE (ATO)

UNDER PDEQ GENERAL AIR QUALITY CONTROL PERMIT FOR NON-NSPS GENERATORS

(As required by Title 49, Chapter 3, Article 2, Section 49-480, Arizona Revised Statutes)

I. FACILITY INFORMATION:

Business Name: COMCAST OF ARIZONA, INC.
Facility Name: COMCAST OF ARIZONA, INC.
Responsible Official: KELLE MASLYN
Contact: SCOTT ANDERSON
Source Location: 8251 N. CORTARO RD, TUCSON, AZ 85743

II. AUTHORIZED EQUIPMENT:

ATO #	Manufacturer	Model	Serial Number/ ID number	Maximum Rated Capacity of Equipment	Allowable Hours of Operation[1]	Manufacture Date[2]	Allowable Fuel(s)
3310-01	CATERPILLAR	3406C	C5G00740	587	500 Maintenance/ Testing Unlimited Emergency	1/10/2006	Diesel

[1]Allowable hours of operation for emergency generators are limited to maintenance testing and readiness checks. There is no limit on hours of operation during true emergencies.
[2]The most recent date of order, manufacture, reconstruction, or modification.

January 5, 2012
SIGNATURE ATO ISSUE DATE

January 4, 2017
EXPIRATION DATE

Mukonde Chama, P.E., Air Permits Supervisor, PDEQ
TITLE