

ATTACHMENT 2

AUTHORIZATION TO OPERATE (ATO)
UNDER PDEQ GENERAL AIR QUALITY CONTROL PERMIT FOR NON-NSPS GENERATORS
 (As required by Title 49, Chapter 3, Article 2, Section 49-480, Arizona Revised Statutes)

I. FACILITY INFORMATION:

Business Name: ISC Partners, LLC
 Facility Name: ISC Tower
 Responsible Official: Mr. Zachary Fenton
 Contact: Mr. Scott Rathbun, RE Manager
 Source Location: 1 S. CHURCH AVE, TUCSON, AZ 85701

II. AUTHORIZED EQUIPMENT:

ATO #	Manufacturer	Model	Serial Number/ ID number	Maximum Rated Capacity of Equipment	Allowable Hours of Operation ¹	Manufacture Date ²	Allowable Fuel(s)
3648-01	CATERPILLAR	3508 STD	023Z01183	1207 HP	100	1/1/1986	Diesel

¹ Allowable hours of operation for generators are determined on a 12 month rolling total and limited to maintenance testing and readiness checks only. There is no limit on hours of operation during true emergencies.

Note: Should the generators operate or become contractually obligated for more than 15 hours a year for the purposes of emergency demand response and/or to stabilize voltage deviations of 5 percent or greater below standard voltage, or should the generators operate for non-emergency purposes to supply power as part of a financial arrangement with another entity, the generators would be subject to the National Emission Standards for Hazardous Air Pollutants (NESHAP) Subpart ZZZZ requirements as an area source and require a significant permit revision.

² The most recent date of order, manufacture, reconstruction, or modification.



Rupesh Patel, Air Permit Manager, PDEQ

ATO Issued Date:	February 10, 2016
ATO Revised Date:	N/A
ATO Expiration Date:	January 4, 2017