

ATTACHMENT 2

AUTHORIZATION TO OPERATE (ATO)
UNDER PDEQ GENERAL AIR QUALITY CONTROL PERMIT FOR NON-NSPS GENERATORS
 (As required by Title 49, Chapter 3, Article 2, Section 49-480, Arizona Revised Statutes)

I. FACILITY INFORMATION:

Business Name: APAC CUSTOMER SERVICE, INC.
 Facility Name: APAC CUSTOMER SERVICE, INC.
 Responsible Official: SHAYNE FARRELL
 Contact: TOBY BOWSER
 Source Location: 1650 S. RESEARCH LOOP, TUCSON, AZ 85710

II. AUTHORIZED EQUIPMENT:

ATO #	Manufacturer	Model	Serial Number/ ID number	Maximum Rated Capacity of Equipment	Allowable Hours of Operation ¹	Manufacture Date ²	Allowable Fuel(s)
602-01	CATERPILLAR	3412C	4RJ00689 3FZ02580	650	500 Maintenance/ Testing Unlimited Emergency	1/1/2001	Diesel

¹Allowable hours of operation for emergency generators are limited to maintenance testing and readiness checks. There is no limit on hours of operation during true emergencies.

²The most recent date of order, manufacture, reconstruction, or modification.



SIGNATURE

January 5, 2012
 ATO ISSUE DATE

January 4, 2017
 EXPIRATION DATE

Mukonde Chama, P.E., Air Permits Supervisor, PDEQ
 TITLE