

**AUTHORIZATION TO OPERATE (ATO)  
UNDER PDEQ CLASS III GENERAL AIR QUALITY OPERATING PERMIT  
For  
Non NSPS/ Non NESHAP GENERATOR(S)**



**I. FACILITY INFORMATION:**

Business Name: Raytheon Company  
 Facility Name: Raytheon Company Missile Systems  
 Responsible Official: Christine Stark  
 Source Location: 9030 S Rita Rd, Tucson AZ 85747

**II. AUTHORIZED EQUIPMENT:**

ATO #	Manufacturer	Model	ID/Serial Number	Maximum Rated Capacity	Allowable Hrs. of Operation <sup>1</sup>	Manufacture Date <sup>2</sup>	Allowable Fuel(s)
606-01	ONAN CHALMERS	670-T	17545191786	162	500 Maintenance/ Testing Unlimited Emergency	1980	Diesel
606-02	CATERPILLAR	3306 B	09NR03532	382	500 Maintenance/ Testing Unlimited Emergency	2001	Diesel
606-03	ONAN/ CHALMERS	20341J	A790389977	390	500 Maintenance/ Testing Unlimited Emergency	1980	Diesel
606-04	JOHN DEERE	6329DF01	49830IT	85	500 Maintenance/ Testing Unlimited Emergency	1980	Diesel
606-05	CUMMINS	NT855G5	30124061	355	500 Maintenance/ Testing Unlimited Emergency	1980	Diesel

<sup>1</sup> Allowable hours of operation for emergency generators are limited to maintenance testing and readiness checks. There is no limit on hours of operation during true emergencies.

<sup>2</sup> The most recent date of order, manufacture, reconstruction, or modification.

Rupesh Patel, Air Permit Manager, PDEQ

ATO Issue Date:	January 5, 2012
ATO Revised:	October 27, 2015
ATO Expiration Date:	January 4, 2017