

ATTACHMENT 2

**AUTHORIZATION TO OPERATE (ATO)
UNDER PDEQ CLASS III GENERAL AIR QUALITY OPERATING PERMIT
For
NON-NSPS GENERATOR(S)/ ENGINES**



I. FACILITY INFORMATION:

Business Name: CLPF MMIC DASCO TUCSON MOB LP
Facility Name: El Dorado Hospital
Responsible Official: Mona Deane, as Agent for Owner
Contact: Mona Deane
Source Location: 1400 N. WImot Rd, Tucson, AZ 85712

II. AUTHORIZED EQUIPMENT:

ATO #	Manufacturer	Model	ID/Serial Number	Maximum Rated Capacity	Allowable Hrs of Operation ¹	Manufacture Date ²	Allowable Fuel(s)
6117-01	SOLAR TURBINES	SATURN 10	SG82629	1207	500 Maintenance/ Testing Unlimited Emergency	1/1/2003	NATURAL GAS
6117-02	SOLAR TURBINES	SATURN 10	SG86509	1207	500 Maintenance/ Testing Unlimited Emergency	1/1/2003	NATURAL GAS

¹ Allowable hours of operation for emergency generators are limited to maintenance testing and readiness checks. There is no limit on hours of operation during true emergencies.

² The most recent date of order, manufacture, reconstruction, or modification.

Rupesh Patel, Air Permit Manager, PDEQ

ATO Issue Date:	January 5, 2012
ATO Revised:	November 19, 2014
ATO Expiration Date:	January 4, 2017