

**AUTHORIZATION TO OPERATE (ATO)
UNDER PDEQ CLASS III GENERAL AIR QUALITY OPERATING PERMIT
For
Non NSPS/ Non NESHAP GENERATOR(S)**



I. FACILITY INFORMATION:

Business Name: PIMA COUNTY REGIONAL WASTEWATER RECLAMATION DEPARTMENT (PCRWRD)
 Facility Name: WATER AND ENERGY SUSTAINABILITY CENTER (WESC)
 Responsible Official: JEFF PREVATT
 Source Location: 2955 W. CALLE AGUA NUEVA, TUCSON, AZ 85745

II. AUTHORIZED EQUIPMENT: EMERGENCY GENERATORS

ATO #	Manufacturer	Model	ID/Serial Number	Maximum Rated Capacity	Allowable Hrs of Operation ¹	Manufacture Date ²	Allowable Fuel(s)
6167-01	Elliot Magnatek	TAD1030GE	2100311524	378	100	Pre-2000	Diesel
6167-02	International	GCD325	WS4486N1196406	325	100	1999	Diesel

¹ Allowable hours of operation for emergency generators are limited to maintenance testing and readiness checks. There is no limit on hours of operation during true emergencies.

² The most recent date of order, manufacture, reconstruction, or modification.

III. OTHER EQUIPMENT

The equipment listed below has been evaluated and determined not to require an air quality permit. In addition, the equipment is not subject to any federal standards.

Equipment	Make/Model #	Serial Number/ ID Number	Maximum Rated Capacity (MMBTU/hr)	Allowable Hours of Operation ¹	Model year/ Applicability Date ²	Allowable Fuel(s)
Boiler	Thermal Solutions EVCA2000BN1	65251945	2MM Btu/hr	N/A	4-2011	Natural Gas
Boiler	Thermal Solutions EVCA2000BN1	65251946	2MM Btu/hr	N/A	4-2011	Natural Gas

ATO Issue Date:	7/15/2014
ATO Revised:	N/A
ATO Expiration Date:	January 4, 2017


 Scott Porter, Environmental Quality Manager, PDEQ