

ATTACHMENT 2

AUTHORIZATION TO OPERATE (ATO)
UNDER PDEQ GENERAL AIR QUALITY CONTROL PERMIT FOR NON-NSPS GENERATORS
 (As required by Title 49, Chapter 3, Article 2, Section 49-480, Arizona Revised Statutes)

I. FACILITY INFORMATION:

Business Name: PIMA COUNTY WASTEWATER MGMT; FIELDS OPS. DIVISION
 Facility Name: ARIZONA STATE PRISION
 Responsible Official: JOHN WARNER
 Contact: JOHN WARNER
 Source Location: 5900 E. OLD VAIL RD, TUCSON AZ 85706

II. AUTHORIZED EQUIPMENT:

ATO #	Manufacturer	Model	Serial Number/ ID number	Maximum Rated Capacity of Equipment	Allowable Hours of Operation ¹	Manufacture Date ²	Allowable Fuel(s)
675-01	DMT CORPORATION	DMT- 300CA2	94-4287-2	448	500 Maintenance/ Testing Unlimited Emergency	1994	Diesel

¹Allowable hours of operation for emergency generators are limited to maintenance testing and readiness checks. There is no limit on hours of operation during true emergencies.

²The most recent date of order, manufacture, reconstruction, or modification.



SIGNATURE

January 5, 2012
 ATO ISSUE DATE

January 4, 2017
 EXPIRATION DATE

Mukonde Chama, P.E., Air Permits Supervisor, PDEQ
 TITLE