

ATTACHMENT 2

**AUTHORIZATION TO OPERATE (ATO)
UNDER PDEQ CLASS III GENERAL AIR QUALITY OPERATING PERMIT
For
Non NSPS/ Non NESHAP GENERATOR(S)**



I. FACILITY INFORMATION:

Business Name: CONVERGYS CUSTOMER MANAGEMENT GROUP, INC.
Facility Name: SAME AS ABOVE
Responsible Official: JIM GRIFFIN - (904) 636-1168, Jim.griffin@convergys.com
Contact: RUEBEN BURROLA – Phone: 520-407-7305, ruben.burrola@convergys.com
Source Location: 3760 N. COMMERCE DRIVE, SUTIE 160, TUCSON, AZ 85705

II. AUTHORIZED EQUIPMENT:

| ATO # | Manufacturer | Model | ID/Serial Number | Maximum Rated Capacity | Allowable Hrs of Operation ¹ | Manufacture Date ² | Allowable Fuel(s) |
|--------|--------------|-------|------------------|------------------------|---|-------------------------------|-------------------|
| 785-01 | CATERPILLAR | SR4B | 8HG01390 | 749 | 100 | 1998 | Diesel |

¹ Allowable hours of operation for emergency generators are limited to maintenance testing and readiness checks. There is no limit on hours of operation during true emergencies.

² The most recent date of order, manufacture, reconstruction, or modification.

Rupesh Patel, Air Permit Manager, PDEQ

| | |
|----------------------|-----------------|
| ATO Issue Date: | 8/18/2015 |
| ATO Revised: | N/A |
| ATO Expiration Date: | January 4, 2017 |