

ATTACHMENT 2

AUTHORIZATION TO OPERATE (ATO)
UNDER PDEQ GENERAL AIR QUALITY CONTROL PERMIT FOR NON-NSPS GENERATORS
 (As required by Title 49, Chapter 3, Article 2, Section 49-480, Arizona Revised Statutes)

I. FACILITY INFORMATION:

Business Name: CITY OF TUCSON, TUCSON CONVENTION CENTER
 Facility Name: CITY OF TUCSON, TUCSON CONVENTION CENTER
 Responsible Official: TONY LARRIVEE
 Contact: DAN HOPPLER
 Source Location: 260 S. CHURCH AVE, TUCSON, AZ 85701

II. AUTHORIZED EQUIPMENT:

ATO #	Manufacturer	Model	Serial Number/ ID number	Maximum Rated Capacity of Equipment	Allowable Hours of Operation ¹	Manufacture Date ²	Allowable Fuel(s)
798-01	CUMMINS	GTA28	25276696	738	500 Maintenance/ Testing Unlimited Emergency	8/1/2003	NATURAL GAS
798-02	FORD	CSG-6491- 6005-F	02587-B-17-RT	40	500 Maintenance/ Testing Unlimited Emergency	1/1/1973	NATURAL GAS
798-03	WISCONSIN	VG4D	6141899	20	500 Maintenance/ Testing Unlimited Emergency	1/1/1973	NATURAL GAS



SIGNATURE

January 5, 2012
 ATO ISSUE DATE

January 4, 2017
 EXPIRATION DATE

Mukonde Chama, P.E., Air Permits Supervisor, PDEQ
 TITLE

¹Allowable hours of operation for emergency generators are limited to maintenance testing and readiness checks. There is no limit on hours of operation during true emergencies.
²The most recent date of order, manufacture, reconstruction, or modification.




SIGNATURE

January 5, 2012
ATO ISSUE DATE

January 4, 2017
EXPIRATION DATE

Mukonde Chama, P.E., Air Permits Supervisor, PDEQ
TITLE