



**PIMA COUNTY
PROCUREMENT DEPARTMENT
DESIGN AND CONSTRUCTION DIVISION**

130 W. CONGRESS STREET, 3rd FLOOR. TUCSON, AZ. 85701
PHONE: (520) 724-3731 FAX: (520) 724-4434

December 14, 2015

ADDENDUM NO. 03

PROJECT: IFB 197016 – CORONA DE TUCSON WRF DISINFECTION AND SERVICE
WATER PROJECT NO. 3CDT22

TO ALL CONTRACTORS:

Be advised of the additions, clarifications and/or changes to the above-referenced Invitation for Bid as stated in the following Addendum.

1. The *Bid Due Date and time* **REMAIN** *Wednesday, December 16, 2015 at 2:00 p.m.*
2. COUNTY has received a late question and is providing the question and its answer:
 - Q: Regarding the Precast "Chlorine Contact Basin", can it be cast in place vs precast? We are seeing extremely high cost to precast, transport and set.
 - A: A cast in place basin is acceptable, subject to an accepted, PE sealed, shop drawing submittal of a basin of similar dimensions and properties. However, due to the tight project schedule, no time extension will be awarded for the design, submittal and approval process of an alternate basin construction method. Construction Completion Time for this project is 210 Calendar Days and will not be changed to allow for re-design of the Chlorine Contact Basin. Completion time will start with issuance of Notice To Proceed.

This addendum is a total of **1 page**.

Any questions regarding this addendum should be directed to keith.rogers@pima.gov or by fax to 520-770-4012.

Any bid that fails to acknowledge any addendum that directly affects cost, scope or schedule will be rejected as non-responsive.

Keith E. Rogers, CPPB
Contracts Officer