



PROCUREMENT DEPARTMENT

DESIGN & CONSTRUCTION DIVISION • 130 W. CONGRESS STREET, 3RD FLOOR • TUCSON, ARIZONA 85701-1317
TELEPHONE (520) 724-3731 • FAX (520) 724-4434

June 17, 2016

ADDENDUM NO. 2

SOLICITATION NO. 220020 OLD VAIL MIDDLE SCHOOL, MARY ANN CLEVELAND WAY, VAIL (40LVMS). MARY ANN CLEVELAND WAY AT KUSH CANYON LANE, TUCSON (4TAMAC)

This Addendum addresses questions raised from June 14, 2016 through to 4:00 pm, June 16, 2016. This Addendum shall be incorporated and made part of the Bid Documents as though included therein. **This addendum is 2 pages.**

QUESTIONS/CLARIFICATIONS/REQUESTS FOR INFORMATION:

PRE-BID ATTENDANCE SIGN IN SHEET: The sign-in sheet for the pre-bid meeting held June 7, 2016, is available on the Pima County Procurement Department Design and Construction Division website at: <http://www.pima.gov/procure/ifbrfp-dc.htm> under the heading for this solicitation.

QUESTIONS:

Q) I am working on a bid for this Old Vail Middle School road project and I can't seem to find a special provisions section for the granite mulch. Is that available?

A) The Specifications have been modified as follows:

ITEM 8030040 – GRANITE MULCH

803-1 DESCRIPTION of the Standard Specifications is modified to add:

The work under this item shall consist of grading areas to be surfaced with decomposed granite and furnishing and installing for dust control in designated areas. Work shall be performed as detailed and noted shown on the project plans and in accordance with the requirements of these specifications

803-2 MATERIALS

803-2.02 Decomposed Granite of the Standard Specifications is modified to add:

Decomposed Granite for Landscaped Area Surfacing and Dust Control:

Decomposed granite for landscaped area surfacing and dust control shall be 3/4" minus meeting the following gradation:

<u>Sieve Size:</u>	<u>Percent Passing:</u>
1"	100%
3/4"	60% - 80%
1/2"	0% - 10%

The color of the decomposed granite used for landscaped area surfacing / dust control shall be "Desert Gold" as supplied by Kalamazoo Materials, or approved equal. Prior to delivering the 3/4" minus decomposed granite to the site, the Contractor shall submit to the Engineer for review and approval a 0.5 cubic foot sample of the material proposed for use on the project. No material shall be delivered to the site until the sample has been approved, in writing, by the Engineer.

All other requirements and terms of the Solicitation remain unchanged. Respondents are required to certify receipt of this addendum in their Bid Proposal. Failure to do so may result in declaration of the bid as non-responsive.

All questions shall be addressed in writing to Anthony V. Schiavone, Commodity/Contracts Officer, email anthony.schiavone@pima.gov or fax number 520-724-4434. Please submit them no later than Wednesday, June 15, 2016. Any questions submitted after the 15th might not get a response.

/s/Anthony V. Schiavone

Anthony V. Schiavone – Commodity/Contracts Officer