



## PIMA COUNTY

### PROCUREMENT DEPARTMENT

DESIGN & CONSTRUCTION DIVISION • 130 W. CONGRESS STREET, 3RD FLOOR • TUCSON, ARIZONA 85701-1317  
TELEPHONE (520) 724-3731 • FAX (520) 724-4434

September 14, 2015

### ADDENDUM NO. 2

#### **SOLICITATION NO. 191406 – ELEPHANT HEAD ROAD BRIDGE OVER THE SANTA CRUZ RIVER SUPERSTRUCTURE REPLACEMENT PROJECT**

This Addendum addresses questions raised through 2:00 pm on September 14, 2015. This Addendum shall be incorporated and made part of the Bid Documents as though included therein. **This addendum is 1 page.**

#### **QUESTIONS/CLARIFICATIONS/REQUESTS FOR INFORMATION:**

**PRE-BID ATTENDANCE SIGN IN SHEET:** The sign-in sheet for the pre-bid meeting held September 3, 2015, is available on the Pima County Procurement Department Design and Construction Division website at: <http://www.pima.gov/procure/ifbrfp-dc.htm> under the heading for this solicitation.

#### **QUESTIONS/CONCERNS:**

**Q)** In the special provisions its noted to have a 42 day bridge closure. Is this including the 28 day cure time for the deck as well as the concrete barrier walls?

**A)** There is a 10-day wet cure time for the concrete topping slab (deck) per Section 1006 of the Special Provisions, and there is cure time specified for the concrete traffic barriers in the Standard Specifications in Section 601. The barriers shall be constructed as per the Special Provisions in Item 6010634, Section 910 and 601 of the Standard Specifications, and per the plans.

All other requirements and terms of the Solicitation remain unchanged. Respondents are required to certify receipt of this addendum in their Bid Proposal. Failure to do so may result in declaration of the bid as non-responsive.

September 11, 2015 was the last day to submit a written question and receive a response. Additional questions will not be entertained.

*/s/Anthony V. Schiavone*

---

Anthony V. Schiavone – Commodity/Contracts Officer