



**PROCUREMENT DEPARTMENT**

DESIGN & CONSTRUCTION DIVISION • 130 W. CONGRESS STREET, 3RD FLOOR • TUCSON, ARIZONA 85701-1317  
TELEPHONE (520) 724-3731 • FAX (520) 724-4434

December 28, 2015

**ADDENDUM NO. 1**

**SOLICITATION NO. 202583 – SUNSET ROAD: SILVERBELL ROAD TO INTERSTATE 10**

This Addendum addresses questions raised through 1:00 pm on December 28, 2015. This Addendum shall be incorporated and made part of the Bid Documents as though included therein. **This addendum is 2 pages.**

**STANDARD SPECIFICATIONS, SECTION 602 – PRESTRESSING CONCRETE:**

**602-1 DESCRIPTION:** of the Standard Specifications is modified to add:

All precast, prestressed structural concrete bridge members shall be transported and erected in place by a contractor certified by the Precast/Prestressed Concrete Institute (PCI) as a Certified Erector.

**QUESTIONS/CLARIFICATIONS/REQUESTS FOR INFORMATION:**

**Q. 1)** Prior to our securing the plans and specs, might you be able to tell me if there is any permanent fencing to bid on this project?

**A. 1)** In the Bid Schedule there are two items for fencing: Chain Link Fence, Type 1 (48”) for a quantity of 950 LF and Fence (Special) for a quantity of 526 LF.

**Q. 2)** Will there be handrail in this project?

**A. 2)** In the Bid Schedule there is Line Item 9330008, Handrail (Std Dtl 105) (Standard Lower Rail Location) for a quantity of 299 CY.

**Q. 3)** Is there any chance you could direct me on where to get an excel copy for the bid items for this project?

**A. 3)** An excel Bid Schedule will be made available on the Procurement web site per Addendum 1.

**BID SCHEDULE:**

A submittable Excel spreadsheet is available on the Procurement website that can be used to submit your bid – you will need to enter the formulas to complete the spreadsheet. The page breaks are set up to print each page with a company name and initial block at the bottom of each page and the signature block on the last page. **Do not alter the page breaks.** If you wish to use the submittable bid schedule form, print out your completed spreadsheet, initial each page, sign the last page, and submit with your sealed bid. Spreadsheets will not be accepted electronically – it must be printed out and submitted with your bid submission.

Use of the Excel™ file is at the bidder’s sole risk. Updates to the Bid Schedule during advertisement will be posted via addendum. Bidder is responsible for making updates to the spreadsheet as applicable.

*In the case of any discrepancy between the electronic files and the hardcopy Bid Documents, the Bid Documents shall prevail.*

All other requirements and terms of the Solicitation remain unchanged. Respondents are required to certify receipt of this addendum in their Bid Proposal. Failure to do so may result in declaration of the bid as non-responsive.

**All questions shall be addressed in writing to Anthony V. Schiavone, Commodity/Contracts Officer, email [anthony.schiavone@pima.gov](mailto:anthony.schiavone@pima.gov) or fax number 520-724-4434.** Please submit them no later than January 13, 2016. Any questions submitted after the 13th might not get a response.

*/s/Anthony V. Schiavone*

---

Anthony V. Schiavone – Commodity/Contracts Officer