



---

# MEMORANDUM

---

Date: August 9, 2017

To: The Honorable Chair and Members  
Pima County Board of Supervisors

From: C.H. Huckelberry  
County Administrator

A handwritten signature in black ink, appearing to read "C.H. Huckelberry", is written over the typed name and title.

Re: **The Region's Largest Renewable Resource Provider**

Pima County is the only county in Arizona to operate a regional wastewater reclamation system. This system is designed to be a regional system and operate primarily with large, regional-scale facilities to convert sewage into reusable water at the lowest possible cost.

Attached for your review is the 2016 Effluent Generation and Utilization Report. This is an annual report I requested to be prepared by our Regional Wastewater Reclamation Department (RWRD) to highlight the benefits of a regional wastewater system. Wastewater reclamation is often viewed as a public health issue, but it is also a significant issue associated with renewable resources and conservation.

The report indicates that last year, RWRD treated over 60,000 acre-feet of sewage and converted it to renewable water. This reusable water has been used to provide source water to the City of Tucson's reclaimed water distribution system and to discharge clean water to the Santa Cruz River, improving its livability and biodiversity. I previously reported on the Regional Flood Control District's Living Rivers Project, which relies heavily on the discharge of clean water as the river's water source.

Natural Resources, Parks and Recreation, RFCD, Transportation Department and the Kino Sports Complex (KSC) all use a substantial amount of water whose genesis was sewage. It is important to understand that in the case of KSC, turf irrigation water is not only supplied through reclaimed water, but through Arizona's largest urban water harvesting project. Last year alone, over 100 million gallons of urban stormwater were harvested to provide turf irrigation at KSC.

The table in Section VI of the 2016 Effluent Generation and Utilization Report illustrates the various generation and uses of reclaimed water throughout the region. While nearly 34,000 acre feet is delivered to in-channel recharge to the Santa Cruz River, various owners of this effluent only receive a 50 percent credit for this recharge or nearly 16,000 acre-feet. This arbitrary standard imposed by the Arizona Department of Water Resources is, unfortunately, creating an incentive to remove discharged effluent from the Santa Cruz River; an action

The Honorable Chair and Members, Pima County Board of Supervisors  
Re: **The Region's Largest Renewable Resource Provider**  
August 9, 2017  
Page 2

that if allowed, will destroy the riparian habitat and diverse water-based ecological systems now established downstream of points of discharge.

CHH/anc

Attachment

c: Carmine DeBonis, Jr., Deputy County Administrator for Public Works  
Nanette Slusser, Assistant County Administrator for Public Works  
Jackson Jenkins, Director, Regional Wastewater Reclamation  
Linda Mayro, Director, Office of Sustainability and Conservation



**Pima County Regional Wastewater Reclamation Department**

# **EFFLUENT GENERATION AND UTILIZATION REPORT 2016**



Photo by Marilyn M. ICC



**Prepared by:**  
**James DuBois, Permit & Regulatory Compliance Officer**  
**Anna Martin, Senior Hydrologist**  
**Pima County RWRD**  
**Compliance & Regulatory Affairs Office**  
**(520) 724-6200**



**TABLE OF CONTENTS**

**I. Executive Summary ..... 1**

**II. Benefits of Effluent/Reclaimed Water as a Resource..... 5**

**III. Effluent Generated at Regional and Sub-Regional Wastewater Reclamation Facilities..... 6**

    A. Metropolitan Facilities..... 6

        1. Tres Rios Wastewater Reclamation Facility ..... 6

        2. Agua Nueva Wastewater Reclamation Facility ..... 7

        3. Randolph Park Wastewater Reclamation Facility..... 8

        4. Metropolitan Facilities Summary Table ..... 9

        5. Metropolitan Facilities Historical Data ..... 9

        6. Metropolitan Facilities Map ..... 12

    B. Non-Metropolitan Sub-Regional Facilities..... 13

        1. Arivaca Junction Wastewater Reclamation Facility ..... 13

        2. Avra Valley Wastewater Reclamation Facility..... 13

        3. Corona de Tucson Wastewater Reclamation Facility ..... 14

        4. Green Valley Wastewater Reclamation Facility ..... 15

        5. Mt. Lemmon Wastewater Reclamation Facility ..... 15

        6. Pima County Fairgrounds Wastewater Reclamation Facility ..... 16

        7. Sub-Regional Facilities Summary ..... 17

        8. Summary Table of All Facilities ..... 18

        9. Non-Metropolitan Facilities Map ..... 19

**IV. Reclaimed Water for Reuse, Environmental Restoration and Underground Storage (Groundwater Recharge)..... 20**

    A. Reclaimed Water Wheeled Through Tucson Water Reclaimed System ..... 20

    B. Environmental Restoration with Reclaimed Water ..... 23

    C. Underground Storage (Groundwater Recharge) of Effluent..... 25

    D. Summary of Use or Distribution of Pima County’s Metropolitan Effluent Allotment ..... 26

**V. Effluent Entitlements ..... 27**

    A. 1979 Intergovernmental Agreement, Resolution No. 1979 - 78..... 27

    B. Southern Arizona Water Rights Settlement Act (SAWRSA)..... 27

    C. City of Tucson-Pima County Supplemental Intergovernmental Agreement Relating to Effluent, Resolution No. 2000-28..... 27

    D. Conservation Effluent Pool Agreement..... 28

    E. Intergovernmental Agreement between the COT and PC for Treating Effluent and Wheeling Reclaimed Water (Wheeling Agreement), Resolution No. 2003-286..... 28

    F. Intergovernmental Agreement-Permitting and Operating Managed In-Channel Recharge of Effluent in the Santa Cruz River Channel (Managed Recharge IGA 2003)..... 28


**VI. Effluent Generation and Use in the Tucson Active Management Area (TAMA)..... 29**

**VII. Glossary of Terms & Acronyms..... 32**

## I. Executive Summary

The Pima County Regional Wastewater Reclamation Department (RWRD) is dedicated to the goal of protecting public health and the environment in a manner sustainable and beneficial to current citizens and future generations. RWRD meets this commitment through the significant use of reclaimed water for groundwater recharge, reuse, and environmental restoration. Our activities in this regard aid in mitigating demand on potable water systems, thereby sustaining groundwater levels and preserving green infrastructure throughout our community.


During 2016, RWRD operated eight treatment facilities, and this report provides a narrative description of the different wastewater treatment processes used at each facility along with the quantity of wastewater received and the amount of effluent produced. During calendar year 2016, RWRD facilities treated wastewater to produce a total of 64,588 acre-feet (AF) of effluent. Figure 1 shows the contributions to total effluent generation in 2016 by RWRD facilities. Tres Rios (formerly known as Ina Rd) Wastewater Reclamation Facility (WRF) and Agua Nueva WRF (replacement facility for the closed Roger Road WRF) represent the current metropolitan facilities identified by the 1979 Intergovernmental Agreement (IGA) between the City of Tucson (COT) and Pima County (PC). Metropolitan facilities generated the majority of effluent with total production at 60,656 AF. Non-metropolitan, sub-regional facilities produced the remaining portion, totaling 3,932 AF.



**Figure 1:** 2016 Effluent Production by Pima County RWRD Facilities – Total Volume Shown is 64,588 Acre-Feet.

**I. Executive Summary (Continued)**


Figure 2 illustrates the various modes of delivery or discharge for the total metropolitan and non-metropolitan effluent. RWRD delivered an appreciable portion of the total effluent volume, consisting of 18,799 AF, or more than 29%, to the City of Tucson’s Reclaimed Water System. In addition, direct delivery of reclaimed water by RWRD to other parties accounted for 1,636 AF. Reuse for landscape, construction, or dust control at WRF sites utilized 67 AF. Direct discharge to groundwater using various means, such as percolation beds and recharge basins, accounted for 2,297 AF. The balance of effluent, or 41,789 AF, was released through surface water discharge under the authorization of Arizona Pollution Discharge Elimination System (AZPDES) permits.



**Figure 2:** Effluent from All Pima County RWRD Facilities by Type of Discharge, Delivery, or Use for 2016

**I. Executive Summary (Continued)**

Figure 3 illustrates how the 1979 IGA and subsequent agreements govern effluent entitlement from the metropolitan facilities, and this report describes how Pima County’s share of the effluent entitlement was used. In 2016, the effluent allocation formula designated the fixed amount of 28,200 AF for the Bureau of Reclamation to manage under Southern Arizona Water Rights Settlement Act (SAWRSA). No effluent was used for the Conservation Effluent Pool. Of the remaining portion, 29,210 AF were accorded to the City of Tucson and other water providers, while Pima County retained 3,246 AF.




**Figure 3:** Effluent Entitlement from the Metropolitan Facilities

**I. Executive Summary (Continued)**

Figure 4 shows the manner in which Pima County’s share of metropolitan effluent was distributed in 2016. Reuse, either on-site at the WRFs or wheeled through the Reclaimed Water System, accounted for approximately 35% of the total. RWRD used 59.4% of its metropolitan effluent to serve as water delivery to underground storage facilities recharging the aquifer: the Lower Santa Cruz Managed Recharge Project (LSCMRP) and the High Plains Constructed Recharge Project. Pima County’s portion of the outflow from the storage reach on the Santa Cruz River comprised 177 AF, making up 5.5% of Pima County’s total metropolitan effluent allocation.

As a result of groundwater recharge project activities in 2016, Pima County will receive credit to its long-term storage account for 2,789.40 AF of effluent. This volume includes 424.47 AF of underground storage credits for its share of effluent discharged into the Lower Santa Cruz Managed Recharge Project and 600.00 AF for effluent diverted off-channel into the High Plains Effluent Recharge Project. Pima County received an additional 329.85 AF of underground storage credits for its non-metropolitan effluent recharged at the Corona de Tucson WRF, and 1,435.08 AF of underground storage credits at the Avra Valley WRF.



**Figure 4:** Distribution of Pima County’s Share of Metropolitan Effluent in 2016

## **II. Benefits of Effluent/Reclaimed Water as a Resource**

Reclaimed water is a vital, locally generated, renewable resource and a key component in Pima County's available water resources. Reclaimed water, as defined in A.R.S. §49-201(32) is water that has been treated or processed by a wastewater treatment plant. This water resource is regarded by a growing number of people as "recycled water" but is also sometimes referred to simply as "effluent." In 1989, the Arizona Supreme Court refused to characterize effluent as either surface water or groundwater, choosing instead to characterize it as "nothing more than sewerage effluent." This decision kept this part of the water supply from being regulated in the same manner as waters of the state. The Court held that local governments do not "own" the effluent, but have the right to put it to a beneficial use. Wastewater, treated to suitable reuse standards to protect public health as established by the Arizona Department of Environmental Quality (ADEQ), makes up a growing and increasingly important portion of Arizona's water supply.

Pima County has legislative authority under ARS §11-264 to construct and operate the regional wastewater system in Pima County. As such, the County is the major producer of effluent/reclaimed water in eastern Pima County.

Effluent/reclaimed water is generally used for three purposes:

- direct reuse
- environmental enhancement
- aquifer replenishment

Pima County uses its highly treated reclaimed water, much of it delivered through Tucson Water's reclaimed distribution system, to irrigate County parks, turf facilities and other landscape vegetation, to provide water for construction and dust control, and to sustain vegetation for environmental restoration projects. Using reclaimed water instead of potable supply for these purposes preserves our groundwater for the future. An additional use of the County's effluent/reclaimed water entitlement is long-term storage in underground storage (recharge) facilities. In this manner, reclaimed water is "banked" for future use and serves to replenish the aquifer until it is recovered.

### III. Effluent Generated at Regional and Sub-Regional Wastewater Reclamation Facilities

#### A. Metropolitan Facilities

##### 1. Tres Rios Wastewater Reclamation Facility

In recognition of the substantial reconfiguration and expansion at the Ina Road facility, it was renamed the Tres Rios WRF in 2013. RWRD's largest facility is located in the northwestern part of the Tucson basin and serves Oro Valley, Marana and the northwest portions of Tucson. The original facility was constructed in 1979 as a 25 Million Gallon per Day (MGD), High-Purity Oxygen (HPO), activated sludge process. Capacity at this facility was increased in 2006 with the addition of a 12.5 MGD, Biological Nutrient Removal Activated Sludge process, thereby increasing the overall combined plant capacity to 37.5 MGD. Completion of RWRD's Regional Optimization Master Plan allowed an increase in capacity to 50 MGD. A new plant interconnect pipeline between Agua Nueva WRF and Tres Rios WRF allows additional sewage flow to be diverted to the Tres Rios Facility. Other modifications include the following components:

- Expansion of preliminary and primary treatment facilities.
- New 25 MGD west train using 5-stage Bardenpho process to replace the HPO process.
- Replacement of Biological Nutrient Removal Activated Sludge process with a Bardenpho process train.
- New aeration tanks and secondary clarifiers for each train.
- New chlorine contact basins with chemical feed and mixing equipment.
- Additional biosolids processing facilities with new sludge thickening, anaerobic digestion, digested sludge thickening/dewatering, and final product storage and load-out facilities.

The addition of the Bardenpho process achieves compliance with regulatory requirements to reduce total nitrogen concentrations to 8 mg/L or less. This facility uses chlorination to disinfect and is permitted (mid-2016) for producing Class A+ reclaimed water. Effluent undergoes dechlorination prior to discharge.

The Tres Rios facility discharges into the Santa Cruz River under authorization of an AZPDES permit. Effluent discharged into the Santa Cruz River flows into the Lower Santa Cruz Managed Recharge Project (LSCMRP) which extends along the river channel from Ina Road to Trico Road. Groundwater storage credits are issued from the Arizona Department of Water Resources (ADWR) for half of the effluent that reaches the water table. Credits are apportioned among participants in the LSCMRP in accordance with IGAs that recognize each party's entitlement.

### III. Effluent Generated at Regional and Sub-Regional Wastewater Reclamation Facilities (Continued)

#### A. Metropolitan Facilities (Continued)

##### 1. Tres Rios Wastewater Reclamation Facility (Continued)

Tres Rios WRF					
Description			AFY	MG/Year	MGD Average
<b>Influent</b>			34,514.80	11,246.68	30.81
<b>Process Water</b>	<i>Used in industrial process at WRF, not included in effluent total used for allocations</i>		2,510.42	818.02	2.24
<b>Effluent Usage</b>	AZPDES discharge	<i>Outfall to Santa Cruz River, some available for storage credits</i>	33,678.13	10,974.05	30.07
	Reuse on-site	<i>N. and S. Irrigation and Fill Stand</i>	22.32	7.27	0.02
<b>Effluent Total</b>	<i>Used for calculation of effluent allocations</i>		33,700.45	10,981.33	30.09

##### 2. Agua Nueva Wastewater Reclamation Facility

The Agua Nueva WRF is located west of I-10 just south of El Camino del Cerro. This facility was built to replace the Roger Road WRF and began discharge in December 2013 in start-up mode. It services a population of approximately 500,000 people in the city of Tucson and has a capacity of 32 MGD. Similar to the Tres Rios upgrade, this new treatment facility utilizes a 5-stage Bardenpho treatment process to achieve nutrient removal.

The effluent produced at this facility can meet A+ reclaimed water standards, but is currently classified as Class B+ reclaimed water utilizing chlorination for disinfection. After dechlorination, it also meets AZPDES permit standards for the Santa Cruz River, as well as numeric Aquifer Water Quality Standards (AWQS). An average of nearly 17 MGD of the total effluent produced was sent to the City of Tucson Reclaimed Water System in 2016. A small percentage of treated effluent is reused for irrigation onsite, at the adjacent Pima County Water Campus, and to maintain wildlife ponds at the former Roger Road facility. The remaining portion of the effluent is discharged to the same outfall previously used by the Roger Rd WRF in the Santa Cruz River at an average rate of 7.2 MGD. Some of the treated wastewater becomes process water used in transporting biosolids pumped by pipeline to the Tres Rios WRF. Biosolids at Tres Rios are treated and transported off-site for use in agricultural land application and mine reclamation.

**III. Effluent Generated at Regional and Sub-Regional Wastewater Reclamation Facilities (Continued)**

**A. Metropolitan Facilities (Continued)**

**2. Agua Nueva Wastewater Reclamation Facility (Continued)**

Agua Nueva WRF					
Description		AFY	MG/Year	MGD Average	
<b>Influent</b>		28,073.66	9,147.83	25.06	
<b>Process Water</b>	<i>Used in biosolids flush water and other industrial processes at WRF, not included in effluent total used for allocations</i>		541.52	176.45	0.48
<b>Effluent Usage</b>	AZPDES discharge	<i>Outfall to Santa Cruz River, some available for storage credits</i>	8,111.29	2,643.07	7.24
	Delivered reclaimed water	<i>Input to COT reclaimed system</i>	18,799.24	6,125.75	16.78
	Reuse on-site	<i>Irrigation at WRF, CLC Irrigation and RR Pond</i>	44.78	14.59	0.04
<b>Effluent Total</b>	<i>Used for calculation of effluent allocations</i>		26,955.31	8,783.41	24.06

**3. Randolph Park Wastewater Reclamation Facility**

The Randolph Park WRF is located in midtown Tucson at the City-owned Randolph Park. This is a 3.5 MGD membrane bioreactor facility and utilizes an ultraviolet light disinfection system. This facility produces Class A effluent that is delivered directly into the COT’s Reclaimed Water System.

The Randolph Park WRF did not operate in 2016. In December 2014 the Randolph Park WRF was placed in temporary cessation by Pima County RWRD. This was done to realize some cost savings and to rely on the new metropolitan WRFs. Because reclaimed water was not produced by Randolph Park WRF, Pima County’s effluent was wheeled through Tucson Water’s Reclaimed Water System from Agua Nueva WRF. The wheeling rate used during FY 2016, as specified in the 2000 Supplemental IGA and 2003 Wheeling Agreement, was the Environmental/ Interruptible rate of \$274.65 per acre foot.

**III. Effluent Generated at Regional and Sub-Regional Wastewater Reclamation Facilities (Continued)**

**A. Metropolitan Facilities (Continued)**

**4. Metropolitan Facilities Summary Table**

Metropolitan Facilities - Overall Usage						
Description		Tres Rios WRF	Agua Nueva WRF	All Facilities		
		AFY		AFY	MG/Yr	MGD
<b>Influent Total</b>		34,514.80	28,073.66	62,588.46	20,394.51	55.88
<b>Process Water Total</b>		2,510.42	541.52	3,051.94	994.48	2.72
Effluent Usage	AZPDES Discharge	33,678.13	8,111.29	41,789.42	13,617.12	37.31
	Delivered to COT Reclaimed Water System	0.00	18,799.24	18,799.24	6,125.75	16.78
	Reuse on-site	22.32	44.78	67.10	21.86	0.06
<b>Effluent Total</b>		33,700.45	26,955.31	60,655.76	19,764.74	54.15

**5. Metropolitan Facilities Historic Data**

Year	Influent Received	Effluent Reused On-site at County WRFs	Effluent Discharged or Delivered to Reclaimed	Effluent Total
	AF	AF	AF	AF
<b>Tres Rios</b>				
2003	27,071.50	806.9	26,407.60	27,214.50
2004	28,714.70	605.6	27,925.50	28,531.10
2005	26,149.80	665.7	24,552.10	25,217.80
2006	25,854.40	613.2	24,968.10	25,581.30
2007	28,840.60	8.0	27,856.30	27,864.30
2008	32,192.00	22.2	31,545.70	31,567.90
2009	28,960.41	24.61	28,527.58	28,552.19
2010	28,982.23	48.06	28,821.21	28,869.27
2011	27,746.58	60.91	27,368.49	27,429.40
2012	25,227.94	56.91	24,390.54	24,447.45
2013	28,334.77	26.08	27,954.40	27,980.48
2014	36,292.58	9.71	35,995.70	36,005.41
2015	34,285.79	26.92	33,760.91	33,787.83
2016	34,514.80	22.32	33,678.13	33,700.45

### III. Effluent Generated at Regional and Sub-Regional Wastewater Reclamation Facilities (Continued)

#### A. Metropolitan Facilities (Continued)

##### 5. Metropolitan Facilities Historic Data (Continued)

Year	Influent Received AF	Effluent Reused On-site at County WRFs AF	Effluent Discharged or Delivered to Reclaimed AF	Effluent Total AF
<b>Roger Road</b>				
2003	41,991.90	119.7	40,862.20	40,981.90
2004	40,957.00	599	39,025.80	39,624.80
2005	43,239.00	13.6	42,311.50	42,325.10
2006	43,381.20	63	40,864.80	40,927.80
2007	40,730.70	60.1	37,763.20	37,823.30
2008	36,823.60	116.3	34,194.20	34,310.50
2009	37,542.80	107.73	35,339.57	35,447.30
2010	35,279.07	70.31	33,261.83	33,332.14
2011	36,327.65	84.23	34,258.96	34,343.19
2012	37,166.37	106.02	34,391.17	34,497.19
2013	32,700.14	103.35	29,907.98	30,011.33
2014	388.40	2.53	300.30	302.83
2015	0.00	0.00	0.00	0.00
2016	0.00	0.00	0.00	0.00
<b>Agua Nueva</b>				
2013	222.60	0.49	215.60	216.09
2014	24,252.07	55.78	23,488.06	23,543.84
2015	28,641.53	33.86	27,534.56	27,568.42
2016	28,073.66	44.78	26,910.53	26,955.31
<b>Randolph Park</b>				
2003	1.4	1.4	0	1.4
2004	114.7	0	97.5	97.5
2005	1,579.60	408.4	1,055.90	1,464.30
2006	2,785.40	679.5	1,878.50	2,558.00
2007	2,866.50	0.5	2,610.40	2,610.90
2008	2,973.60	0.3	2,661.60	2,661.90
2009	2,649.11	235.31	2,176.30	2,176.65
2010	2,738.75	0.30	2,337.37	2,337.67
2011	2,521.23	0.21	2,143.83	2,144.04
2012	2,816.99	0.22	2,447.78	2,448.00
2013	2,690.67	0.34	2,364.24	2,364.58
2014	2,618.01	0.20	2,267.63	2,267.83
2015	0.00	0.00	0.00	0.00
2016	0.00	0.00	0.00	0.00

**III. Effluent Generated at Regional and Sub-Regional Wastewater Reclamation Facilities (Continued)**

**A. Metropolitan Facilities (Continued)**


**5. Metropolitan Facilities Historic Data (Continued)**

<b>Year</b>	<b>Influent Received AF</b>	<b>Effluent Reused On-site at County WRFs AF</b>	<b>Effluent Discharged or Delivered to Reclaimed System AF</b>	<b>Effluent Total AF</b>
<b>Metropolitan Facility Totals</b>				
2003	69,064.80	927.9	67,269.90	68,197.80
2004	69,786.40	1,204.60	67,048.80	68,253.40
2005	70,968.40	1,087.70	67,919.50	69,007.20
2006	72,021.00	1,355.70	67,711.40	69,067.10
2007	72,437.80	68.6	68,229.90	68,298.50
2008	71,989.20	138.8	68,401.50	68,540.30
2009	69,152.32	367.65	66,043.45	66,411.10
2010	67,000.05	118.67	64,420.41	64,539.08
2011	66,595.46	145.35	63,771.28	63,916.63
2012	65,211.30	163.15	61,229.49	61,392.64
2013	63,948.18	130.26	60,442.22	60,572.48
2014	63,551.06	68.22	62,051.69	62,119.91
2015	62,927.32	60.78	61,295.47	61,356.25
2016	62,588.46	67.10	60,588.66	60,655.76

III. Effluent Generated at Regional and Sub-Regional Wastewater Reclamation Facilities (Continued)

A. Metropolitan Facilities (Continued)

6. Metropolitan Facilities Map



**III. Effluent Generated at Regional and Sub-Regional Wastewater Reclamation Facilities (Continued)**

**B. Non-Metropolitan Sub-Regional Facilities**

**1. Arivaca Junction Wastewater Reclamation Facility**

The Arivaca Junction WRF is located in the town of Amado, approximately 38 miles south of Tucson. It consists of a single, 3.2-acre, aerated lagoon with a permitted treatment capacity of 100,000 gallons per day (GPD). Chlorination is the method of disinfection. Effluent disposal is via evaporation, percolation through the base of the unlined pond, and reuse. Evaporation ranges from 7,000 to 14,000 GPD, while percolation is approximately 10,000 GPD. RWRD has a reuse agreement with Reventone Ranch to accept delivery of this facility’s Class C reclaimed water for restricted agricultural use.

Arivaca Junction WRF					
Description		AFY	MG/Year	MGD Average	
<b>Influent</b>		46.78	15.24	0.04	
<b>Process Water</b>	<i>Used in biosolids flush water and other industrial processes at WRF, not included in effluent total used for allocations</i>		0.00	0.00	0.00
<b>Effluent Usage</b>	Reclaimed, delivered to other parties	<i>Reventone Ranch</i>	14.12	4.60	0.01
	Groundwater Discharge	<i>Percolation through base of impoundment (estimated at 10,000 gallons per day)</i>	11.23	3.66	0.01
	Reuse on-site	<i>Irrigation at WRF</i>	0.02	0.01	0.00
<b>Effluent Total</b>			25.37	8.27	0.02

**2. Avra Valley Wastewater Reclamation Facility**

The Avra Valley WRF is located on the west side of the Tucson Mountains, approximately 20 miles southwest of Tucson. The treatment facility has a permitted capacity of 4.0 MGD using two oxidation ditches for achieving nitrification and denitrification. It utilizes sand filtration, and UV treatment is the method of disinfection. Effluent produced at this facility can meet Class A+, but is permitted for Class B+ reclaimed quality. Effluent is discharged primarily by percolation through five basins permitted for groundwater recharge. Also, on-site reuse is possible for irrigation and dust control, and limited surface water discharge to Black Wash is covered under an AZDPES permit.

**III. Effluent Generated at Regional and Sub-Regional Wastewater Reclamation Facilities (Continued)**

**B. Non-Metropolitan Sub-Regional Facilities (Continued)**

**2. Avra Valley Wastewater Reclamation Facility (Continued)**

Avra Valley WRF					
Description		AFY	MG/Year	MGD Average	
<b>Influent</b>		1,449.02	472.16	1.29	
<b>Process Water</b>	<i>Used in industrial processes at WRF, not included in effluent total used for allocations</i>		81.55	26.57	0.07
<b>Effluent Usage</b>	AZPDES Discharge	<i>Black Wash Spray Field</i>	0.00	0.00	0.00
	Groundwater Discharge	<i>Percolation beds and ponds - groundwater recharge with storage credit accrual</i>	1,459.41	475.55	1.30
	Reuse on-site	<i>Irrigation at WRF</i>	0.00	0.00	0.00
<b>Effluent Total<sup>1</sup></b>		1,459.41	475.55	1.30	

<sup>1</sup>A volume of 1,435.08 AF in storage credits was reported to ADWR for this recharge after subtracting evaporative losses (delivery volume discrepancy due to difference in timing of measurement during 2016).

**3. Corona de Tucson Wastewater Reclamation Facility**

The Corona de Tucson WRF is located 22 miles southeast of Tucson. The facility consists of two 0.5 MGD BNROD (oxidation ditch) treatment trains with closed loop reactors for achieving both nitrification and denitrification. This facility is not classified for reuse. Effluent is disposed into percolation basins designed and permitted for groundwater recharge. In 2016 a new chlorine contact basin and sodium hypochlorite feed system were added as the method of disinfection.

Corona de Tucson WRF					
Description		AFY	MG/Year	MGD Average	
<b>Influent</b>		332.81	108.45	0.30	
<b>Process Water</b>	<i>Used in industrial processes at WRF, not included in effluent total used for</i>		0.00	0.00	0.00
<b>Effluent Usage</b>	Groundwater Discharge	<i>Percolation beds and ponds - groundwater recharge with storage credit accrual</i>	331.65	108.07	0.30
<b>Effluent Total<sup>2</sup></b>		331.65	108.07	0.30	

<sup>2</sup>A volume of 329.85 AF in storage credits was reported to ADWR for this recharge after subtracting evaporative losses.

**III. Effluent Generated at Regional and Sub-Regional Wastewater Reclamation Facilities (Continued)**

**B. Non-Metropolitan Sub-Regional Facilities (Continued)**

**4. Green Valley Wastewater Reclamation Facility**

The Green Valley WRF is located approximately 29 miles south of Tucson and serves the town of Green Valley. This facility is comprised of two distinct treatment sequences. The first consists of a 2.0 MGD BNROD (oxidation ditch) achieving nitrification and denitrification. Sand filtration followed by chlorination of this effluent produces Class A+ reclaimed water. The reclaimed water is delivered to Robson/ Quail Creek for groundwater recharge. The other option for treatment at the facility can handle up to 2.1 MGD. It consists of two separate secondary aerated lagoons, two separate polishing ponds, and four percolation ponds. It produces the equivalent of Class B reclaimed water, but this stream is not classified for reuse in the Aquifer Protection Permit. Effluent from this portion of the facility is disposed of only through percolation. In 2016 an ADEQ permit amendment was issued to allow discharge of BNROD effluent into selected on-site percolation ponds.

Green Valley WRF						
Description		AFY	MG/Year	MGD Average		
<b>Influent</b>		2,102.28	685.03	1.88		
<b>Process Water</b>	<i>Used in industrial processes at WRF, not included in effluent total used for allocations</i>		0.00	0.00	0.00	
<b>Effluent Usage</b>	Reclaimed, delivered to other parties	<i>Effluent from BNROD to Robson/ Quail Creek for groundwater recharge</i>		1,621.44	528.35	1.45
	Groundwater Discharge	<i>Percolation ponds (Lagoon Facility) - groundwater recharge without storage credit accrual</i>		479.51	156.25	0.43
<b>Effluent Total</b>		2,100.95	684.60	1.88		

**5. Mt. Lemmon Wastewater Reclamation Facility**

The Mt. Lemmon WRF is located in the Village of Summerhaven in the Catalina Mountains. This facility operates under a special use permit issued by the United States Forest Service (USFS), which authorizes a treatment capacity of 17,000 gallons per day. The facility consists of a closed loop BNROD (oxidation ditch) for achieving both nitrification and denitrification. Effluent is disposed of through an off-site sprayfield, through a French drain, and through a surface water discharge to an unnamed tributary to the San Pedro River under an AZPDES permit. The facility currently is regulated by an APP general permit, so a reclaimed water classification is not possible. The spray application is to a restricted area of forest and is not regarded as reuse by ADEQ.

**III. Effluent Generated at Regional and Sub-Regional Wastewater Reclamation Facilities (Continued)**

**B. Non-Metropolitan Sub-Regional Facilities (Continued)**

**5. Mt. Lemmon Wastewater Reclamation Facility (Continued)**

Mt. Lemmon WRF					
Description			AFY	MG/Year	MGD Average
<b>Influent</b>			3.21	1.05	0.0029
<b>Process Water</b>	<i>Used in industrial processes at WRF, not included in effluent total used for</i>		0.00	0.00	0.0000
<b>Effluent Usage</b>	Groundwater Discharge	<i>Discharge to spray field, drain, or AZPDES release to unnamed tributary to San Pedro River</i>	3.06	1.00	0.0027
<b>Effluent Total</b>			3.06	1.00	0.0027

**6. Pima County Fairgrounds Wastewater Reclamation Facility**

The PC Fairgrounds WRF is located approximately 18 miles southeast of Tucson and serves the fairgrounds complex. This facility has a permitted capacity of 20,000 GPD. It uses stabilization lagoons and the effluent is disposed of through evaporation and percolation. The facility currently is regulated by an APP general permit, so a reclaimed water classification is not possible.

Pima County Fairgrounds WRF					
Description			AFY	MG/Year	MGD Average
<b>Influent</b>			12.02	3.92	0.0107
<b>Effluent Usage</b>	Groundwater Discharge	<i>Percolation</i>	12.02	3.92	0.0107

**III. Effluent Generated at Regional and Sub-Regional Wastewater Reclamation Facilities (Continued)**

**B. Non-Metropolitan Sub-Regional Facilities (Continued)**

**7. Sub-Regional Facilities Summary**

<b>Sub-Regional Facilities - Effluent Usage</b>										
		Arivaca	Ava Valley	Corona	Green Valley	Mt. Lemmon	Fair-grounds	All Facilities		
Description		AFY					AFY	MG/Yr	MGD	
<b>Influent Total</b>		<b>46.78</b>	<b>1,449.02</b>	<b>332.81</b>	<b>2,102.28</b>	<b>3.21</b>	<b>12.02</b>	<b>3,946.12</b>	<b>1,285.85</b>	<b>3.52</b>
<b>Process Water Total</b>		<b>0.00</b>	<b>81.55</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>81.55</b>	<b>26.57</b>	<b>0.07</b>
Effluent Usage	AZPDES Discharge		0.00					0.00	0.00	0.00
	Reclaimed, delivered to other parties	14.12			1,621.44			1,635.56	532.95	1.46
	Groundwater Discharge (basin, percolation bed, infiltration gallery, spray field)	11.23	1,459.41	331.65	479.51	3.06	12.02	2,296.88	748.44	2.05
	Reuse on-site	0.02	0.00					0.02	0.01	0.00
<b>Effluent Total</b>		<b>25.37</b>	<b>1,459.41</b>	<b>331.65</b>	<b>2,100.95</b>	<b>3.06</b>	<b>12.02</b>	<b>3,932.46</b>	<b>1,281.40</b>	<b>3.51</b>

**III. Effluent Generated at Regional and Sub-Regional Wastewater Reclamation Facilities (Continued)**

**B. Non-Metropolitan Sub-Regional Facilities (Continued)**


**8. Summary Table of All Facilities**

<b>All Facilities - Effluent Usage</b>					
	Metropolitan	Sub-Regional	All Facilities		
Description	AFY		AFY	MG/Yr	MGD
<b>Influent Total</b>	<b>62,588.46</b>	<b>3,946.12</b>	<b>66,534.58</b>	<b>21,680.36</b>	<b>59.40</b>
<b>Process Water Total</b>	<b>3,051.94</b>	<b>81.55</b>	<b>3,133.49</b>	<b>1,021.05</b>	<b>2.80</b>
AZPDES Discharge	41,789.42	0.00	41,789.42	13,617.12	37.31
Delivered to COT Reclaimed System	18,799.24		18,799.24	6,125.75	16.78
Reclaimed, delivered to other parties		1,635.56	1,635.56	532.95	1.46
Groundwater Discharge		2,296.88	2,296.88	748.44	2.05
Reuse on-site	67.10	0.02	67.12	21.87	0.06
<b>Effluent Total</b>	<b>60,655.76</b>	<b>3,932.46</b>	<b>64,588.22</b>	<b>21,046.14</b>	<b>57.66</b>

III. Effluent Generated at Regional and Sub-Regional Wastewater Reclamation Facilities (Continued)

B. Non-Metropolitan Sub-Regional Facilities (Continued)

9. Non-Metropolitan Facilities Map



**IV. Reclaimed Water for Reuse, Environmental Restoration and Underground Storage (Groundwater Recharge)**

**A. Reclaimed Water Wheeled Through Tucson Water Reclaimed System**

To take advantage of effluent as a renewable water supply, Pima County reuses a substantial volume of its wastewater for irrigation, construction, environmental restoration and other purposes. Most of this reuse is conducted by the Natural Resources, Parks and Recreation Department and the Kino Sports Complex/Kino Environmental Restoration Project. Pima County Regional Flood Control District and Pima County Department of Transportation also use reclaimed water for certain projects. RWRD periodically draws on the reclaimed supply for sewer line flushing and construction use. The supply of reclaimed water for various County sites is Class A reclaimed water wheeled through the City of Tucson Reclaimed Water System and delivered in the amounts shown in the following tables.

<b>Natural Resources, Parks and Recreation</b>			
<b>2016 Monthly Reclaimed Water Use</b>			
<b>Month</b>	<b>Gallons</b>	<b>Ccf</b>	<b>AF</b>
January	8,349,756	11,162.0	25.62
February	8,289,912	11,082.0	25.44
March	15,951,460	21,324.0	48.95
April	26,728,644	35,731.0	82.03
May	32,524,551	43,479.0	99.81
June	40,175,626	53,707.0	123.29
July	38,469,319	51,426.0	118.06
August	35,292,343	47,179.0	108.31
September	28,948,114	38,698.0	88.84
October	22,579,948	30,185.0	69.30
November	23,915,969	31,971.0	73.40
December	20,474,930	27,371.0	62.84
<b>Total</b>	<b>301,700,571</b>	<b>403,315.0</b>	<b>925.88</b>

<b>Regional Flood Control District</b>			
<b>2016 Monthly Reclaimed Water Use</b>			
<b>Month</b>	<b>Gallons</b>	<b>Ccf</b>	<b>AF</b>
January	68,073	91.0	0.21
February	60,592	81.0	0.19
March	262,566	351.0	0.81
April	238,629	319.0	0.73
May	399,460	534.0	1.23
June	595,449	796.0	1.83
July	526,629	704.0	1.62
August	238,629	319.0	0.73
September	693,444	927.0	2.13
October	347,844	465.0	1.07
November	219,927	294.0	0.67
December	127,169	170.0	0.39
<b>Total</b>	<b>3,778,410</b>	<b>5,051.0</b>	<b>11.60</b>

**IV. Reclaimed Water for Reuse, Environmental Restoration and Underground Storage (Groundwater Recharge) (Continued)**

**A. Reclaimed Water Wheeled Through Tucson Water Reclaimed System (Continued)**

<b>Department of Transportation</b>			
<b>2016 Monthly Reclaimed Water Use</b>			
<b>Month</b>	<b>Gallons</b>	<b>Ccf</b>	<b>AF</b>
January	3,740	5.0	0.01
February	0	0.0	0.00
March	18,342	24.5	0.06
April	18,342	24.5	0.06
May	18,342	24.5	0.06
June	0	0.0	0.00
July	0	0.0	0.00
August	0	0.0	0.00
September	0	0.0	0.00
October	0	0.0	0.00
November	0	0.0	0.00
December	0	0.0	0.00
<b>Total</b>	<b>58,767</b>	<b>78.6</b>	<b>0.18</b>

<b>Regional Wastewater Reclamation Department</b>			
<b>2016 Monthly Reclaimed Water Use *</b>			
<b>Month</b>	<b>Gallons</b>	<b>Ccf</b>	<b>AF</b>
January	1,496	2.0	0.00
February	0	0.0	0.00
March	0	0.0	0.00
April	0	0.0	0.00
May	0	0.0	0.00
June	0	0.0	0.00
July	0	0.0	0.00
August	0	0.0	0.00
September	0	0.0	0.00
October	0	0.0	0.00
November	0	0.0	0.00
December	0	0.0	0.00
<b>Total</b>	<b>1,496</b>	<b>2.0</b>	<b>0.00</b>

\*Water used for sewer line flushing.

**IV. Reclaimed Water for Reuse, Environmental Restoration and Underground Storage (Groundwater Recharge) (Continued)**

**A. Reclaimed Water Wheeled Through Tucson Water Reclaimed System (Continued)**

<b>Kino Sports Park &amp; KERP</b>			
<b>2016 Monthly Reclaimed Water Use</b>			
<b>Month</b>	<b>Gallons</b>	<b>Ccf</b>	<b>AF</b>
January	0	0.0	0.00
February	131,657	176.0	0.40
March	140,634	188.0	0.43
April	20,945	28.0	0.06
May	2,728,145	3,647.0	8.37
June	15,371,719	20,549.0	47.17
July	5,070,296	6,778.0	15.56
August	25,434	34.0	0.08
September	0	0.0	0.00
October	748	1.0	0.00
November	3,635,532	4,860.0	11.16
December	3,268,987	4,370.0	10.03
<b>Total</b>	<b>30,394,099</b>	<b>40,631.0</b>	<b>93.28</b>

<b>Historical Water Use at Kino Sports Park &amp; KERP</b>			
	<b>Reclaimed</b>		<b>Harvested Stormwater*</b>
<b>Year</b>	<b>Ccf</b>	<b>AF</b>	<b>AF</b>
2003	156,042.8	358.2	87.00
2004	143,723.0	329.9	30.70
2005	78,493.0	180.2	64.90
2006	171,955.0	394.8	0.00
2007	69,389.0	159.3	65.95
2008	81,916.0	188.1	95.85
2009	163,725.0	375.9	0.00
2010	56,140.0	128.9	88.53
2011	74,907.7	172.0	50.22
2012	94,651.0	217.3	36.79
2013	80,297.0	184.3	126.81
2014	76,132.0	174.8	149.39
2015	39,865.0	91.5	187.77
2016	40,631.0	93.3	318.14
<b>Total</b>	<b>1,327,867.5</b>	<b>3,048.4</b>	<b>1302.05</b>

\*2016 was a record high volume for stormwater harvested.

#### IV. Reclaimed Water for Reuse, Environmental Restoration and Underground Storage (Groundwater Recharge) (Continued)

##### A. Reclaimed Water Wheeled Through Tucson Water Reclaimed System (Continued)

Yearly Reclaimed Water Use by Pima County from Tucson Water's Reclaimed System			
Year	Gallons	Ccf	AF
2003	69,573,993	93,006.9	213.51
2004	86,118,658	115,123.9	264.29
2005	74,349,631	99,391.0	228.17
2006	92,822,026	124,085.0	284.86
2007	295,588,987	395,145.0	907.13
2008	302,590,005	404,504.0	928.61
2009	418,643,532	559,645.0	1,284.77
2010	317,788,925	424,822.0	975.26
2011	366,899,807	490,473.7	1,125.97
2012	330,454,192	441,753.0	1,014.13
2013	360,033,662	481,295.0	1,104.90
2014	360,110,712	481,398.0	1,105.14
2015	301,148,509	402,577.0	924.19
<b>2016</b>	<b>335,933,344</b>	<b>449,077.6</b>	<b>1,030.94</b>

##### B. Environmental Restoration with Reclaimed Water

As part of Pima County's Sustainable Action Plan begun in FY '09, RWRD began tabulating the volume of effluent used for environmental restoration or riparian enhancement at various projects and sites. For some of the listed projects, riparian vegetation is one of the multiple benefits derived from operating a groundwater recharge project.

#### IV. Reclaimed Water for Reuse, Environmental Restoration and Underground Storage (Groundwater Recharge) (Continued)

##### B. Environmental Restoration with Reclaimed Water

Environmental Restoration with Reclaimed Water			
Project Name	Volume (AF)	Multibenefit Recharge Project?	Comments
Kino Environmental Restoration Project (KERP)*	0.0		Reclaimed water was not needed for riparian vegetation at the site during the year. KERPs vegetation is usually supported with harvested stormwater, except in particularly dry years.
Lower Santa Cruz Managed Recharge Project	165.7	Yes	This volume represents Pima County's share of the total evapotranspiration (ET) from the managed recharge project. The total ET was 1043.50 AF, and this volume is split among the participants by an agreed upon allocation formula.
Marana High Plains Effluent Recharge Project	3.9	Yes	Delivery of 627.2 AF was diverted from Santa Cruz River. Calculated evapotranspiration of 3.9 AF is the portion of the delivery volume that supports riparian vegetation.
Rillito Riparian/Swan Wetlands*	0.3		Reclaimed water is being used for sustaining plants that were installed as part of this ecosystem restoration project.
Roger Rd WRF Pond	25.4		This volume is used to support a riparian and wildlife viewing pond adjacent to the Santa Cruz River on-site at the Roger Rd WRF.
Santa Cruz River- West Branch Bosques*	0.5		Small wetland area managed by PCRFCFCD. Reclaimed water used for vegetation establishment in water harvesting basins adjacent to existing mesquite bosque along West Branch of Santa Cruz River. Previously (2005-2011) provided drought relief for mature bosque vegetation.
Paseo de las Iglesias*	21.8		Project involves bank protection, paved pathway River Park with new vegetation, water harvesting basins and preservation of in-place areas of vegetation/habitat on the Santa Cruz River near Silverlake Road, managed by PCRFCFCD.
Arroyo Chico*	7.3		Construction of a series of detention basins in Arroyo Chico near Cherry Avenue including athletic fields and environmental restoration of habitat and revegetation within the basins. Managed by PCRFCFCD.
<b>Annual Total</b>	<b>225.0</b>		

\*Reclaimed water delivered through COT reclaimed

**IV. Reclaimed Water for Reuse, Environmental Restoration and Underground Storage (Groundwater Recharge) (Continued)**

**C. Underground Storage (Groundwater Recharge) of Effluent**

Pima County operates, or participates in operation of four facilities designed to replenish groundwater supply by recharging the aquifer. The source water for this recharge is wastewater effluent that has been treated to a high quality. Each recharge project operates under an Aquifer Protection Permit issued by ADEQ and an Underground Storage Facility Permit issued by ADWR. The tables below reflect the groundwater recharge credits earned and the most recent balance of Pima County’s Long-term Storage Account with ADWR.

<b>Recharge Volumes - Calendar Year 2016 in Acre Feet (AF)</b>						
<b>PROJECT</b>	<b>Delivery Volume</b>	<b>Evapo-transpiration</b>	<b>Contribution to Stream Diversions</b>	<b>Outflow</b>	<b>Cut to Aquifer</b>	<b>Recharge Credit</b>
<b>Lower Santa Cruz Managed Recharge Project (LSCMRP)</b>	<b>1,301.66</b>	<b>165.73</b>	<b>286.99</b>	<b>177.44</b>	<b>424.47</b>	<b>424.47</b>
<b>Marana High Plains Effluent Recharge Project (MHPERP)</b>	<b>627.20</b>	<b>3.90</b>				<b>600.00</b>
<b>Corona de Tucson</b>	<b>331.65</b>	<b>1.8</b>				<b>329.85</b>
<b>Avra Valley</b>	<b>1,460.58</b>	<b>25.5</b>				<b>1,435.08</b>
<b>Total</b>	<b>3,721.09</b>	<b>196.93</b>	<b>286.99</b>	<b>177.44</b>	<b>424.47</b>	<b>2,789.40</b>

<b>Long-term Storage Credit Summary</b>			
<b>Year</b>	<b>County Share of Metro Effluent (AF)</b>	<b>County Storage Credits (AF)</b>	<b>Cumulative Credits (AF)</b>
2003	3,999.80	58.10	58.10
2004	4,005.30	449.30	507.40
2005	4,080.70	535.10	1,042.50
2006	4,086.70	532.30	1,574.80
2007	4,009.90	788.38	2,363.18
2008	4,034.00	1,025.89	3,389.07
2009	3,821.10	977.41	4,366.48
2010	3,633.91	1,085.37	5,451.85
2011	3,571.66	990.06	6,441.91
2012	3,319.26	1,131.71	7,573.62
2013	3,237.25	962.69	8,536.31
2014	3,391.99	1,339.98	9,876.29
2015	3,315.63	1,910.89	11,787.18
2016	3,245.58	2,789.40	14,576.58

**IV. Reclaimed Water for Reuse, Environmental Restoration and Underground Storage (Groundwater Recharge) (Continued)**

**D. Summary of Use or Distribution of Pima County’s Metropolitan Effluent Allotment**

<b>Pima County Effluent Use Summary (10% Metropolitan Allotment)</b>					
Description			AFY	MG/Yr	MGD
<b>Reuse</b>	<b>Reclaimed System</b>	Natural Resources, Parks and Recreation	925.88	301.70	0.83
		Kino Sports Park & KERP	93.28	30.39	0.08
		Department of Transportation	0.18	0.06	0.00
		Regional Flood Control District	11.60	3.78	0.01
		Regional Wastewater Reclamation	0.00	0.00	0.00
		System Loss (4% in 2016)	41.24	13.44	0.04
		<b>Total from Reclaimed System</b>	<b>1,072.18</b>	<b>349.37</b>	<b>0.96</b>
	Reuse on Metropolitan WRF sites	67.10	21.86	0.06	
<b>Santa Cruz Releases</b>	Delivered to High Plains Constructed Recharge Project	627.20	204.37	0.56	
	Qualified as Delivery to Lower Santa Cruz River Managed Recharge Project (LSCMRP)	1,301.66	424.15	1.16	
	PC Share of Outflow from LSCMRP	177.44	57.82	0.16	
<b>Effluent Total</b>			<b>3,245.58</b>	<b>1,057.57</b>	<b>2.90</b>

## V. Effluent Entitlements

The 1979 IGA and subsequent agreements govern effluent entitlement from the metropolitan facilities. In 2016 the total metropolitan effluent produced was 60,655.8 AF. The effluent allocation formula designated the fixed amount of 28,200 AF for the Bureau of Reclamation to manage under Southern Arizona Water Rights Settlement Act (SAWRSA). Of the remaining portion, the City of Tucson and other water providers received 29,210.2 AF, while Pima County retained 3,245.6 AF.

Entitlement Calculations	Effluent Total (AF)
Total Effluent	60,655.8
SAWRSA	28,200.0
Total Less SAWRSA*	32,455.8
Water Providers Share	0.9
Pima County Share	0.1
<b>Entities Share 2016</b>	
- Water Providers (90%)	29,210.2
- Pima County (10%)	3,245.6

\*SAWRSA = Southern Arizona Water Rights Settlement Act.

Allocation and use of effluent in Pima County are governed by a series of agreements and legal constraints. The key agreements are listed and described below:

### A. 1979 Intergovernmental Agreement, Resolution No. 1979 - 78

The 1979 Intergovernmental Agreement, signed on June 26, 1979, was the original agreement between Pima County and the City of Tucson. This agreement assigned control of wastewater conveyance and treatment activities to PC RWRD. In exchange, the COT would receive 90% of all effluent produced at the RWRD metropolitan sites, which were limited to Ina Road WRF and Roger Road WRF at the time.

### B. Southern Arizona Water Rights Settlement Act (SAWRSA)

SAWRSA stands for the Southern Arizona Water Rights Settlement Act of 1982 (P.L. 97-293) and the subsequent Arizona Water Settlements Act (P.L. 108-451--12/10/2004). The U.S. Department of Interior Bureau of Reclamation receives, on behalf of the Tohono O'odham Nation, 28,200 acre-feet per year of secondary treated effluent from Tucson area wastewater treatment plants to assist in implementation of the settlement. Reclamation currently recharges this treated effluent in the Santa Cruz River and receives credit for 50% of the water recharged.

### C. City of Tucson-Pima County Supplemental Intergovernmental Agreement Relating to Effluent, Resolution No. 2000-28

The 2000 Supplemental Intergovernmental Agreement signed on February 8, 2000, placed restrictions on how PC could use effluent. This agreement also exempted Sub-Regional treatment facilities from the City control, identified the need for reopening the Randolph Park

## V. Effluent Entitlements (Continued)

### C. City of Tucson - Pima County Supplemental Intergovernmental Agreement Relating to Effluent, Resolution No. 2000-28 (Continued)

WRF, and provided an avenue for the County to deliver County effluent to County facilities. This supplemental agreement also established a Conservation Effluent Pool for use with riparian habitat projects and identified how the Southern Arizona Water Rights Settlement Act (SAWRSA) volumes are to be treated in determining effluent allocations.

### D. Conservation Effluent Pool Agreement

The Conservation Effluent Pool (CEP), which is a specific quantity of effluent that can be used for conservation projects, was identified in the 2000 Supplemental Intergovernmental Agreement. The CEP agreement was approved by the Board of Supervisors in December 2010 and was approved by the City of Tucson's Mayor and Council in January 2011. The CEP administrative procedures will establish the process for considering CEP requests, address how allocations and apportionments will be made, require an accounting of quantities used, address how CEP water will be delivered and scheduled, and require project status reporting. No CEP water has been used through the reporting year, 2016. However, Pima County has appointed a Conservation Effluent Pool Administrator and a CEP Taskforce has identified 13 prospective sites.

### E. Intergovernmental Agreement between the COT and PC for Treating Effluent and Wheeling Reclaimed Water (Wheeling Agreement), Resolution No. 2003-286 and Resolution No. 2017-17


The Wheeling Agreement, signed December 16, 2003, governs reclaimed water transactions between RWRD (the effluent provider), the City of Tucson (COT, the distributor and a reclaimed water user) and other County facilities (reclaimed water users). Effluent enters the reclaimed water system at the COT Sweetwater Plant and formerly through direct delivery from the Randolph Park WRF, where it is piped to various locations. The agreement governs the costs per acre-foot that will be charged to Pima County by COT for distribution of Pima County effluent to County sites. In 2016 and 2017, the COT and Pima County approved revision to the 2003 Wheeling Agreement which will facilitate adding new sites where reclaimed water can be delivered.

### F. Intergovernmental Agreement - Permitting and Operating Managed In-Channel Recharge of Effluent in the Santa Cruz River Channel (Managed Recharge IGA 2003)

The Managed Recharge IGA 2003 governs the recharge of effluent and the associated groundwater storage credits made available from recharging effluent into LSCMRP (Lower Santa Cruz Managed Recharge Project) between the Tres Rios (at that time, Ina Road) WRF and Trico Road in Marana. Participants include the Town of Marana, Cortaro-Marana Irrigation District, Avra Valley Irrigation District, Metropolitan Domestic Water Improvement District, Flowing Wells Irrigation District, Oro Valley, Spanish Trail Water Co, Pima County, and the City of Tucson.

**VI. Effluent Generation and Use in the Tucson Active Management Area (TAMA)**

ADWR and local water managers often examine the water budget from the perspective of the entire Tucson Active Management Area (TAMA). In order to show the overall picture of effluent production and use for this region, a table is included here that depicts the amount of effluent each entity controlled and how that effluent was utilized. Pima County’s wastewater production constitutes the primary source of effluent in the region, but there are a number of other entities that operate treatment facilities. This data is somewhat incomplete in that information is not available for all of the smaller wastewater treatment facilities. However, future reports may be able to capture additional data in this regard, and the majority of effluent generated in the TAMA is represented below.



**Figure 5:** 2016 Tucson AMA Effluent Use and Dispensation

In 2016, the total amount of effluent produced in the TAMA was 66,789.6 AF. Of this total, a volume of 17,258.2 AF or 26% was either directly reused or recharged with subsequent recovery for use during the year. Aquifer recharge activity resulted in net accrual of 24,847.6 AF in long-term storage credit, slightly more than what was stored in 2015. Only 8% of the effluent produced, or 5,453.8 AF, flowed out of the AMA according to measurement at the Trico Road gage on the Santa Cruz River.

**VI. Effluent Generation and Use in the Tucson Active Management Area (TAMA) (Continued)**

This volume of outflow was slightly more than in 2015, but considerably less than in previous years. Increased infiltration and dramatically reduced outflow are likely due to improved water quality from upgraded treatment plants and concurrent clearing of organic matter that was plugging sediment in the channel bottom. Additionally, in 2016 Tucson Water diverted more effluent to their Sweetwater recharge basins. Finally, in 2016 a total volume of 17,824.8 AF or 27% of the effluent was either “cut to the aquifer” from recharge accounting or simply discharged in a manner that it was not accounted for as either reuse or recharge credit.

VI. Effluent Generation and Use in the Tucson Active Management Area (TAMA) (Continued)

Tucson AMA  
Annual Effluent Utilization

Entities with Effluent	2016 Effluent Generation & Use in the Tucson AMA (values in acre-feet)												2016 Effluent Recharge Balance Activity				
	Net Effluent	Off Channel Recharge and Direct Reuse	Off Channel Recharge (Constructed USF or GSF)				In Channel Recharge						Off Channel Recharge (Constructed USF or GSF)		In Channel Recharge		
			Delivered to Off-Channel Recharge	Calculated Evaporation (ET loss)	Cut to the Aquifer	Annual Recovery	Delivered to In-Channel Recharge	Share of Down-stream Diversions <sup>2</sup>	Calculated Evaporation (ET loss)	Cut to the Aquifer	Outflow at Trico Rd Gage	Annual Recovery	Long-Term Credits Earned/ Reported	Long-term Credits Recovered	Long-Term Credits Earned/ Reported	Long-term Credits Recovered	
<b>PC Metropolitan WRFs</b>																	
Secretary of the Interior <sup>1</sup>	28,200.0						23,863.5			11,931.7	4,336.6						11,931.7
Conservation Effluent Pool																	
Pima County <sup>3</sup>	3,245.6	1,766.5	627.2	3.9			1,301.7	287.0	165.7	424.5	177.4		600.0				424.5
City of Tucson <sup>1,4</sup>	24,370.1	15,724.5	11,282.6	36.0		7,229.6	6,632.1	969.5	826.8	2,991.5	599.4		4,017.1				2,991.5
Marana	265.3						233.5	51.5	29.7	76.1	31.8	76.1					
Oro Valley	1,999.4	1,999.4															
Metro Water	2,044.9						1,799.6	396.8	229.1	586.8	245.3						586.8
Flowing Wells	485.3	3.2					424.3	93.5	54.0	138.4	57.8	138.4					
Spanish Trail	45.3						39.8	8.8	5.1	13.0	5.4						13.0
Subtotal	60,655.8	19,493.5	11,909.8	39.9		7,229.6	34,294.3	1,807.0	1,310.5	16,162.0	5,453.8	214.5	4,617.1				15,947.5
<b>PC Non-Metro WRFs</b>	2,311.1	1,806.4	1,792.2	27.3									1,764.9				
<b>Other Facilities</b>																	
Marana WRF	394.9																
Milagro	1.9	1.9															
Marana - Rillito Vista	4.4																
Marana High School	10.4																
Robson Ranch Quail Creek <sup>5</sup>	1,621.4	1,621.4	1,621.4	7.3									1,614.2				
Saddlebrooke/Saddlebrooke Ranch <sup>6</sup>	515.3	289.3	12.4	0.1									12.3				
Sahaurita <sup>6</sup>	1,144.0	911.8	911.8	20.2									891.6				
U of A Tech Park	130.4	130.4															
<b>Effluent Total</b>	<b>66,789.6</b>	<b>24,254.8</b>	<b>16,247.7</b>	<b>94.7</b>		<b>7,229.6</b>	<b>34,294.3</b>	<b>1,807.0</b>	<b>1,310.5</b>	<b>16,162.0</b>	<b>5,453.8</b>	<b>214.5</b>	<b>8,900.1</b>	<b>-</b>	<b>15,947.5</b>	<b>-</b>	

Data from Entities with Effluent Entitlements, ADWR, ADEQ, or Corporation Commission records.

<sup>1</sup> In-channel recharge data include credits from both SCRMUSF + LSCMRP.

<sup>2</sup> Diversion of effluent off-channel is for agricultural use, which also counts as reuse.

<sup>3</sup> Off channel recharge and direct reuse data for Pima County include direct reuse of 1,139.27 af plus 627.2 af directed to constructed recharge.

<sup>4</sup> Off channel recharge and direct reuse data for City of Tucson include direct reuse of 4,441.9 af plus 11,282.61 af directed to constructed recharge.

<sup>5</sup> Robson recharges effluent from Green Valley WRF. Delivery is the volume reported to ADWR for 2016, but ET and credits earned are estimated.

<sup>6</sup> Unconfirmed data.

Summary Table		
	AF	% of Total
Effluent Available	66,789.6	100
Direct Reuse & Annual Recovery	17,258.2	25.8
Net Added Long Term Credits	24,847.6	37.2
ET Losses from Recharge	1,405.2	2.1
Left Tucson AMA (@ Trico Rd)	5,453.8	8.2
Effluent Balance	17,824.8	26.7

## VII. Glossary of Terms & Acronyms

**Acre-foot (AF):** A measure of water volume. One acre-foot of water will cover one acre to a depth of one foot and equals 43,560 cubic feet or 325,851 gallons. An acre-foot of water meets the needs of three average Tucson families for one year.

**AFY:** Acre-feet per year.

**AMA or Active Management Area:** Areas with heavy reliance on mined groundwater were identified and designated as Active Management Areas (AMAs) by the 1980 Arizona Groundwater Management Act. There are five AMAs: Prescott, Phoenix, Pinal, Tucson, and Santa Cruz, where groundwater is subject to state regulation.

**Aquifer Protection Permit (APP):** ADEQ's permit program to protect groundwater quality from discharging facilities.

**Arizona Department of Environmental Quality (ADEQ):** State agency responsible for groundwater quality protection, water quality standards, and wastewater reclamation and reuse permits.

**Arizona Department of Water Resources (ADWR):** State agency responsible for water management and administration of water-related programs within the State.

**Arizona Pollutant Discharge Elimination System (AZPDES):** Arizona's permit program to protect surface water quality. ADEQ holds NPDES primacy from EPA.

**BADCT - Best Available Demonstrated Control Technology –** the technical design standard applied by ADEQ in their APP program.

**CCF:** A water billing unit that equals 100 cubic feet or 748 gallons – this is the typical measure of metering for water delivery volumes for residential and commercial customers.

**BNR - Biological Nutrient Removal.**

**BNRAS - Biological Nutrient Removal Activated Sludge.**

**BNROD - Biological Nutrient Removal Oxidation Ditch.**

**Class A Reclaimed Water:** Treated wastewater that has undergone secondary treatment, filtration and disinfection to a level that is essentially pathogen-free. The "A" designation established by ADEQ is suitable for outdoor irrigation with unrestricted access and certain industrial uses.

**Class A+ Reclaimed Water:** Means wastewater that has undergone secondary treatment with nutrient reduction so that total nitrogen is less than 10 mg/l, followed by filtration and disinfection to a level that is essentially pathogen-free. The "A+" designation by ADEQ is suitable for "A" category uses without the need for liners, volume restrictions, and certain reporting requirements.

**Class B Reclaimed Water:** Treated wastewater that has undergone secondary treatment, and disinfection to meet the Partial Body Contact criteria. The "B" designation by ADEQ is suitable for outdoor irrigation with restricted access, construction, dust control, and livestock watering.

**Class B+ Reclaimed Water:** Treated wastewater that has undergone secondary treatment with nutrient reduction so that total nitrogen is less than 10 mg/l, followed by disinfection to meet the Partial Body Contact criteria. The "B+" designation by ADEQ is suitable for "B" category uses without the need for liners, volume restrictions, and certain reporting requirements.

**Class C Reclaimed Water:** Treated wastewater that has undergone secondary treatment in a stabilization lagoon with aeration. This reclaimed water is suitable for livestock watering of non-dairy animals and irrigation of non-food crops.

**Conservation Effluent Pool (CEP):** Effluent set aside each year pursuant to an intergovernmental agreement between the City of Tucson and Pima County for use in riparian restoration projects.

**Constructed Recharge:** Replenishing the aquifer using a facility that is designed and constructed, in-channel, or off-channel, to store water underground pursuant to permits issued by ADWR.

**COT:** City of Tucson.

**Disinfection:** The treatment of water to inactivate, destroy, and/or remove disease-producing bacteria, viruses, and other microorganisms.

**Effluent:** Treated municipal wastewater.

## VIII. Glossary of Terms & Acronyms (Continued)

**Environmental Restoration:** (also referred to as Riparian Restoration, Riparian Enhancement, or Habitat Restoration) Environmental restoration means enhancing existing ecosystems or creating new habitat. The goal of restoration is recovery of some functional characteristics of the ecosystem including plant communities and habitat structure. In most instances replication of historical ecosystems isn't possible, but enhancing vegetation can result in sustainable habitat that helps restore ecosystem function and its support for wildlife and increased biodiversity. Enhancements may also include erosion control, improved water quality and achieving a self-sustaining, functional flow regime.

**ET:** Evapotranspiration, which accounts for water that is both evaporated and absorbed by plants and transpired into the atmosphere.

**GPD:** Gallons per day.

**Intergovernmental Agreement (IGA):** An agreement authorized by state statute between two or more governmental entities that provides for joint action or joint exercise of governmental powers.

**KERP:** Kino Environmental Restoration Project. The KERP basin is approximately 27 acres of watercourse and riparian habitat within the 120-acre Ajo Detention Basin. This project harvests stormwater and uses reclaimed water for both environmental restoration and irrigation of sports fields and landscape.

**LSCMRP:** Lower Santa Cruz River Managed Recharge Project.

**Managed Recharge:** A facility that uses the unmodified natural channel of a stream to artificially recharge and store water underground in an aquifer pursuant to permits issued by ADWR.

**Metropolitan (or Metro) Wastewater Reclamation Facility:** This term refers to any of the three metropolitan wastewater reclamation facilities operated by RWRD: Ina Rd, Roger Rd, and Randolph Park.

**MG:** Million gallons.

**MGD:** Million gallons per day – one means of measuring discharge or flow volume.

**MHPERP:** Marana High Plains Effluent Recharge Project.

**Milligrams per Liter (mg/l):** A unit of measure of dissolved or suspended concentration within a fluid that equates to parts per million.

**Oxidation Ditch:** The oxidation ditch is a component of the wastewater treatment process that provides long-term aeration. It consists of a long channel laid out in an elliptical or circular configuration. The channel is equipped with mechanical aeration equipment, such as brush rotors, disc aerators, draft tube aerators, or fine bubble diffusers. The design generates wastewater flow through the ditch, stirring water in the channel and supplying oxygen. A certain amount of settled solids (sludge) is added into the incoming wastewater in order to activate the bacterial treatment.

**PC:** Pima County.

**Recharge:** Water that replenishes an aquifer by surface infiltration or by other natural or induced means.

**Reclaimed Water:** Means water that has been treated or processed by a wastewater treatment plant (A.R.S. §49-201.31).

**Regional Wastewater Reclamation Facility:** This term refers to any of the three metropolitan wastewater reclamation facilities operated by RWRD: Ina Rd, Roger Rd, and Randolph Park.

**RFCD (or PCRFCFCD):** Pima County Regional Flood Control District.

**RWRD (or PCRWRD):** Pima County Regional Wastewater Reclamation Department.

**Riparian:** Pertaining to or situated on the bank of a body of water, especially a river.

**Soil-Aquifer Treatment:** Use of the physical, chemical, and/or microbiological properties of the soil and the aquifer to provide treatment of water introduced into the groundwater system.

**Southern Arizona Water Rights Settlement Act (SAWRSA):** 1982 federal legislation to settle water-rights claims of the Tohono O'odham Nation against City of Tucson and several other parties.

**Stabilization Lagoons:** This type of treatment facility consists of shallow man-made basins comprising a single or several series of anaerobic, facultative or maturation ponds that are operated without aeration. Such ponds allow suspended solids to settle and the soluble element of organic matter (BOD) is reduced through the coordinated activity of algae and heterotrophic bacteria.

## VIII. Glossary of Terms & Acronyms (Continued)

**Sub-regional:** A term used to describe the non-metropolitan wastewater reclamation facilities in Pima County. This group includes Arivaca Junction, Avra Valley, Corona de Tucson, Green Valley, Marana, Mount Lemmon, Pima County Fairgrounds, and Rillito Vista.

**Surface Water:** Water on the Earth's surface, such as in a stream, river, lake, or reservoir.

**Underground Storage:** Recharge of the groundwater in a manner that anticipates eventual recovery from the aquifer. In Arizona this usually involves establishing an account with ADWR for tracking short- or long-term storage credits.

**USBR:** United States Bureau of Reclamation.

**UV:** Ultra-Violet, which is a band of wavelengths of light that is useful in disinfecting wastewater.

**Water Harvesting:** The process of intercepting stormwater from a surface, such as a roof, parking area, or land surface, and putting it to beneficial use.

**Wheeled Water or Water Wheeling:** Water transferred between two agencies whereby one agency uses its system infrastructure to treat and/or convey water that is owned by the receiving agency.

**WRF:** Wastewater Reclamation Facility.