

# Pima County Department of Environmental Quality - Manhole Vacuum Test Documentation Sheet

Project Description: \_\_\_\_\_

Observed By: \_\_\_\_\_

PDEQ Project Number: \_\_\_\_\_

Inspection Date: \_\_\_\_\_

Manhole Number	Manhole Manufacturer	Manhole Diameter (inch)	Manhole Height (ft)	Spec Test Time* (min:sec)	Test Time Data: Pres. drop = 10 inHg to 9 inHg		Pass/Fail	Date		Manhole Clean		Steps	
					(Min.)	(Sec.)		Test	Re-Test	Yes	No	Yes	No

\* Calculated from ASTM C 1244-02, The Standard Test Method for Concrete Sewer Manholes by the Negative Air Pressure (Vacuum) Test, Table 1 as referenced in Arizona Administrative Code R18-9-E301.D.3.e.ii.