

ATTACHMENT 2

**AUTHORIZATION TO OPERATE (ATO)
UNDER PDEQ CLASS II GENERAL AIR QUALITY PERMIT #6096
For
NESHAP GASOLINE DISPENSING FACILITIES**



CI. FACILITY INFORMATION:

Business Name: Costco Wholesale Corporation
 Facility Name: Costco Gasoline - Loc. No. 407
 Source Location: 6255 E. Grant Road, Tucson AZ, 85712

II. AUTHORIZED EQUIPMENT: Gasoline Storage Tanks & Phase I Vapor Balance/Control Equipment

ATO #	TANK				SUBMERGED FILL DEVICE		VAPOR BALANCE SYSTEM	
	ID	VOLUME (Gallons)	MANUFACTURE DATE	INSTALLATION DATE	INSTALLATION DATE	TANK BOTTOM CLEARANCE	TYPE	INSTALLATION DATE
2213	01	30,000	≤1/10/08	≤11/9/06	>11/9/06	≤6"	Dual Point	≤12/15/09
2213	02	15,000	≤1/10/08	≤11/9/06	>11/9/06	≤6"	Dual Point	≤12/15/09
2213	03	15,000	≤1/10/08	≤11/9/06	>11/9/06	≤6"	Dual Point	≤12/15/09
2213	04	15,000	≤1/10/08	≤11/9/06	>11/9/06	≤6"	Dual Point	≤12/15/09

III. THROUGHPUT LIMITATION (Facility-wide)

Maximum Yearly Throughput (gallons*): 28,000,000

*Gallons, as used in this document, shall mean net gallons defined as the volume of gasoline corrected to a reference temperature of 60 degrees Fahrenheit. **Note:** As presented in the revision application dated May 10, 2019, the Control Officer has accepted revised emission factors to account for increased vehicle onboard refueling vapor recovery system controls and usage as published in 76 FR41723 and related EPA documentation. For the above authorized facility, the throughput limitation in Condition II.A.2 of G.P. #6096 has been severed by the Control Officer pursuant to PCC 17.13.020.A.6.

ATO # 2213	
ATO Issue Date:	February 5, 2018
ATO Revision Date:	June 8, 2019
ATO Expiration Date:	October 17, 2020

Rupesh Patel, Air Permit Manager, PDEQ