

AUTHORIZATION TO OPERATE (ATO)

**UNDER PDEQ CLASS II/III GENERAL AIR QUALITY PERMIT 6205
For
FUEL BURNING EQUIPMENT (BOILERS, HEATERS, & GENERATORS)**



I. FACILITY INFORMATION:

Business Name: City of Tucson - Environmental & General Services Department
 Facility Name: Westside Police Service Center
 Source Location: 1310 W Miracle Mile, Tucson, AZ 85705

Permitted Emissions Limits:

Conventional or Criteria Air Pollutant (tons/year)								HAP(s) (tons/year)
PM _{2.5}	PM ₁₀	PM	NO _x	VOC	CO	SO ₂	Lead	Total
< 90	< 90	< 90	< 90	< 90	< 90	< 90	< 0.6	< 10

II. AUTHORIZED EQUIPMENT:

Equipment, operations, and activities for which emissions are allowed by the general permit are as follows:

Section 4C – NSPS for CI ICE (Emergency Designated Engines):

Equip. No.	Description/ Location	MFR/ Model	Serial Number/ Unique ID	Maximum Rated Capacity	Date of MFR	Date Installed	Run Hour Limitation ¹	Allowable Fuels
6123-001	Generator	Caterpillar/C15	FSE03261	762 hp	5/1/2010	-	100	Diesel
6123-002	Generator	John Deere/-	6068HF150	251 hp	9/1/2006	-	100	Diesel

¹ The run hours are limited to maintenance testing and readiness checks and non-emergency operation in accordance with the federal requirements. There is no limit on hours of operation during true emergencies.

Section 4C – Supplemental Requirements:

Equip. No.	Applicable NSPS Emission Standard	NO _x g/hp-hr	NMHC g/hp-hr	NMHC+NO _x g/hp-hr	CO g/hp-hr	PM g/hp-hr	Certified Emission Life (term, date)
6123-001	Model Year 2007 and Later Emergency	-	-			0.15	8,000 hours or 10 years, whichever comes first.
6123-002	Model Year 2007 and Later Emergency	-	-			0.15	8,000 hours or 10 years, whichever comes first.

IV. OTHER APPLICABLE ATTACHMENTS: Attachment 1 to the ATO – Fugitive Dust Requirements

Rupesh Patel, Air Permit Manager, PDEQ

ATO #6123	
Issued Date:	January 12, 2018
Effective Date:	January 19, 2018
Expiration Date:	January 4, 2022