

**AUTHORIZATION TO OPERATE (ATO)**

**UNDER PDEQ CLASS II/III GENERAL AIR QUALITY PERMIT 6205  
For  
FUEL BURNING EQUIPMENT (BOILERS, HEATERS, & GENERATORS)**



**I. FACILITY INFORMATION:**

Business Name: Sahuarita Water Company, LLC  
 Facility Name: Booster Station 2  
 Source Location: 424 W Calle Sedillo, Sahuarita, AZ 85629

**Permitted Emissions Limits:**

Conventional or Criteria Air Pollutant (tons/year)								HAP(s) (tons/year)
PM <sub>2.5</sub>	PM <sub>10</sub>	PM	NO <sub>x</sub>	VOC	CO	SO <sub>2</sub>	Lead	Total
< 90	< 90	< 90	< 90	< 90	< 90	< 90	< 0.6	< 10

**II. AUTHORIZED EQUIPMENT:**

Equipment, operations, and activities for which emissions are allowed by the general permit are as follows:

**Section 4C – NSPS for CI ICE (Emergency Designated Engines):**

Equip. No.	Description/ Location	MFR/ Model	Serial Number/ Unique ID	Maximum Rated Capacity	Date of MFR	Date Installed	Run Hour Limitation <sup>1</sup>	Allowable Fuels
6218-001	Generator	Cummins/DSHAD 7091274	E080181832	364 hp	3/19/2008	-	100	Diesel

<sup>1</sup> The run hours are limited to maintenance testing and readiness checks and non-emergency operation in accordance with the federal requirements. There is no limit on hours of operation during true emergencies.

**Section 4C – Supplemental Requirements:**

Equip. No.	Applicable NSPS Emission Standard	NO <sub>x</sub> g/hp-hr	NMHC g/hp-hr	NMHC+NO <sub>x</sub> g/hp-hr	CO g/hp-hr	PM g/hp-hr	Certified Emission Life (term, date)
6218-001	Model Year 2007 and Later Emergency	-	-	3.0	2.6	0.15	8,000 hours or 10 years, whichever comes first.

Rupesh Patel, Air Permit Manager, PDEQ

ATO #6218	
Issued Date:	October 6, 2017
Effective Date:	October 13, 2017
Expiration Date:	January 4, 2022