

AUTHORIZATION TO OPERATE (ATO)
UNDER PDEQ CLASS II/III GENERAL AIR QUALITY PERMIT 6205
For
FUEL BURNING EQUIPMENT (BOILERS, HEATERS, & GENERATORS)



I. FACILITY INFORMATION:

Business Name: Convergys Customer Management Group
 Facility Name: Convergys Customer Management Group
 Source Location: 3760 N Commerce Dr, Tucson, AZ 85705

Permitted Emissions Limits:

Conventional or Criteria Air Pollutant (tons/year)								HAP(s) (tons/year)
PM _{2.5}	PM ₁₀	PM	NO _x	VOC	CO	SO ₂	Lead	Total
< 90	< 90	< 90	< 90	< 90	< 90	< 90	< 0.6	< 10

II. AUTHORIZED EQUIPMENT:

Equipment, operations, and activities for which emissions are allowed by the general permit are as follows:

Section 4A of the Permit – Non-NSPS/Non-NESHAP ICE (Emergency Designated Engines):

Equip. No.	Description/ Location	MFR/ Model	Serial Number/ Unique ID	Maximum Rated Capacity	Date of MFR	Date Installed	Limitation ¹	Allowable Fuels
785-001	Generator	Caterpillar/3412	81Z22325	749 hp	3/2/1998	-	100 hours	Diesel

¹ The run hours are limited to maintenance testing and readiness checks. There is no limit on hours of operation during true emergencies. Permittee may also demonstrate compliance with the operational limitation by limiting the amount of fuel fired in the unit.

Rupesh Patel, Air Permit Manager, PDEQ

ATO #785	
Issued Date:	December 19, 2016
Effective Date:	January 5, 2017
Expiration Date:	January 4, 2022

AUTHORIZATION TO OPERATE (ATO)

**UNDER PDEQ CLASS II/III GENERAL AIR QUALITY PERMIT 6205
For
FUEL BURNING EQUIPMENT (BOILERS, HEATERS, & GENERATORS)**



Section 4C – NSPS for CI ICE (Emergency Designated Engines):

Equip. No.	Description/ Location	MFR/ Model	Serial Number/ Unique ID	Maximum Rated Capacity	Date of MFR	Date Installed	Run Hour Limitation ¹	Allowable Fuels
785-002	Generator	Cummins/DQDAA1325051	D130490581	402.3 hp	8/13/2013	-	100	Diesel

¹. The run hours are limited to maintenance testing and readiness checks and non-emergency operation in accordance with the federal requirements. There is no limit on hours of operation during true emergencies.

Section 4C – Supplemental Requirements:

Equip. No.	Applicable NSPS Emission Standard	NO _x g/hp-hr	NMHC g/hp-hr	NMHC+NO _x g/hp-hr	CO g/hp-hr	PM g/hp-hr	Certified Emission Life (term, date)
785-002	Model Year 2007 and Later Emergency	-	-	4.8	2.6	0.15	8,000 hours or 10 years, whichever comes first.

Rupesh Patel, Air Permit Manager, PDEQ

ATO #785	
Issued Date:	December 19, 2016
Effective Date:	January 5, 2017
Expiration Date:	January 4, 2022