

AUTHORIZATION TO OPERATE (ATO)

**UNDER PDEQ CLASS II/III GENERAL AIR QUALITY PERMIT 6205
For
FUEL BURNING EQUIPMENT (BOILERS, HEATERS, & GENERATORS)**



I. FACILITY INFORMATION:

Business Name: Pacific Service Company
 Facility Name: 5451 E. Williams Blvd.
 Source Location: 5451 E. Williams Blvd, Tucson, AZ 85711

Permitted Emissions Limits, tons/year:

Conventional or Criteria Air Pollutant								HAP(s)
PM _{2.5}	PM ₁₀	PM	NO _x	VOC	CO	SO ₂	Lead	Total
< 90	< 90	< 90	< 90	< 90	< 90	< 90	< 0.6	< 10

II. AUTHORIZED EQUIPMENT:

Equipment, operations, and activities for which emissions are allowed by the general permit are as follows:

Section 4A of the Permit – Non-NSPS/Non-NESHAP ICE (Emergency Designated Engines):

Equip. No.	Description/ Location	MFR/ Model	Serial Number/ Unique ID	Maximum Rated Capacity	Date of MFR	Date Installed	Limitation ¹	Allowable Fuels
1352-001	Generator	Caterpillar/ 3412	3FZ02328	671	1/1/1999	-	100 hours or 3428 Gallons	Diesel

¹ The run hours are limited to maintenance testing and readiness checks. There is no limit on hours of operation during true emergencies. Permittee may also demonstrate compliance with the operational limitation by limiting the amount of fuel fired in the unit.

Rupesh Patel, Air Program Manager, PDEQ

ATO # 1352	
Issue Date:	March 16, 2018
Effective Date:	March 17, 2018
Expiration Date:	January 4, 2022