

**AUTHORIZATION TO OPERATE (ATO)**  
**UNDER PDEQ CLASS II/III GENERAL AIR QUALITY PERMIT**  
**For**  
**FUEL BURNING EQUIPMENT (BOILERS, HEATERS, & GENERATORS)**



**I. FACILITY INFORMATION:**

Business Name: Allegretti & Company  
 Facility Name: 5451 E Williams Blvd.  
 Source Location: 5451 E Williams Blvd, Tucson, AZ 85711

**II. AUTHORIZED EQUIPMENT:**

Equipment, operations, and activities for which emissions are allowed by the general permit are as follows:

**§ 6A of the Permit – Non-NSPS/Non-NESHAP ICE (*Emergency Designated Engines*):**

Equip. No.	Description/ Location	MFR/ Model	Serial Number/ Unique ID	Maximum Rated Capacity	Date of MFR	Date Installed	Limitation <sup>1</sup>	Allowable Fuels
1352-001	Generator	Caterpillar	3FZ02328	671 hp	1/1/1999	-	100 hours	Diesel

<sup>1</sup> The run hours are limited to maintenance testing and readiness checks. There is no limit on hours of operation during true emergencies. Permittee may also demonstrate compliance with the operational limitation by limiting the amount of fuel fired in the unit.

Rupesh Patel, Air Program Manager, PDEQ

<b>Permit Number: #1352</b>	
Issued Date:	March 31, 2022
Effective Date:	March 31, 2022
Expiration Date:	March 30, 2027