

AUTHORIZATION TO OPERATE (ATO)

**UNDER PDEQ CLASS II/III GENERAL AIR QUALITY PERMIT 6205
For
FUEL BURNING EQUIPMENT (BOILERS, HEATERS, & GENERATORS)**



I. FACILITY INFORMATION:

Business Name: KCI 250 Investors, LLC
 Facility Name: KCI 250 Investors, LLC
 Source Location: 250 S Williams Cr, Tucson, AZ 85711

Permitted Emissions Limits:

Conventional or Criteria Air Pollutant (tons/year)								HAP(s) (tons/year)
PM _{2.5}	PM ₁₀	PM	NO _x	VOC	CO	SO ₂	Lead	Total
< 90	< 90	< 90	< 90	< 90	< 90	< 90	< 0.6	< 10

II. AUTHORIZED EQUIPMENT:

Equipment, operations, and activities for which emissions are allowed by the general permit are as follows:

Section 4A of the Permit – Non-NSPS/Non-NESHAP ICE (Emergency Designated Engines):

Equip. No.	Description/ Location	MFR/ Model	Serial Number/ Unique ID	Maximum Rated Capacity	Date of MFR	Date Installed	Limitation ¹	Allowable Fuels
3226-001	Generator	Generac/SD350	2087431	528 hp	2/1/2006	-	100 hours	Diesel

¹ The run hours are limited to maintenance testing and readiness checks. There is no limit on hours of operation during true emergencies. Permittee may also demonstrate compliance with the operational limitation by limiting the amount of fuel fired in the unit.

Rupesh Patel, Air Permit Manager, PDEQ

ATO #3226	
Issued Date:	June 10, 2019
Effective Date:	June 10, 2019
Expiration Date:	January 4, 2022