

AUTHORIZATION TO OPERATE (ATO)
UNDER PDEQ CLASS II/III GENERAL AIR QUALITY PERMIT 6205
For
FUEL BURNING EQUIPMENT (BOILERS, HEATERS, & GENERATORS)



I. FACILITY INFORMATION:

Business Name: Five Star Tucson Forum LLC DBA Forum at Tucson
 Facility Name: Forum at Tucson
 Source Location: 2500 N Rosemont Blvd, Tucson, AZ 85712

Permitted Emissions Limits:

| Conventional or Criteria Air Pollutant (tons/year) | | | | | | | | HAP(s) (tons/year) |
|--|------------------|------|-----------------|------|------|-----------------|-------|--------------------|
| PM _{2.5} | PM ₁₀ | PM | NO _x | VOC | CO | SO ₂ | Lead | Total |
| < 90 | < 90 | < 90 | < 90 | < 90 | < 90 | < 90 | < 0.6 | < 10 |

II. AUTHORIZED EQUIPMENT:

Equipment, operations, and activities for which emissions are allowed by the general permit are as follows:

Section 4A of the Permit – Non-NSPS/Non-NESHAP ICE (Emergency Designated Engines):

| Equip. No. | Description/ Location | MFR/ Model | Serial Number/ Unique ID | Maximum Rated Capacity | Date of MFR | Date Installed | Limitation ¹ | Allowable Fuels |
|------------|--------------------------|----------------|-----------------------------|---------------------------|----------------|-------------------|-------------------------|-----------------|
| 3435-001 | Generator | Kohler250R0Z71 | 237784 | 336 hp | 4/1/2007 | - | 100 hours | Natural Gas |

¹ The run hours are limited to maintenance testing and readiness checks. There is no limit on hours of operation during true emergencies. Permittee may also demonstrate compliance with the operational limitation by limiting the amount of fuel fired in the unit.

Rupesh Patel, Air Permit Manager, PDEQ

| ATO #3435 | |
|------------------|-------------------|
| Issued Date: | December 19, 2016 |
| Effective Date: | January 5, 2017 |
| Expiration Date: | January 4, 2022 |