

**AUTHORIZATION TO OPERATE (ATO)**  
**UNDER PDEQ CLASS II/III GENERAL AIR QUALITY PERMIT 6205**  
**For**  
**FUEL BURNING EQUIPMENT (BOILERS, HEATERS, & GENERATORS)**



**I. FACILITY INFORMATION:**

Business Name: Alorica, Inc.  
 Facility Name: Alorica, Inc.  
 Source Location: 1650 S Research Loop, Tucson, AZ 85710

**Permitted Emissions Limits:**

Conventional or Criteria Air Pollutant (tons/year)								HAP(s) (tons/year)
PM <sub>2.5</sub>	PM <sub>10</sub>	PM	NO <sub>x</sub>	VOC	CO	SO <sub>2</sub>	Lead	Total
< 90	< 90	< 90	< 90	< 90	< 90	< 90	< 0.6	< 10

**II. AUTHORIZED EQUIPMENT:**

Equipment, operations, and activities for which emissions are allowed by the general permit are as follows:

**Section 4A of the Permit – Non-NSPS/Non-NESHAP ICE (Emergency Designated Engines):**

Equip. No.	Description/ Location	MFR/ Model	Serial Number/ Unique ID	Maximum Rated Capacity	Date of MFR	Date Installed	Limitation <sup>1</sup>	Allowable Fuels
602-001	Generator	Caterpillar/3412	3FZ02580	670.5 hp	1/1/2001	-	100 hours	Diesel

<sup>1</sup> The run hours are limited to maintenance testing and readiness checks. There is no limit on hours of operation during true emergencies. Permittee may also demonstrate compliance with the operational limitation by limiting the amount of fuel fired in the unit.

Rupesh Patel, Air Program Manager, PDEQ

ATO #602	
Issued Date:	March 31, 2020
Effective Date:	March 31, 2020
Expiration Date:	January 4, 2022