



MEMORANDUM

Pima County Department of Environmental Quality

DATE: 8/15/2011

TO: Alex Gallego
Assistant Superintendent Operations & Facilities Planning

FROM: Beth Gorman
Program Manager

RE: Pima County DEQ Beryllium Monitoring Report 2nd Quarter 2011

Attached is the Pima County Department of Environmental Quality's (PDEQ) Air Monitoring Division Beryllium Monitoring Network Summary for the 2nd Quarter of 2011.

Highlights:

- 106 samples collected resulting in 101 valid and 5 invalid samples (95.3% data recovery). EPA requires monitoring data recovery at 75%.
- No beryllium values were detected over the Practical Quantitation Limit (PQL).
- The PQL was updated from 0.265 to 0.225 to reflect the lowest standard used in the analysis.
- PDEQ and SUSD staff are continuing to employ stringent monitoring protocols to ensure quality data is being collected properly to better protect public health.

For additional information on this report, please contact me at Pima County Department of Environmental Quality at (520) 740-3340.

Attachment

Cc: Ursula Kramer, Pima County Department of Environmental Quality Director
Richard Grimaldi, Pima County Department of Environmental Deputy Director



Pima County

Department of Environmental Quality

Air Monitoring Division

Beryllium Monitoring Network Summary

2nd Quarter 2011



*Pima County Department of Environmental Quality
33 N. Stone Avenue, Suite 700
Tucson, Arizona 85701*

Summary

The Pima County Department of Environmental Quality has contracted with the Pima County Regional Wastewater Reclamation Department (RWRD) to perform analysis on filters sampled in the Beryllium Monitoring Network located in the Sunnyside Unified School District.

For the 2nd quarter of 2011 there was a total of 106 PM₁₀ samples collected resulting in 101 valid and 5 invalid samples; for a data recovery of 95.39 %. Twelve samples were collected to be used as precision checks as recommended in *40 CFR, Part 58, Appendix A, Section 5.3.1*. All samples run for a 24-hour period as specified in *40 CFR, Part 50, Appendix B*.

There were a total of 101 samples analyzed for beryllium. Beryllium concentrations are reported as <0.225 ng/m³ PQL (Practical Quantitation Level. In the preamble to a November 13, 1985 rulemaking (50 FR 46906), the PQL was defined as “the lowest concentration of an analyte that can be reliably measured within specific limits of precision and accuracy during routine laboratory operating conditions.” The Agency has used the PQL to estimate or evaluate the minimum concentration at which most laboratories can be expected to reliably measure a specific chemical contaminant during day-to-day analysis.

The following pages display the sampling dates, sampling locations, PM₁₀ concentrations (µg/m³) calculated in standard conditions, PM₁₀ 24-hour NAAQS standard, precision measurements, Beryllium analysis results, accompanying graphs and a brief explanation of all invalid samples for the 2nd quarter of 2011.

PM₁₀ /Beryllium Concentrations

Monthly Summary of PM₁₀/Beryllium Data

April 2011

| Date | Location | Standard Concentration PM ₁₀ (µg/m ³) | 24-hour NAAQS PM ₁₀ (µg/m ³) | Beryllium (ng/m ³) |
|----------|----------------------|--|---|--------------------------------|
| 04/01/11 | Transportation Bldg | 21.3 | 150 | <0.225 |
| 04/02/11 | Sunnyside H.S. | 29.8 | 150 | <0.225 |
| 04/03/11 | Ocotillo #1 | 15.0 | 150 | <0.225 |
| 04/03/11 | Ocotillo #2 | 15.9 | 150 | <0.225 |
| 04/04/11 | Los Amigos | 22.3 | 150 | <0.225 |
| 04/05/11 | Los Niños | 28.1 | 150 | <0.225 |
| 04/06/11 | Chaparral M.S. | 52.1 | 150 | <0.225 |
| 04/07/11 | Transportation Bldg | 58.2 | 150 | <0.225 |
| 04/08/11 | Sunnyside H.S. | 42.0 | 150 | <0.225 |
| 04/09/11 | Ocotillo #1 | 4.0 | 150 | <0.225 |
| 04/09/11 | Ocotillo #2 | 5.1 | 150 | <0.225 |
| 04/10/11 | Los Amigos | 4.7 | 150 | <0.225 |
| 04/11/11 | Los Niños | 9.9 | 150 | <0.225 |
| 04/12/11 | Chaparral M.S. | 14.2 | 150 | <0.225 |
| 04/13/11 | Transportation Bldg | 16.2 | 150 | <0.225 |
| 04/14/11 | Sunnyside H.S. | 50.1 | 150 | <0.225 |
| 04/15/11 | Ocotillo #1 | 44.5 | 150 | <0.225 |
| 04/15/11 | Ocotillo #2 | 46.5 | 150 | <0.225 |
| 04/16/11 | Los Amigos | 28.7 | 150 | <0.225 |
| 04/17/11 | Los Niños | 21.3 | 150 | <0.225 |
| 04/18/11 | Chaparral M.S. | 37.6 | 150 | <0.225 |
| 04/19/11 | Transportation Bldg | 19.3 | 150 | <0.225 |
| 04/20/11 | Sunnyside H.S. | 21.5 | 150 | <0.225 |
| 04/21/11 | Ocotillo #1 | 18.4 | 150 | <0.225 |
| 04/21/11 | Ocotillo #2 | 17.7 | 150 | <0.225 |
| 04/22/11 | Los Amigos | 13.4 | 150 | <0.225 |
| 04/23/11 | Los Niños | 22.7 | 150 | <0.225 |
| 04/24/11 | Chaparral M.S. | 20.5 | 150 | <0.225 |
| 04/25/11 | Transportation Bldg. | 20.5 | 150 | <0.225 |
| 04/26/11 | Sunnyside H.S. | 38.3 | 150 | <0.225 |
| 04/27/11 | Ocotillo #1 | 21.0 | 150 | <0.225 |
| 04/27/11 | Ocotillo #2 | 25.1 | 150 | <0.225 |
| 04/28/11 | Los Amigos | 26.5 | 150 | <0.225 |
| 04/29/11 | Los Niños | 42.7 | 150 | <0.225 |
| 04/30/11 | Chaparral M.S. | 31.4 | 150 | <0.225 |

NAAQS = National Ambient Air Quality Standard for PM₁₀

PM₁₀ /Beryllium Concentrations (continued)

Monthly Summary of PM₁₀/Beryllium Data

May 2011

| Date | Location | Standard Concentration PM₁₀ (µg/m³) | 24-hour NAAQS PM₁₀ (µg/m³) | Beryllium (ng/m³) |
|-------------|---------------------|--|---|-------------------------------------|
| 05/01/11 | Transportation Bldg | 12.3 | 150 | <0.225 |
| 05/02/11 | Sunnyside H.S. | 24.0 | 150 | <0.225 |
| 05/03/11 | Ocotillo #1 | 28.7 | 150 | <0.225 |
| 05/03/11 | Ocotillo #2 | 32.9 | 150 | <0.225 |
| 05/04/11 | Los Amigos | 31.6 | 150 | <0.225 |
| 05/05/11 | Los Ninos | 43.0 | 150 | <0.225 |
| 05/06/11 | Chaparral M.S. | 33.4 | 150 | <0.225 |
| 05/07/11 | Transportation Bldg | 23.5 | 150 | <0.225 |
| 05/08/11 | Sunnyside H.S. | 34.6 | 150 | <0.225 |
| 05/09/11 | Ocotillo #1 | 34.5 | 150 | <0.225 |
| 05/09/11 | Ocotillo #2 | 33.1 | 150 | <0.225 |
| 05/10/11 | Los Amigos | 37.8 | 150 | <0.225 |
| 05/11/11 | Los Ninos | INVALID | 150 | INVALID |
| 05/12/11 | Chaparral M.S. | 31.9 | 150 | <0.225 |
| 05/13/11 | Transportation Bldg | 24.0 | 150 | <0.225 |
| 05/14/11 | Sunnyside H.S. | 28.0 | 150 | <0.225 |
| 05/15/11 | Ocotillo #1 | 29.2 | 150 | <0.225 |
| 05/15/11 | Ocotillo #2 | 19.5 | 150 | <0.225 |
| 05/16/11 | Los Amigos | 39.0 | 150 | <0.225 |
| 05/17/11 | Los Niños | INVALID | 150 | <0.225 |
| 05/18/11 | Chaparral M.S. | 36.5 | 150 | <0.225 |
| 05/19/11 | Transportation Bldg | 20.6 | 150 | <0.225 |
| 05/20/11 | Sunnyside H.S. | 32.4 | 150 | <0.225 |
| 05/21/11 | Ocotillo #1 | 28.5 | 150 | <0.225 |
| 05/21/11 | Ocotillo #2 | 20.6 | 150 | <0.225 |
| 05/22/11 | Los Amigos | 31.0 | 150 | <0.225 |
| 05/23/11 | Los Niños | 48.4 | 150 | <0.225 |
| 05/24/11 | Chaparral M.S. | 28.4 | 150 | <0.225 |
| 05/25/11 | Transportation Bldg | 27.1 | 150 | <0.225 |
| 05/26/11 | Sunnyside H.S. | 33.3 | 150 | <0.225 |
| 05/27/11 | Ocotillo #1 | 25.6 | 150 | <0.225 |
| 05/27/11 | Ocotillo #2 | 24.4 | 150 | <0.225 |
| 05/28/11 | Los Amigos | 27.1 | 150 | <0.225 |
| 05/29/11 | Los Niños | 87.8 | 150 | <0.225 |
| 05/30/11 | Chaparral M.S. | 47.2 | 150 | <0.225 |
| 05/31/11 | Transportation Bldg | 30.8 | 150 | <0.225 |

Sample running on 05/11/11 invalid do to equipment malfunction.

Sample running on 05/17/11 invalid for PM10 due to run time being less than 1380 minutes.

NAAQS = National Ambient Air Quality Standard for PM₁₀

PM₁₀ /Beryllium Concentrations (continued)

Monthly Summary of PM₁₀/Beryllium Data

| June 2011 | | | | |
|------------------|---------------------|--|---|-------------------------------------|
| Date | Location | Standard Concentration PM₁₀ (µg/m³) | 24-hour NAAQS PM₁₀ (µg/m³) | Beryllium (ng/m³) |
| 06/01/11 | Sunnyside H.S. | 43.3 | 150 | <0.225 |
| 06/02/11 | Ocotillo #1 | 30.9 | 150 | <0.265 |
| 06/02/11 | Ocotillo #2 | 32.7 | 150 | <0.265 |
| 06/03/11 | Los Amigos | 45.2 | 150 | <0.265 |
| 06/04/11 | Los Niños | 32.8 | 150 | <0.265 |
| 06/05/11 | Chaparral M.S. | 29.5 | 150 | <0.265 |
| 06/06/11 | Transportation Bldg | 28.0 | 150 | <0.265 |
| 06/07/11 | Sunnyside H.S. | 36.6 | 150 | <0.265 |
| 06/08/11 | Ocotillo #1 | 27.5 | 150 | <0.265 |
| 06/08/11 | Ocotillo #2 | 28.1 | 150 | <0.265 |
| 06/09/11 | Los Amigos | 25.1 | 150 | <0.265 |
| 06/10/11 | Los Niños | 25.4 | 150 | <0.265 |
| 06/11/11 | Chaparral M.S. | 33.6 | 150 | <0.265 |
| 06/12/11 | Transportation Bldg | 31.0 | 150 | <0.265 |
| 06/13/11 | Sunnyside H.S. | 36.8 | 150 | <0.265 |
| 06/14/11 | Ocotillo #1 | INVALID | 150 | INVALID |
| 06/14/11 | Ocotillo #2 | INVALID | 150 | INVALID |
| 06/15/11 | Los Amigos | 26.4 | 150 | <0.265 |
| 06/16/11 | Los Niños | 29.4 | 150 | <0.265 |
| 06/17/11 | Chaparral M.S. | 46.6 | 150 | <0.265 |
| 06/18/11 | Transportation Bldg | 32.8 | 150 | <0.265 |
| 06/19/11 | Sunnyside H.S. | 94.1 | 150 | <0.265 |
| 06/20/11 | Ocotillo #1 | INVALID | 150 | INVALID |
| 06/20/11 | Ocotillo #2 | INVALID | 150 | INVALID |
| 06/21/11 | Los Amigos | 25.5 | 150 | <0.265 |
| 06/22/11 | Los Ninos | 34.7 | 150 | <0.265 |
| 06/23/11 | Chaparral M.S. | 37.8 | 150 | <0.265 |
| 06/24/11 | Transportation Bldg | 34.3 | 150 | <0.265 |
| 06/25/11 | Sunnyside H.S. | 31.7 | 150 | <0.265 |
| 06/26/11 | Ocotillo #1 | 28.8 | 150 | <0.225 |
| 06/26/11 | Ocotillo #2 | 29.8 | 150 | <0.265 |
| 06/27/11 | Los Amigos | 33.2 | 150 | <0.265 |
| 06/28/11 | Los Ninos | 53.8 | 150 | <0.265 |
| 06/29/11 | Chaparral M.S. | 45.3 | 150 | <0.265 |
| 06/30/11 | Transportation Bldg | 35.5 | 150 | <0.265 |

Samples running on 06/14/11 and 06/20/11 invalid due to SUSD not changing the filters resulting in double exposures.


NAAQS = National Ambient Air Quality Standard for PM₁₀


Precision of Duplicate Pairs – PM10

At low concentrations, agreement between the measurements of collocated samplers, expressed as relative percent difference, may be relatively poor. For this reason, collocated measurement pairs are selected for use in the precision and bias calculations only when both measurement pairs are equal to or above 15 $\mu\text{g}/\text{m}^3$ (40CFR58, Appendix A, Section 4c).


| Sample Date | Primary Sampler Number | Measured PM ₁₀ ($\mu\text{g}/\text{m}^3$) | Duplicate Sampler Number | Measured PM ₁₀ ($\mu\text{g}/\text{m}^3$) | Difference ($\mu\text{g}/\text{m}^3$) | Percent Difference % |
|-------------|------------------------|--|--------------------------|--|---|----------------------|
| 4/3/11 | 1 | 15.0 | 2 | 15.9 | 0.9 | 5.83 |
| 4/15/11 | 1 | 44.5 | 2 | 46.5 | 2.0 | 4.40 |
| 4/21/11 | 1 | 18.4 | 2 | 17.7 | -0.7 | -3.38 |
| 4/27/11 | 1 | 21.0 | 2 | 25.1 | 4.1 | 17.79 |
| 5/3/11 | 1 | 28.7 | 2 | 32.9 | 4.2 | 13.64 |
| 5/9/11 | 1 | 34.5 | 2 | 33.1 | -1.4 | -4.14 |
| 5/15/11 | 1 | 29.2 | 2 | 19.5 | -9.7 | -39.84 |
| 5/21/11 | 1 | 28.5 | 2 | 20.6 | -7.9 | -32.18 |
| 5/27/11 | 1 | 25.6 | 2 | 24.4 | -1.2 | -4.80 |
| 6/2/11 | 1 | 30.9 | 2 | 32.7 | 1.8 | 5.66 |
| 6/8/11 | 1 | 27.5 | 2 | 28.1 | 0.6 | 2.16 |
| 6/26/11 | 1 | 28.8 | 2 | 29.8 | 1.0 | 3.41 |

PM₁₀ Concentration Charts





Sample running on 05/11/11 invalid do to equipment malfunction.
 Sample running on 05/17/11 invalid for PM10 due to run time being less than 1380 minutes.



Samples running on 06/14/11 and 06/20/11 invalid due to SUSD not changing the filters resulting in double exposures.

Audit Results

Audits were performed on all of the samplers for the 2nd quarter of 2011. If the audit flow rate percent difference is $\leq \pm 10\%$, the sampler calibration is accepted. Differences exceeding $\pm 10\%$ require sampler recalibration. Differences exceeding $\pm 15\%$ will result in invalidation of all data subsequent to the last calibration or valid flow check. The following pages display the audit results for each sampling location.

AUDIT SPREADSHEET FOR PARTICULATES

| Month | Ts | Ps |
|-------|-------|-------|
| Jan | 288.8 | 693.9 |
| Feb | 292.4 | 693.2 |
| Mar | 296.0 | 692.8 |
| Apr | 298.9 | 692.9 |
| May | 300.6 | 692.9 |
| June | 300.3 | 693.4 |
| Jul | 297.6 | 694.0 |
| Aug | 293.8 | 694.5 |
| Sep | 290.1 | 694.9 |
| Oct | 287.2 | 695.3 |
| Nov | 285.8 | 695.2 |
| Dec | 286.5 | 694.7 |

Sampler: Chaparral M.S. **Ts =** 300.3
Audit Date: 06/24/11 **Ps =** 693.4
Motor: 1424 **Temp c =** 40.10
Temp f: 104.18 **Ta =** 313.1
Press: 27.203 **Pa =** 691.0
Altim: 29.865 **Orifice Calibration Relationship**
 m= 1.31697 b= -0.05235

| Plate No. | Orifice dH2O | Qa Orifice | Sampler dPex | Sampler dPext |
|-----------|--------------|------------|--------------|---------------|
| 18 | 3.00 | 32.7 | 1.61 | 0.85 |
| 13 | 2.55 | 30.2 | 1.42 | 0.80 |
| 10 | 2.17 | 28.0 | 1.24 | 0.75 |
| 7 | 1.52 | 23.7 | 0.94 | 0.65 |
| 5 | 1.02 | 19.6 | 0.63 | 0.53 |

Orifice dH2O 2.052
 Sample dPex 1.2
 Orifice Qa(m3/m) 0.771952
 Sample Qa dPex 27.20081

Audit flow rate % diff: 4.93 %

| Orifice | | |
|---------|----------|-----------|
| dH2O | Qa (CFM) | Qa (M3/m) |
| 2.052 | 27.25 | 0.77 |

| Sampler w/Orifice | | |
|-------------------|----------|-----------|
| dPex | Qa (CFM) | Qa (M3/m) |
| 1.17 | 28.60 | 0.81 |

| Sampler Audit Relationship | | |
|----------------------------|-------------|------------|
| m = | 0.024 | |
| b = | 0.066 | |
| r = | 0.996 | |
| | pm10 | tsp |
| Set Point (cfm) | 41.9 | 52.3 |
| Set Point (H20) | 2.6 | 4.0 |

AUDIT SPREADSHEET FOR PARTICULATES

| Month | Ts | Ps |
|-------|-------|-------|
| Jan | 288.8 | 693.9 |
| Feb | 292.4 | 693.2 |
| Mar | 296.0 | 692.8 |
| Apr | 298.9 | 692.9 |
| May | 300.6 | 692.9 |
| June | 300.3 | 693.4 |
| Jul | 297.6 | 694.0 |
| Aug | 293.8 | 694.5 |
| Sep | 290.1 | 694.9 |
| Oct | 287.2 | 695.3 |
| Nov | 285.8 | 695.2 |
| Dec | 286.5 | 694.7 |

Sampler: Sunnyside H.S. **Ts =** 300.3
Audit Date: 06/24/11 **Ps =** 693.4
Motor: 1418 **Temp c =** 36.80
Temp f: 98.24 **Ta =** 309.8
Press: 27.203 **Pa =** 691.0
Altim: 29.865 **Orifice Calibration Relationship**
 m= 1.31697 b= -0.05235

| Plate No. | Orifice dH2O | Qa Orifice | Sampler dPex | Sampler dPext |
|-----------|--------------|------------|--------------|---------------|
| 18 | 3.71 | 36.0 | 2.20 | 0.99 |
| 13 | 3.15 | 33.3 | 1.93 | 0.93 |
| 10 | 2.64 | 30.6 | 1.59 | 0.84 |
| 7 | 1.81 | 25.6 | 1.14 | 0.71 |
| 5 | 1.17 | 20.8 | 0.82 | 0.61 |

Orifice dH2O 2.496
 Sample dPex 1.5
 Orifice Qa(m3/m) 0.843024
 Sample Qa dPex 29.70683

Audit flow rate % diff: 4.89 %

| Orifice | | |
|---------|----------|-----------|
| dH2O | Qa (CFM) | Qa (M3/m) |
| 2.496 | 29.76 | 0.84 |

| Sampler w/Orifice | | |
|-------------------|----------|-----------|
| dPex | Qa (CFM) | Qa (M3/m) |
| 1.54 | 31.22 | 0.88 |

| Sampler Audit Relationship | | |
|----------------------------|-------------|------------|
| m = | 0.026 | |
| b = | 0.061 | |
| r = | 0.998 | |
| | pm10 | tsp |
| Set Point (cfm) | 41.4 | 51.8 |
| Set Point (H20) | 2.9 | 4.4 |

AUDIT SPREADSHEET FOR PARTICULATES

| Month | Ts | Ps |
|-------|-------|-------|
| Jan | 288.8 | 693.9 |
| Feb | 292.4 | 693.2 |
| Mar | 296.0 | 692.8 |
| Apr | 298.9 | 692.9 |
| May | 300.6 | 692.9 |
| June | 300.3 | 693.4 |
| Jul | 297.6 | 694.0 |
| Aug | 293.8 | 694.5 |
| Sep | 290.1 | 694.9 |
| Oct | 287.2 | 695.3 |
| Nov | 285.8 | 695.2 |
| Dec | 286.5 | 694.7 |

Sampler: Los Amigos **Ts =** 300.6
Audit Date: 06/24/11 **Ps =** 693.4
Motor: 1419 **Temp c =** 37.60
Temp f: 99.68 **Ta =** 310.6
Press: 27.203 **Pa =** 691.0
Altim: 29.865 **Orifice Calibration Relationship**
 m= 1.31697 b= -0.05235

| Plate No. | Orifice dH20 | Qa Orifice | Sampler dPex | Sampler dPext |
|-----------|--------------|------------|--------------|---------------|
| 18 | 3.15 | 33.3 | 1.36 | 0.78 |
| 13 | 2.70 | 30.9 | 1.12 | 0.71 |
| 10 | 2.27 | 28.5 | 0.90 | 0.64 |
| 7 | 1.55 | 23.8 | 0.49 | 0.47 |
| 5 | 1.04 | 19.7 | 0.24 | 0.33 |

Orifice dH2O 2.142
 Sample dPex 0.8
 Orifice Qa(m3/m) 0.784845
 Sample Qa dPex 27.93024

| Orifice | | |
|---------|----------|-----------|
| dH2O | Qa (CFM) | Qa (M3/m) |
| 2.142 | 27.71 | 0.78 |

| Sampler w/Orifice | | |
|-------------------|----------|-----------|
| dPex | Qa (CFM) | Qa (M3/m) |
| 0.82 | 28.78 | 0.82 |

| Sampler Audit Relationship | | |
|----------------------------|-------------|------------|
| m = | 0.034 | |
| b = | -0.331 | |
| r = | 0.999 | |
| | pm10 | tsp |
| Set Point (cfm) | 41.5 | 51.8 |
| Set Point (H2O) | 2.5 | 4.4 |

Audit flow rate % diff: 3.86 %

AUDIT SPREADSHEET FOR PARTICULATES

| Month | Ts | Ps |
|-------|-------|-------|
| Jan | 288.8 | 693.9 |
| Feb | 292.4 | 693.2 |
| Mar | 296.0 | 692.8 |
| Apr | 298.9 | 692.9 |
| May | 300.6 | 692.9 |
| June | 300.3 | 693.4 |
| Jul | 297.6 | 694.0 |
| Aug | 293.8 | 694.5 |
| Sep | 290.1 | 694.9 |
| Oct | 287.2 | 695.3 |
| Nov | 285.8 | 695.2 |
| Dec | 286.5 | 694.7 |

Sampler: Los Niños **Ts =** 300.6
Audit Date: 06/24/11 **Ps =** 693.4
Motor: 1421 **Temp c =** 38.80
Temp f: 101.84 **Ta =** 311.8
Press: 27.128 **Pa =** 689.0
Altim: 29.784 **Orifice Calibration Relationship**
 m= 1.31697 b= -0.05235

| Plate No. | Orifice dH20 | Qa Orifice | Sampler dPex | Sampler dPext |
|-----------|--------------|------------|--------------|---------------|
| 18 | 2.96 | 32.4 | 1.20 | 0.74 |
| 13 | 2.56 | 30.3 | 0.98 | 0.67 |
| 10 | 2.13 | 27.7 | 0.78 | 0.59 |
| 7 | 1.48 | 23.3 | 0.49 | 0.47 |
| 5 | 1.01 | 19.5 | 0.25 | 0.34 |

Orifice dH2O 2.028
 Sample dPex 0.7
 Orifice Qa(m3/m) 0.76715
 Sample Qa dPex 27.24452

| Orifice | | |
|---------|----------|-----------|
| dH2O | Qa (CFM) | Qa (M3/m) |
| 2.028 | 27.08 | 0.77 |

| Sampler w/Orifice | | |
|-------------------|----------|-----------|
| dPex | Qa (CFM) | Qa (M3/m) |
| 0.74 | 28.14 | 0.80 |

| Sampler Audit Relationship | | |
|----------------------------|-------------|------------|
| m = | 0.030 | |
| b = | -0.251 | |
| r = | 0.998 | |
| | pm10 | tsp |
| Set Point (cfm) | 41.8 | 52.2 |
| Set Point (H2O) | 2.3 | 4.0 |

Audit flow rate % diff: 3.87 %

AUDIT SPREADSHEET FOR PARTICULATES

| Month | Ts | Ps |
|-------|-------|-------|
| Jan | 288.8 | 693.9 |
| Feb | 292.4 | 693.2 |
| Mar | 296.0 | 692.8 |
| Apr | 298.9 | 692.9 |
| May | 300.6 | 692.9 |
| June | 300.3 | 693.4 |
| Jul | 297.6 | 694.0 |
| Aug | 293.8 | 694.5 |
| Sep | 290.1 | 694.9 |
| Oct | 287.2 | 695.3 |
| Nov | 285.8 | 695.2 |
| Dec | 286.5 | 694.7 |

Sampler: Ocotillo #1 **Ts =** 300.3
Audit Date: 06/24/11 **Ps =** 693.4
Motor: 1420 **Temp c =** 34.80
Temp f: 94.64 **Ta =** 307.8
Press: 27.203 **Pa =** 691.0
Altim: 29.865 **Orifice Calibration Relationship**
 m= 1.31697 b= -0.05235

| Plate No. | Orifice dH2O | Qa Orifice | Sampler dPex | Sampler dPext |
|-----------|--------------|------------|--------------|---------------|
| 18 | 3.33 | 34.1 | 1.33 | 0.77 |
| 13 | 2.80 | 31.3 | 1.08 | 0.69 |
| 10 | 2.35 | 28.8 | 0.84 | 0.61 |
| 7 | 1.62 | 24.2 | 0.48 | 0.46 |
| 5 | 1.08 | 20.0 | 0.24 | 0.33 |

Orifice dH2O 2.236
 Sample dPex 0.8
 Orifice Qa(m3/m) 0.797579
 Sample Qa dPex 28.37338

Audit flow rate % diff: 3.92 %

| Orifice | | |
|---------|----------|-----------|
| dH2O | Qa (CFM) | Qa (M3/m) |
| 2.236 | 28.15 | 0.80 |

| Sampler w/Orifice | | |
|-------------------|---------|----------|
| dPex | Qa(CFM) | Qa(M3/m) |
| 0.79 | 29.27 | 0.83 |

| Sampler Audit Relationship | | |
|----------------------------|-------------|------------|
| m = | 0.032 | |
| b = | -0.305 | |
| r = | 1.000 | |
| | pm10 | tsp |
| Set Point (cfm) | 41.1 | 51.4 |
| Set Point (H2O) | 2.2 | 3.9 |

AUDIT SPREADSHEET FOR PARTICULATES

| Month | Ts | Ps |
|-------|-------|-------|
| Jan | 288.8 | 693.9 |
| Feb | 292.4 | 693.2 |
| Mar | 296.0 | 692.8 |
| Apr | 298.9 | 692.9 |
| May | 300.6 | 692.9 |
| June | 300.3 | 693.4 |
| Jul | 297.6 | 694.0 |
| Aug | 293.8 | 694.5 |
| Sep | 290.1 | 694.9 |
| Oct | 287.2 | 695.3 |
| Nov | 285.8 | 695.2 |
| Dec | 286.5 | 694.7 |

Sampler: Ocotillo #2 **Ts =** 300.3
Audit Date: 06/24/11 **Ps =** 693.4
Motor: 1417 **Temp c =** 34.80
Temp f: 94.64 **Ta =** 307.8
Press: 27.203 **Pa =** 691.0
Altim: 29.865 **Orifice Calibration Relationship**
 m= 1.31697 b= -0.05235

| Plate No. | Orifice dH2O | Qa Orifice | Sampler dPex | Sampler dPext |
|-----------|--------------|------------|--------------|---------------|
| 18 | 3.22 | 33.5 | 1.39 | 0.79 |
| 13 | 2.73 | 31.0 | 1.15 | 0.72 |
| 10 | 2.30 | 28.5 | 0.97 | 0.66 |
| 7 | 1.59 | 24.0 | 0.61 | 0.52 |
| 5 | 1.06 | 19.8 | 0.36 | 0.40 |

Orifice dH2O 2.18
 Sample dPex 0.9
 Orifice Qa(m3/m) 0.788029
 Sample Qa dPex 27.91121

Audit flow rate % diff: 4.13 %

| Orifice | | |
|---------|----------|-----------|
| dH2O | Qa (CFM) | Qa (M3/m) |
| 2.18 | 27.82 | 0.79 |

| Sampler w/Orifice | | |
|-------------------|----------|-----------|
| dPex | Qa (CFM) | Qa (M3/m) |
| 0.90 | 28.98 | 0.82 |

| Sampler Audit Relationship | | |
|----------------------------|-------------|------------|
| m = | 0.028 | |
| b = | -0.157 | |
| r = | 0.999 | |
| | pm10 | tsp |
| Set Point (cfm) | 41.1 | 51.4 |
| Set Point (H2O) | 2.3 | 3.8 |

AUDIT SPREADSHEET FOR PARTICULATES

| Month | Ts | Ps |
|-------|-------|-------|
| Jan | 288.8 | 693.9 |
| Feb | 292.4 | 693.2 |
| Mar | 296.0 | 692.8 |
| Apr | 298.9 | 692.9 |
| May | 300.6 | 692.9 |
| June | 300.3 | 693.4 |
| Jul | 297.6 | 694.0 |
| Aug | 293.8 | 694.5 |
| Sep | 290.1 | 694.9 |
| Oct | 287.2 | 695.3 |
| Nov | 285.8 | 695.2 |
| Dec | 286.5 | 694.7 |

Sampler: Transportation **Ts =** 300.3
Audit Date: 06/27/11 **Ps =** 693.4
Motor: 1422 **Temp c =** 34.80
Temp f: 94.64 **Ta =** 307.8
Press: 27.126 **Pa =** 689.0
Altim: 29.782 **Orifice Calibration Relationship**
 m= 1.31697 b= -0.05235

| Plate No. | Orifice dH2O | Qa Orifice | Sampler dPex | Sampler dPext |
|-----------|--------------|------------|--------------|---------------|
| 18 | 3.35 | 34.2 | 1.43 | 0.80 |
| 13 | 2.83 | 31.6 | 1.15 | 0.72 |
| 10 | 2.35 | 28.9 | 0.97 | 0.66 |
| 7 | 1.60 | 24.1 | 0.64 | 0.53 |
| 5 | 1.06 | 19.9 | 0.37 | 0.41 |

Orifice dH2O 2.238
 Sample dPex 0.9
 Orifice Qa(m3/m) 0.798992
 Sample Qa dPex 28.27772

Audit flow rate % diff: 4.25 %

| Orifice | | |
|---------|----------|-----------|
| dH2O | Qa (CFM) | Qa (M3/m) |
| 2.238 | 28.20 | 0.80 |

| Sampler w/Orifice | | |
|-------------------|----------|-----------|
| dPex | Qa (CFM) | Qa (M3/m) |
| 0.91 | 29.41 | 0.83 |

| Sampler Audit Relationship | | |
|----------------------------|-------------|------------|
| m = | 0.027 | |
| b = | -0.119 | |
| r = | 0.998 | |
| | pm10 | tsp |
| Set Point (cfm) | 41.3 | 51.6 |
| Set Point (H2O) | 2.2 | 3.6 |