



MEMORANDUM

Pima County Department of Environmental Quality

DATE: March 8, 2010

TO: Raul Ochoa
Assistant Superintendent Operations & Facilities Planning

FROM: Beth Gorman
Program Manager

RE: Pima County DEQ Beryllium Monitoring Report 4th Quarter 2009

Attached is the Pima County Department of Environmental Quality's (PDEQ) Air Monitoring Division Beryllium Monitoring Network Summary for the 4th Quarter of 2009.

Highlights:

- 110 samples collected resulting in 104 valid and 6 invalid samples (94.5% data recovery). EPA requires monitoring data recovery at 75%.
- No beryllium values were detected over the Practical Quantitation Limit (PQL).
- PDEQ and SUSD staff are continuing to employ stringent monitoring protocols to ensure quality data is being collected properly to better protect public health.

For additional information on this report, please contact me at Pima County Department of Environmental Quality at (520) 740-3340.

Attachment

Cc: Ursula Kramer, Pima County Department of Environmental Quality Director
Richard Grimaldi, Pima County Department of Environmental Deputy Director



Pima County

Department of Environmental Quality

Air Monitoring Division

Beryllium Monitoring Network Summary

4th Quarter 2009



*Pima County Department of Environmental Quality
150 West Congress St., 1st Floor
Tucson, Arizona 85701*

Summary

The Pima County Department of Environmental Quality has contracted with the Pima County Regional Wastewater Reclamation Department (RWRD) to perform analysis on filters sampled in the Beryllium Monitoring Network located in the Sunnyside Unified School District.

For the 4th quarter of 2009 there was a total of 110 PM₁₀ samples collected resulting in 104 valid and 6 invalid samples; for a data recovery of 94.5 %. Thirteen samples were collected to be used as precision checks as recommended in *40 CFR, Part 58, Appendix A, Section 5.3.1*. All samples run for a 24-hour period as specified in *40 CFR, Part 50, Appendix B*.

There were a total of 107 samples analyzed for beryllium. Beryllium concentrations are reported as <0.265 ng/m³ PQL (Practical Quantitation Level. In the preamble to a November 13, 1985 rulemaking (50 FR 46906), the PQL was defined as “the lowest concentration of an analyte that can be reliably measured within specific limits of precision and accuracy during routine laboratory operating conditions.” The Agency has used the PQL to estimate or evaluate the minimum concentration at which most laboratories can be expected to reliably measure a specific chemical contaminant during day-to-day analysis.

The following pages display the sampling dates, sampling locations, PM₁₀ concentrations (µg/m³) calculated in standard conditions, PM₁₀ 24-hour NAAQS standard, precision measurements, Beryllium analysis results, accompanying graphs and a brief explanation of all invalid samples for the 4th quarter of 2009.

PM₁₀ /Beryllium Concentrations

Monthly Summary of PM₁₀/Beryllium Data

October - 2009

| Date | Location | Standard Concentration PM ₁₀ (µg/m ³) | 24-hour NAAQS PM ₁₀ (µg/m ³) | Beryllium (ng/m ³) |
|----------|---------------------|--|---|--------------------------------|
| 10/01/09 | Chaparral M.S. | 50.0 | 150 | <0.265 |
| 10/02/09 | Transportation Bldg | 38.8 | 150 | <0.265 |
| 10/03/09 | Sunnyside H.S. | 12.4 | 150 | <0.265 |
| 10/04/09 | Ocotillo #1 | 12.9 | 150 | <0.265 |
| 10/04/09 | Ocotillo #2 | 12.7 | 150 | <0.265 |
| 10/05/09 | Los Amigos | 34.8 | 150 | <0.265 |
| 10/06/09 | Los Niños | 41.0 | 150 | <0.265 |
| 10/07/09 | Chaparral M.S. | 32.8 | 150 | <0.265 |
| 10/08/09 | Transportation Bldg | 25.4 | 150 | <0.265 |
| 10/09/09 | Sunnyside H.S. | 32.1 | 150 | <0.265 |
| 10/10/09 | Ocotillo #1 | 31.5 | 150 | <0.265 |
| 10/10/09 | Ocotillo #2 | 30.6 | 150 | <0.265 |
| 10/11/09 | Los Amigos | 15.3 | 150 | <0.265 |
| 10/12/09 | Los Niños | 23.8 | 150 | <0.265 |
| 10/13/09 | Chaparral M.S. | INVALID | 150 | <0.265 |
| 10/14/09 | Transportation Bldg | 36.6 | 150 | <0.265 |
| 10/15/09 | Sunnyside H.S. | 42.9 | 150 | <0.265 |
| 10/16/09 | Ocotillo #1 | 37.7 | 150 | <0.265 |
| 10/16/09 | Ocotillo #2 | 39.5 | 150 | <0.265 |
| 10/17/09 | Los Amigos | 22.6 | 150 | <0.265 |
| 10/18/09 | Los Niños | 21.4 | 150 | <0.265 |
| 10/19/09 | Chaparral M.S. | 18.4 | 150 | <0.265 |
| 10/20/09 | Transportation Bldg | INVALID | 150 | <0.265 |
| 10/21/09 | Sunnyside H.S. | 33.5 | 150 | <0.265 |
| 10/22/09 | Ocotillo #1 | 23.8 | 150 | <0.265 |
| 10/22/09 | Ocotillo #2 | 28.3 | 150 | <0.265 |
| 10/23/09 | Los Amigos | 48.2 | 150 | <0.265 |
| 10/24/09 | Los Niños | 34.2 | 150 | <0.265 |
| 10/25/09 | Chaparral M.S. | 29.9 | 150 | <0.265 |
| 10/26/09 | Transportation Bldg | 47.8 | 150 | <0.265 |
| 10/27/09 | Sunnyside H.S. | 59.9 | 150 | <0.265 |
| 10/28/09 | Ocotillo #1 | 30.0 | 150 | <0.265 |
| 10/28/09 | Ocotillo #2 | 31.4 | 150 | <0.265 |
| 10/29/09 | Los Amigos | 27.5 | 150 | <0.265 |
| 10/30/09 | Los Niños | 35.5 | 150 | <0.265 |
| 10/31/09 | Chaparral M.S. | 32.1 | 150 | <0.265 |

Sample running on 10/13/09 invalid for PM₁₀ due to sampler flow being >44 CFM.

Sample running on 10/20/09 invalid for PM₁₀ due to sampler flow being >44 CFM.

*Sample invalid for use in Beryllium analysis.

NAAQS = National Ambient Air Quality Standard for PM₁₀

PM₁₀ /Beryllium Concentrations (continued)

Monthly Summary of PM₁₀/Beryllium Data

November - 2009

| Date | Location | Standard Concentration PM₁₀ (µg/m³) | 24-hour NAAQS PM₁₀ (µg/m³) | Beryllium (ng/m³) |
|-------------|---------------------|--|---|-------------------------------------|
| 11/01/09 | Transportation Bldg | 18.2 | 150 | <0.265 |
| 11/02/09 | Sunnyside H.S. | 38.0 | 150 | <0.265 |
| 11/03/09 | Ocotillo #1 | 28.2 | 150 | <0.265 |
| 11/03/09 | Ocotillo #2 | 30.5 | 150 | <0.265 |
| 11/04/09 | Los Amigos | 30.2 | 150 | <0.265 |
| 11/05/09 | Los Niños | 25.2 | 150 | <0.265 |
| 11/06/09 | Chaparral M.S. | 49.2 | 150 | <0.265 |
| 11/07/09 | Transportation Bldg | INVALID | 150 | <0.265 |
| 11/08/09 | Sunnyside H.S. | 20.5 | 150 | <0.265 |
| 11/09/09 | Ocotillo #1 | 30.4 | 150 | <0.265 |
| 11/09/09 | Ocotillo #2 | 32.1 | 150 | <0.265 |
| 11/10/09 | Los Amigos | 34.4 | 150 | <0.265 |
| 11/11/09 | Los Niños | 28.4 | 150 | <0.265 |
| 11/12/09 | Chaparral M.S. | INVALID | 150 | INVALID* |
| 11/13/09 | Transportation Bldg | 12.9 | 150 | <0.265 |
| 11/14/09 | Sunnyside H.S. | 18.5 | 150 | <0.265 |
| 11/15/09 | Ocotillo #1 | 15.2 | 150 | <0.265 |
| 11/15/09 | Ocotillo #2 | 17.3 | 150 | <0.265 |
| 11/16/09 | Los Amigos | 25.8 | 150 | <0.265 |
| 11/17/09 | Los Ninos | INVALID | 150 | INVALID* |
| 11/18/09 | Chaparral M.S. | INVALID | 150 | INVALID* |
| 11/19/09 | Transportation Bldg | 30.2 | 150 | <0.265 |
| 11/20/09 | Sunnyside H.S. | 44.3 | 150 | <0.265 |
| 11/21/09 | Ocotillo #1 | 26.1 | 150 | <0.265 |
| 11/21/09 | Ocotillo #2 | 26.3 | 150 | <0.265 |
| 11/22/09 | Los Amigos | 22.3 | 150 | <0.265 |
| 11/23/09 | Los Ninos | 21.2 | 150 | <0.265 |
| 11/24/09 | Chaparral M.S. | 37.4 | 150 | <0.265 |
| 11/25/09 | Transportation Bldg | 36.0 | 150 | <0.265 |
| 11/26/09 | Sunnyside H.S. | 44.4 | 150 | <0.265 |
| 11/27/09 | Ocotillo #1 | 24.7 | 150 | <0.265 |
| 11/27/09 | Ocotillo #2 | 26.3 | 150 | <0.265 |
| 11/28/09 | Los Amigos | 45.1 | 150 | <0.265 |
| 11/29/09 | Los Niños | 20.8 | 150 | <0.265 |
| 11/30/09 | Chaparral M.S. | 5.5 | 150 | <0.265 |

Sample running on 11/07/09 invalid for PM10 due to sampler flow being >44 CFM.

Sample running on 11/12/09 invalid due to double exposure caused by filter not being changed by SUSD.

Sample running on 11/17/09 invalid due to the filter not being installed by SUSD.

Sample running on 11/18/09 invalid due to double exposure caused by filter not being change by SUSD.

* Sample invalid for use in Beryllium analysis.

NAAQS = National Ambient Air Quality Standard for PM₁₀

PM₁₀ /Beryllium Concentrations (continued)

Monthly Summary of PM₁₀/Beryllium Data

December - 2009

| Date | Location | Standard Concentration PM₁₀ (µg/m³) | 24-hour NAAQS PM₁₀ (µg/m³) | Beryllium (ng/m³) |
|-------------|---------------------|--|---|---|
| 12/01/09 | Transportation Bldg | 11.3 | 150 | <0.265 |
| 12/02/09 | Sunnyside H.S. | 19.0 | 150 | <0.265 |
| 12/03/09 | Ocotillo #1 | 20.4 | 150 | <0.265 |
| 12/03/09 | Ocotillo #2 | 22.3 | 150 | <0.265 |
| 12/04/09 | Los Amigos | 23.4 | 150 | <0.265 |
| 12/05/09 | Los Niños | 13.8 | 150 | <0.265 |
| 12/06/09 | Chaparral M.S. | 18.7 | 150 | <0.265 |
| 12/07/09 | Transportation Bldg | 55.0 | 150 | <0.265 |
| 12/08/09 | Sunnyside H.S. | 75.0 | 150 | <0.265 |
| 12/09/09 | Ocotillo #1 | 33.1 | 150 | <0.265 |
| 12/09/09 | Ocotillo #2 | 37.4 | 150 | <0.265 |
| 12/10/09 | Los Amigos | 35.2 | 150 | <0.265 |
| 12/11/09 | Los Niños | 30.5 | 150 | <0.265 |
| 12/12/09 | Chaparral M.S. | 15.6 | 150 | <0.265 |
| 12/13/09 | Transportation Bldg | 23.5 | 150 | <0.265 |
| 12/14/09 | Sunnyside H.S. | 28.2 | 150 | <0.265 |
| 12/15/09 | Ocotillo #1 | 18.1 | 150 | <0.265 |
| 12/15/09 | Ocotillo #2 | 17.0 | 150 | <0.265 |
| 12/16/09 | Los Amigos | 13.2 | 150 | <0.265 |
| 12/17/09 | Los Niños | 21.5 | 150 | <0.265 |
| 12/18/09 | Chaparral M.S. | 29.0 | 150 | <0.265 |
| 12/19/09 | Transportation Bldg | 19.9 | 150 | <0.265 |
| 12/20/09 | Sunnyside H.S. | 19.6 | 150 | <0.265 |
| 12/21/09 | Ocotillo #1 | 27.6 | 150 | <0.265 |
| 12/21/09 | Ocotillo #2 | 29.3 | 150 | <0.265 |
| 12/22/09 | Los Amigos | 88.5 | 150 | <0.265 |
| 12/23/09 | Los Ninos | 45.8 | 150 | <0.265 |
| 12/24/09 | Chaparral M.S. | 12.6 | 150 | <0.265 |
| 12/25/09 | Transportation Bldg | 12.1 | 150 | <0.265 |
| 12/26/09 | Sunnyside H.S. | 17.1 | 150 | <0.265 |
| 12/27/09 | Ocotillo #1 | 11.6 | 150 | <0.265 |
| 12/27/09 | Ocotillo #2 | 12.1 | 150 | <0.265 |
| 12/28/09 | Los Amigos | 13.8 | 150 | <0.265 |
| 12/29/09 | Los Ninos | 16.6 | 150 | <0.265 |
| 12/30/09 | Chaparral M.S. | 15.5 | 150 | <0.265 |
| 12/31/09 | Transportation Bldg | 11.9 | 150 | <0.265 |

* Sample invalid for use in Beryllium analysis.


NAAQS = National Ambient Air Quality Standard for PM₁₀

Precision of Duplicate Pairs – PM10

At low concentrations, agreement between the measurements of collocated samplers, expressed as relative percent difference, may be relatively poor. For this reason, collocated measurement pairs are selected for use in the precision and bias calculations only when both measurement pairs are equal to or above 15µg/m³ (40CFR58, Appendix A, Section 4c).


| Sample Date | Primary Sampler Number | Measured PM ₁₀ (µg/m ³) | Duplicate Sampler Number | Measured PM ₁₀ (µg/m ³) | Difference (µg/m ³) | Percent Difference % |
|-------------|------------------------|--|--------------------------|--|---------------------------------|----------------------|
| 10/10/09 | 1 | 31.5 | 2 | 30.6 | -0.9 | -2.90 |
| 10/16/09 | 1 | 37.7 | 2 | 39.5 | 1.8 | 4.66 |
| 10/22/09 | 1 | 23.8 | 2 | 28.3 | 4.5 | 17.27 |
| 10/28/09 | 1 | 30.0 | 2 | 31.4 | 1.4 | 4.56 |
| 11/03/09 | 1 | 28.2 | 2 | 30.5 | 2.3 | 7.84 |
| 11/09/09 | 1 | 30.4 | 2 | 32.1 | 1.7 | 5.44 |
| 11/15/09 | 1 | 15.2 | 2 | 17.3 | 2.1 | 12.92 |
| 11/21/09 | 1 | 26.1 | 2 | 26.3 | 0.2 | 0.76 |
| 11/27/09 | 1 | 24.7 | 2 | 26.3 | 1.6 | 6.27 |
| 12/03/09 | 1 | 20.4 | 2 | 22.3 | 1.9 | 8.90 |
| 12/09/09 | 1 | 33.1 | 2 | 37.4 | 4.3 | 12.20 |
| 12/15/09 | 1 | 18.1 | 2 | 17.0 | -1.1 | -6.27 |
| 12/21/09 | 1 | 27.6 | 2 | 29.3 | 1.7 | 5.98 |

PM₁₀ Concentration Charts



Sample running on 10/13/09 invalid for PM₁₀ due to sampler flow being >44 CFM.
 Sample running on 10/20/09 invalid for PM₁₀ due to sampler flow being >44 CFM.

NAAQS = National Ambient Air Quality Standards for PM₁₀




Sample running on 11/07/09 invalid for PM10 due to sampler flow being >44 CFM.

Sample running on 11/12/09 invalid due to double exposure caused by filter not being changed by SUSD.

Sample running on 11/17/09 invalid due to the filter not being installed by SUSD.

Sample running on 11/18/09 invalid due to double exposure caused by filter not being change by SUSD.

NAAQS = National Ambient Air Quality Standards for PM₁₀



NAAQS = National Ambient Air Quality Standards for PM₁₀

Audit Results

Audits were performed on all of the samplers for the 4th quarter of 2009. If the audit flow rate percent difference is $\leq \pm 10\%$, the sampler calibration is accepted. Differences exceeding $\pm 10\%$ require sampler recalibration. Differences exceeding $\pm 15\%$ will result in invalidation of all data subsequent to the last calibration or valid flow check. The following pages display the audit results for each sampling location.

AUDIT SPREADSHEET FOR PARTICULATES

| Month | Ts | Ps |
|-------|-------|-------|
| Jan | 288.8 | 693.9 |
| Feb | 292.4 | 693.2 |
| Mar | 296.0 | 692.8 |
| Apr | 298.9 | 692.9 |
| May | 300.6 | 692.9 |
| June | 300.3 | 693.4 |
| Jul | 297.6 | 694.0 |
| Aug | 293.8 | 694.5 |
| Sep | 290.1 | 694.9 |
| Oct | 287.2 | 695.3 |
| Nov | 285.8 | 695.2 |
| Dec | 286.5 | 694.7 |

Sampler: Chaparral M.S. **Ts =** 286.5
Audit Date: 12/21/09 **Ps =** 694.7
Motor: 1424 **Temp c =** 17.30
Temp f: 63.14 **Ta =** 290.3
Press: 27.362 **Pa =** 695.0
Altim: 30.037 **Orifice Calibration Relationship**
 m= 1.30507 b= -0.03648

| Plate No. | Orifice dH20 | Qa Orifice | Sampler dPex | Sampler dPext |
|-----------|--------------|------------|--------------|---------------|
| 18 | 4.41 | 37.7 | 2.38 | 1.00 |
| 13 | 3.70 | 34.6 | 2.02 | 0.92 |
| 10 | 3.06 | 31.6 | 1.68 | 0.84 |
| 7 | 2.03 | 25.9 | 1.17 | 0.70 |
| 5 | 1.32 | 21.1 | 0.85 | 0.60 |

Orifice dH2O 2.904
 Sample dPex 1.6
 Orifice Qa(m3/m) 0.871861
 Sample Qa dPex 30.71088

| Orifice | | |
|---------|---------|----------|
| dH20 | Qa(CFM) | Qa(M3/m) |
| 2.904 | 30.78 | 0.87 |

| Sampler w/Orifice | | |
|-------------------|---------|----------|
| dPex | Qa(CFM) | Qa(M3/m) |
| 1.62 | 32.42 | 0.92 |

| Sampler Audit Relationship | | |
|----------------------------|-------------|------------|
| m = | 0.024 | |
| b = | 0.078 | |
| r = | 0.999 | |
| | pm10 | tsp |
| Set Point (cfm) | 40.5 | 50.6 |
| Set Point (H20) | 2.7 | 4.1 |

Audit flow rate % diff: 5.31 %

AUDIT SPREADSHEET FOR PARTICULATES

| Month | Ts | Ps |
|-------|-------|-------|
| Jan | 288.8 | 693.9 |
| Feb | 292.4 | 693.2 |
| Mar | 296.0 | 692.8 |
| Apr | 298.9 | 692.9 |
| May | 300.6 | 692.9 |
| June | 300.3 | 693.4 |
| Jul | 297.6 | 694.0 |
| Aug | 293.8 | 694.5 |
| Sep | 290.1 | 694.9 |
| Oct | 287.2 | 695.3 |
| Nov | 285.8 | 695.2 |
| Dec | 286.5 | 694.7 |

Sampler: Sunnyside H.S. **Ts =** 286.5
Audit Date: 12/21/09 **Ps =** 694.7
Motor: 1418 **Temp c =** 21.60
Temp f: 70.88 **Ta =** 294.6
Press: 27.362 **Pa =** 695.0
Altim: 30.037 **Orifice Calibration Relationship**
 m= 1.30507 b= -0.03648

| Plate No. | Orifice dH20 | Qa Orifice | Sampler dPex | Sampler dPext |
|-----------|--------------|------------|--------------|---------------|
| 18 | 3.96 | 36.0 | 2.30 | 0.99 |
| 13 | 3.35 | 33.2 | 2.01 | 0.92 |
| 10 | 2.85 | 30.7 | 1.70 | 0.85 |
| 7 | 1.90 | 25.3 | 1.18 | 0.71 |
| 5 | 1.23 | 20.5 | 0.83 | 0.59 |

Orifice dH20 2.658
 Sample dPex 1.6
 Orifice Qa(m3/m) 0.841284
 Sample Qa dPex 29.64797

| Orifice | | |
|---------|---------|----------|
| dH20 | Qa(CFM) | Qa(M3/m) |
| 2.658 | 29.70 | 0.84 |

| Sampler w/Orifice | | |
|-------------------|---------|----------|
| dPex | Qa(CFM) | Qa(M3/m) |
| 1.60 | 31.24 | 0.88 |

| Sampler Audit Relationship | | |
|----------------------------|-------------|------------|
| m = | 0.026 | |
| b = | 0.062 | |
| r = | 0.999 | |
| | pm10 | tsp |
| Set Point (cfm) | 41.1 | 51.4 |
| Set Point (H20) | 3.0 | 4.5 |

Audit flow rate % diff: 5.17 %

AUDIT SPREADSHEET FOR PARTICULATES

| Month | Ts | Ps |
|-------|-------|-------|
| Jan | 288.8 | 693.9 |
| Feb | 292.4 | 693.2 |
| Mar | 296.0 | 692.8 |
| Apr | 298.9 | 692.9 |
| May | 300.6 | 692.9 |
| June | 300.3 | 693.4 |
| Jul | 297.6 | 694.0 |
| Aug | 293.8 | 694.5 |
| Sep | 290.1 | 694.9 |
| Oct | 287.2 | 695.3 |
| Nov | 285.8 | 695.2 |
| Dec | 286.5 | 694.7 |

Sampler: Los Amigos **Ts =** 286.5
Audit Date: 12/21/09 **Ps =** 694.7
Motor: 1419 **Temp c =** 14.60
Temp f: 58.28 **Ta =** 287.6
Press: 27.441 **Pa =** 697.0
Altim: 30.122 **Orifice Calibration Relationship**
 m= 1.30507 b= -0.03648

| Plate No. | Orifice dH2O | Qa Orifice | Sampler dPex | Sampler dPext |
|-----------|--------------|------------|--------------|---------------|
| 18 | 3.58 | 33.9 | 1.56 | 0.80 |
| 13 | 2.98 | 31.0 | 1.26 | 0.72 |
| 10 | 2.43 | 28.1 | 0.96 | 0.63 |
| 7 | 1.65 | 23.3 | 0.55 | 0.48 |
| 5 | 1.10 | 19.2 | 0.23 | 0.31 |

Orifice dH2O 2.348
 Sample dPex 0.9
 Orifice Qa(m3/m) 0.782163
 Sample Qa dPex 27.86929

| Orifice | | |
|---------|---------|----------|
| dH2O | Qa(CFM) | Qa(M3/m) |
| 2.348 | 27.61 | 0.78 |

| Sampler w/Orifice | | |
|-------------------|---------|----------|
| dPex | Qa(CFM) | Qa(M3/m) |
| 0.91 | 28.80 | 0.82 |

| Sampler Audit Relationship | | |
|----------------------------|-------------|------------|
| m = | 0.034 | |
| b = | -0.320 | |
| r = | 0.995 | |
| | pm10 | tsp |
| Set Point (cfm) | 40.0 | 50.0 |
| Set Point (H2O) | 2.5 | 4.5 |

Audit flow rate % diff: 4.28 %

AUDIT SPREADSHEET FOR PARTICULATES

| Month | Ts | Ps |
|-------|-------|-------|
| Jan | 288.8 | 693.9 |
| Feb | 292.4 | 693.2 |
| Mar | 296.0 | 692.8 |
| Apr | 298.9 | 692.9 |
| May | 300.6 | 692.9 |
| June | 300.3 | 693.4 |
| Jul | 297.6 | 694.0 |
| Aug | 293.8 | 694.5 |
| Sep | 290.1 | 694.9 |
| Oct | 287.2 | 695.3 |
| Nov | 285.8 | 695.2 |
| Dec | 286.5 | 694.7 |

Sampler: Los Niños **Ts =** 286.5
Audit Date: 12/21/09 **Ps =** 694.7
Motor: 1421 **Temp c =** 19.50
Temp f: 67.10 **Ta =** 292.5
Press: 27.362 **Pa =** 695.0
Altim: 30.037 **Orifice Calibration Relationship**
 m= 1.30507 b= -0.03648

| Plate No. | Orifice dH2O | Qa Orifice | Sampler dPex | Sampler dPext |
|-----------|--------------|------------|--------------|---------------|
| 18 | 3.23 | 32.5 | 1.31 | 0.74 |
| 13 | 2.73 | 30.0 | 1.04 | 0.66 |
| 10 | 2.28 | 27.5 | 0.83 | 0.59 |
| 7 | 1.56 | 22.9 | 0.48 | 0.45 |
| 5 | 1.00 | 18.5 | 0.26 | 0.33 |

Orifice dH2O 2.160
 Sample dPex 0.8
 Orifice Qa(m3/m) 0.758525
 Sample Qa dPex 26.94804

| Orifice | | |
|---------|---------|----------|
| dH2O | Qa(CFM) | Qa(M3/m) |
| 2.160 | 26.78 | 0.76 |

| Sampler w/Orifice | | |
|-------------------|---------|----------|
| dPex | Qa(CFM) | Qa(M3/m) |
| 0.78 | 27.92 | 0.79 |

| Sampler Audit Relationship | | |
|----------------------------|-------------|------------|
| m = | 0.029 | |
| b = | -0.220 | |
| r = | 0.999 | |
| | pm10 | tsp |
| Set Point (cfm) | 40.8 | 51.0 |
| Set Point (H2O) | 2.3 | 3.9 |

Audit flow rate % diff: 4.25 %

AUDIT SPREADSHEET FOR PARTICULATES

| Month | Ts | Ps |
|-------|-------|-------|
| Jan | 288.8 | 693.9 |
| Feb | 292.4 | 693.2 |
| Mar | 296.0 | 692.8 |
| Apr | 298.9 | 692.9 |
| May | 300.6 | 692.9 |
| June | 300.3 | 693.4 |
| Jul | 297.6 | 694.0 |
| Aug | 293.8 | 694.5 |
| Sep | 290.1 | 694.9 |
| Oct | 287.2 | 695.3 |
| Nov | 285.8 | 695.2 |
| Dec | 286.5 | 694.7 |

Sampler: Ocotillo #1 **Ts =** 286.5
Audit Date: 12/24/09 **Ps =** 694.7
Motor: 1420 **Temp c =** 13.50
Temp f: 56.30 **Ta =** 286.5
Press: 27.441 **Pa =** 697.0
Altim: 30.122 **Orifice Calibration Relationship**
 m= 1.30507 b= -0.03648

| Plate No. | Orifice dH20 | Qa Orifice | Sampler dPex | Sampler dPext |
|-----------|--------------|------------|--------------|---------------|
| 18 | 3.83 | 34.9 | 1.59 | 0.81 |
| 13 | 3.18 | 31.9 | 1.28 | 0.73 |
| 10 | 2.67 | 29.3 | 0.98 | 0.63 |
| 7 | 1.80 | 24.3 | 0.56 | 0.48 |
| 5 | 1.18 | 19.8 | 0.23 | 0.31 |

Orifice dH2O 2.532
 Sample dPex 0.9
 Orifice Qa(m3/m) 0.809658
 Sample Qa dPex 28.85584

| Orifice | | |
|---------|---------|----------|
| dH2O | Qa(CFM) | Qa(M3/m) |
| 2.532 | 28.58 | 0.81 |

| Sampler w/Orifice | | |
|-------------------|---------|----------|
| dPex | Qa(CFM) | Qa(M3/m) |
| 0.93 | 29.81 | 0.84 |

| Sampler Audit Relationship | | |
|----------------------------|-------------|------------|
| m = | 0.033 | |
| b = | -0.336 | |
| r = | 0.997 | |
| | | |
| | pm10 | tsp |
| Set Point (cfm) | 39.9 | 49.8 |
| Set Point (H2O) | 2.3 | 4.2 |

Audit flow rate % diff: 4.27 %

AUDIT SPREADSHEET FOR PARTICULATES

| Month | Ts | Ps |
|-------|-------|-------|
| Jan | 288.8 | 693.9 |
| Feb | 292.4 | 693.2 |
| Mar | 296.0 | 692.8 |
| Apr | 298.9 | 692.9 |
| May | 300.6 | 692.9 |
| June | 300.3 | 693.4 |
| Jul | 297.6 | 694.0 |
| Aug | 293.8 | 694.5 |
| Sep | 290.1 | 694.9 |
| Oct | 287.2 | 695.3 |
| Nov | 285.8 | 695.2 |
| Dec | 286.5 | 694.7 |

Sampler: Ocotillo #2 **Ts =** 286.5
Audit Date: 12/24/09 **Ps =** 694.7
Motor: 1417 **Temp c =** 13.50
Temp f: 56.30 **Ta =** 286.5
Press: 27.441 **Pa =** 697.0
Altim: 30.122 **Orifice Calibration Relationship**
 m= 1.30507 b= -0.03648

| Plate No. | Orifice dH20 | Qa Orifice | Sampler dPex | Sampler dPext |
|-----------|--------------|------------|--------------|---------------|
| 18 | 3.90 | 35.2 | 1.71 | 0.84 |
| 13 | 3.32 | 32.6 | 1.42 | 0.76 |
| 10 | 2.79 | 30.0 | 1.14 | 0.68 |
| 7 | 1.83 | 24.5 | 0.68 | 0.53 |
| 5 | 1.19 | 19.9 | 0.35 | 0.38 |

Orifice dH2O 2.606
 Sample dPex 1.1
 Orifice Qa(m3/m) 0.820999
 Sample Qa dPex 29.14093

| Orifice | | |
|---------|---------|----------|
| dH2O | Qa(CFM) | Qa(M3/m) |
| 2.606 | 28.98 | 0.82 |

| Sampler w/Orifice | | |
|-------------------|---------|----------|
| dPex | Qa(CFM) | Qa(M3/m) |
| 1.06 | 30.27 | 0.86 |

| Sampler Audit Relationship | | |
|----------------------------|-------------|------------|
| m = | 0.030 | |
| b = | -0.207 | |
| r = | 0.999 | |
| | | |
| | pm10 | tsp |
| Set Point (cfm) | 39.9 | 49.8 |
| Set Point (H2O) | 2.3 | 4.0 |

Audit flow rate % diff: 4.43 %

AUDIT SPREADSHEET FOR PARTICULATES

| Month | Ts | Ps |
|-------|-------|-------|
| Jan | 288.8 | 693.9 |
| Feb | 292.4 | 693.2 |
| Mar | 296.0 | 692.8 |
| Apr | 298.9 | 692.9 |
| May | 300.6 | 692.9 |
| June | 300.3 | 693.4 |
| Jul | 297.6 | 694.0 |
| Aug | 293.8 | 694.5 |
| Sep | 290.1 | 694.9 |
| Oct | 287.2 | 695.3 |
| Nov | 285.8 | 695.2 |
| Dec | 286.5 | 694.7 |

Sampler: Transportation **Ts =** 286.5
Audit Date: 12/21/09 **Ps =** 694.7
Motor: 1422 **Temp c =** 20.70
Temp f: 69.26 **Ta =** 293.7
Press: 27.362 **Pa =** 695.0
Altim: 30.037 **Orifice Calibration Relationship**
 m= 1.30507 b= -0.03648

| Plate No. | Orifice dH20 | Qa Orifice | Sampler dPex | Sampler dPext |
|-----------|--------------|------------|--------------|---------------|
| 18 | 3.70 | 34.8 | 1.65 | 0.84 |
| 13 | 3.19 | 32.4 | 1.31 | 0.74 |
| 10 | 2.60 | 29.3 | 1.04 | 0.66 |
| 7 | 1.77 | 24.4 | 0.68 | 0.54 |
| 5 | 1.17 | 20.0 | 0.41 | 0.42 |

Orifice dH2O 2.486
 Sample dPex 1.0
 Orifice Qa(m3/m) 0.813326
 Sample Qa dPex 28.81027

Audit flow rate % diff: 4.44 %

| Orifice | | |
|---------|---------|----------|
| dH20 | Qa(CFM) | Qa(M3/m) |
| 2.486 | 28.71 | 0.81 |

| Sampler w/Orifice | | |
|-------------------|---------|----------|
| dPex | Qa(CFM) | Qa(M3/m) |
| 1.02 | 29.99 | 0.85 |

| Sampler Audit Relationship | | |
|----------------------------|-------------|------------|
| m = | 0.028 | |
| b = | -0.139 | |
| r = | 0.997 | |
| | pm10 | tsp |
| Set Point (cfm) | 41.0 | 51.2 |
| Set Point (H2O) | 2.3 | 3.8 |