



June 1, 2011

Mr. Mukonde Chama, P.E.
Air Permitting Supervisor
Pima County Department of Environmental Quality
33 N. Stone Avenue, Suite 700
Tucson, AZ 85701-1317

**Re: Air Quality Permit Application, Permit No. 6112
Rosemont Copper Project**

Dear Mr. Chama:

Rosemont Copper Company (Rosemont) is pleased to respond to your letter dated May 12, 2011 requesting Rosemont provide additional information in support of its Class II Air Quality Application for the proposed Rosemont Copper Project. Specifically, the PDEQ letter requested detailed information demonstrating that the pollution control equipment are designed in a manner that will achieve the proposed voluntarily accepted emission limits.

This letter and the associated attachments address the requested additional information. Additionally, Rosemont is making one minor amendment to the Class II Air Quality Permit Application. Attachment A includes the Certification of Truth, Accuracy, and Completeness signed by the responsible official of the Rosemont Copper Company. Attachment B was prepared by our air consultant, Applied Environmental Consultants, a JBR company, and summarizes the amendment and the additional information that was requested by PDEQ.

If any additional information is necessary to complete the processing of the Class II air quality permit application, please inform Rosemont as soon as possible.

Sincerely,

Katherine Ann Arnold, PE
Vice President of Environmental and Regulatory Affairs

Attachments:

Attachment A: Certification of Truth, Accuracy, and Completeness
Attachment B: Requested Additional Information

ATTACHMENT A

CERTIFICATION OF TRUTH, ACCURACY, AND COMPLETENESS



ROSEMONT COPPER

A Bridge to a Sustainable Future.

June 1, 2011

Mr. Mukonde Chama, P.E.
Air Permitting Supervisor
Pima County Department of Environmental Quality
33 North Stone Avenue, Suite 700
Tucson, AZ 85701

Re: Certification of Truth, Accuracy, and Completeness for Rosemont Copper Company's
Amendment and Response to the Additional Information Requested by the Pima County
Department of Environmental Quality

Dear Mr. Chama:

Enclosed please find Rosemont Copper Company's response to the necessary additional information requested by the Pima County Department of Environmental Quality (PDEQ). Additionally, an amendment to the Rosemont Copper Mine's Class II Air Quality Permit Application has also been included.

By my signature, I, Katherine Ann Arnold, Vice President of Environmental and Regulatory Affairs, Rosemont Copper Company, hereby certify that based on information and belief formed after reasonable inquiry, the statements and information in the amendment and response to PDEQ's request for additional information are true, accurate, and complete.

Sincerely,

Katherine Ann Arnold, PE
Vice President of Environmental and Regulatory Affairs
Rosemont Copper Company

ATTACHMENT B

REQUESTED ADDITIONAL INFORMATION

1. INTRODUCTION

In a letter dated May 12, 2011, the Pima Department of Environmental Quality (PDEQ) made the following request for additional information from the Rosemont Copper Company in regards to the Rosemont Copper Mine's (RCM's) application for a Class II Air Quality Permit:

PDEQ requires additional information regarding the technical aspects of the mine processes, specifically a written demonstration that includes calculations showing the control efficiencies for the pollution control equipment (APC) and the proposed technical and operational design of the operation.

When evaluating RCM's proposed pre-construction emission limits in its application, a detailed and verifiable demonstration is required of how these limits will be met upon start-up of the mine's operations. The application only provides the voluntarily accepted limits on the source's Potential to Emit (PTE) so that the source is classified as a Class II synthetic minor. In order for these limits to be enforceable as a practical manner, RCM must provide detailed information that shows the source is designed in a manner that proposed limits can be achieved. This demonstration would include the specific parameters and design calculations such as capture efficiency, flow rates, and manufacturer's specifications for the following APC:

1. *Crushing area wet scrubber*
2. *Stockpile area wet scrubber*
3. *Reclaim tunnel scrubber*
4. *Pebble crusher area scrubber*
5. *Copper concentrate scrubber 1 & 2*
6. *Molybdenum scrubber*
7. *Molybdenum precipitator*
8. *Laboratory dust collector*

The remainder of this attachment addresses the information requested by the PDEQ and an amendment to RCM's Class II Air Quality Permit Application. Background and amendment information about the particulate matter pollution control devices used in the Rosemont Copper Project (RCP) is presented in Section 2. The methodology used to provide the requested additional information is presented in Section 3. A summary table demonstrating that the particulate matter pollution control devices are designed in a manner that the proposed limits can be achieved at the start-up of the mine is presented in Section 4. Finally, detailed information about the amendment is presented in Section 5.

2. BACKGROUND AND AMENDMENT INFORMATION

2.1. BACKGROUND INFORMATION

Particulate matter pollution control equipment that will be utilized by the RCP includes six wet scrubbers, one venturi scrubber, four baghouses, and an electrostatic precipitator. These pollution

control devices control emissions from metallic mineral processing equipment subject to 40 CFR 60 Subpart LL, New Source Performance Standards (NSPS) for metallic mineral processing facilities. Therefore, the pollution control devices are subject to an outlet grain loading limit of 0.022 grains/dscf for particulate matter (40 CFR 60.382(a)(1)). In order to minimize potential emissions from the particulate matter control devices and be classified as a synthetic minor source, the RCP has proposed in its application for a Class II Air Quality Permit to accept federally enforceable emission limits expressed in either pounds/hour or in grains/dscf that are stricter than the federally mandated emission standard.

A listing of the particulate matter pollution control devices used at the RCP is presented in Table 2.1. The proposed emission limit for particulate matter less than 10 microns in aerodynamic diameter (PM₁₀), the exhaust flow rate, the type of pollution control device, and the name of the manufacturer for each particulate matter pollution control device are also presented in Table 2.1. Detailed manufacturer's information including design parameters for the different particulate matter pollution control devices is presented in Attachments B3 through B5. Table 2.1 references the appropriate attachment for each particulate matter pollution control device.

2.2. AMENDMENT INFORMATION

Although the design of the RCP equipment was considered final at the time of submittal of the Class II Air Quality Permit Application, subsequent review indicated that the molybdenum scrubber and electrostatic precipitator operating in series to control emissions from the molybdenum drying operations was oversized. Reconsideration of the pollution control system has resulted in a more appropriately sized control system, with a lower exhaust flow rate and consequently a slightly lower emission rate.

Through this response to the PDEQ, the RCP is amending the PM₁₀ emission limit proposed for the molybdenum scrubber / electrostatic precipitator. The PM₁₀ emission limit will be revised from 0.02 lb/hour to 0.014 lb/hour. More detailed information about the amendment is presented in Section 5 of this attachment. This information includes:

- A demonstration showing compliance with the NSPS emission standard; and
- Calculation of the revised potential to emit from the molybdenum scrubber / electrostatic precipitator and the entire RCP.

For completeness, Table 2.1 presents the proposed PM₁₀ emission limit and exhaust flow rate information for the molybdenum scrubber / electrostatic precipitator both prior to and after the amendment.

Table 2.1 Particulate Matter Pollution Control Equipment at the RCP

Unit ID	Pollution Control Device	Proposed PM ₁₀ Emission Limit	Exhaust Flow Rate	Type of Pollution Control Device	Name of Manufacturer	Reference for Manufacturer's Information
PCL01	Crushing Area Scrubber (PC-CAS)	1.28 lb/hour	18,000 acfm	Wet Scrubber	Ducon Environmental Systems	Attachment B3
PCL02	Stockpile Area Scrubber (PC-SAS)	2.59 lb/hour	36,500 acfm	Wet Scrubber	Ducon Environmental Systems	Attachment B3
PCL03	Reclaim Tunnel Scrubber (PC-RTS)	1.07 lb/hour	15,000 acfm	Wet Scrubber	Ducon Environmental Systems	Attachment B3
PCL04	Pebble Crusher Area Scrubber (PC-PCAS)	1.56 lb/hour	22,000 acfm	Wet Scrubber	Ducon Environmental Systems	Attachment B3
PCL05	Copper Concentrate Scrubber 1 (PC-CCS1)	3.55 lb/hour	50,000 acfm	Wet Scrubber	Ducon Environmental Systems	Attachment B3
PCL06	Copper Concentrate Scrubber 2 (PC-CCS2)	3.55 lb/hour	50,000 acfm	Wet Scrubber	Ducon Environmental Systems	Attachment B3
PCL07	Molybdenum Scrubber (PC-MS) / Electrostatic Precipitator (PC-EP) - Designed in series	0.02 lb/hour (prior to amendment) 0.014 lb/hour (after amendment)	500 acfm ^a (prior to amendment) 139 acfm ^a (after amendment)	Rod Deck Venturi Scrubber and Wet Electrostatic Precipitator	Bionomic Industries	Attachment B4

Table 2.1 Particulate Matter Pollution Control Equipment at the RCP

Unit ID	Pollution Control Device	Proposed PM ₁₀ Emission Limit	Exhaust Flow Rate	Type of Pollution Control Device	Name of Manufacturer	Reference for Manufacturer's Information
PCL08	Molybdenum Dust Collector (PC-MDC)	0.010 grains/dscf	1,500 acfm	Baghouse	Ducon Environmental Systems	Attachment B3
PCL09	Laboratory Dust Collector 1 (PC-L1)	0.005 grains/dscf	10,000 acfm	Baghouse	Farr Air Pollution Control	Attachment B5
PCL10	Laboratory Dust Collector 2 (PC-L2)	0.005 grains/dscf	10,000 acfm	Baghouse	Farr Air Pollution Control	Attachment B5
PCL11	Laboratory Dust Collector 3 (PC-L3)	0.005 grains/dscf	10,000 acfm	Baghouse	Farr Air Pollution Control	Attachment B5

^a The exhaust flow rate is for the Electrostatic Precipitator, as it is located second in the series of pollution control devices.

3. METHODOLOGY USED TO PROVIDE REQUESTED INFORMATION

In response to PDEQ's request for additional information, a methodology has been developed to demonstrate that the particulate matter pollution control devices to be used at the RCP are designed in a manner to achieve the PM₁₀ emission limits proposed in RCM's Class II Air Quality Permit Application. The methodology consists of using manufacturer's control efficiencies to calculate controlled emissions from the particulate matter pollution control devices and then comparing the calculated controlled emissions to the proposed PM₁₀ emission limits. Because the manufacturer's control efficiencies are at specific cut-points (e.g. 10 µm, 6 µm, 2.5 µm, etc.), whereas particulates from control devices have a continuous size distribution, the analysis requires that particulates be segregated into discrete size ranges with a corresponding control efficiency applied to that size range. The analysis methodology is a six step process as described in Sections 3.1 through 3.6 and includes the following:

- Calculating uncontrolled emissions from sources controlled by a pollution control device;
- Segregating uncontrolled emissions into discrete size ranges;
- Calculating controlled emissions by applying manufacturer's control efficiencies;
- Combining controlled emissions from the discrete size ranges;
- Summing controlled emissions from all sources controlled by the pollution control device; and
- Comparing the total emissions to the proposed emission limit.

Information about how the methodology is applied to the RCP is included in the description of the six steps.

3.1. STEP 1

Calculate uncontrolled emissions for each of the following air pollutants from all of the emission units controlled by a pollution control device:

- *PM (particulate matter);*
- *PM₁₀ (particulate matter less than 10 microns in aerodynamic diameter);*
- *PM₆ (particulate matter less than 6 microns in aerodynamic diameter);*
- *PM_{2.5} (particulate matter less than 2.5 microns in aerodynamic diameter); and*
- *PM₁ (particulate matter less than 1 micron in aerodynamic diameter).*

Some pollution control devices being evaluated control more than one emission unit at the RCP. Each emission unit may have different uncontrolled emission rates as well as different size distributions. Consequently, all emission units controlled by pollution control equipment must be evaluated. Additionally, since the majority of the proposed emission limits are expressed in terms of lb/hour, the uncontrolled emissions are calculated on an hourly basis.

Uncontrolled hourly PM, PM₁₀, and PM_{2.5} emissions from each emission unit have previously been calculated in the RCM's Class II Air Quality Permit Application. A description of how the uncontrolled hourly PM, PM₁₀, and PM_{2.5} emissions are calculated is presented in Appendix D of the application.

Uncontrolled hourly PM_6 and PM_1 emissions are calculated by using the known emission factors for various particle sizes and interpolating and extrapolating the PM_6 and PM_1 emission factors using a best-fit curve. The results from interpolation and extrapolation are presented in Attachment B2. When necessary, the emission factors for PM or dust are assumed to estimate PM_{30} (particulate matter less than 30 microns in aerodynamic diameter) emission factors. This methodology was used to calculate uncontrolled emissions from processes controlled by all pollution control devices except primary crushing and molybdenum drying operations.

Uncontrolled emissions from primary crushing have been reevaluated due to a previous overestimate of $PM_{2.5}$ emissions (e.g. the previous fraction of $PM_{2.5}$ emissions from primary crushing was estimated to be greater than the $PM_{2.5}$ fraction for tertiary crushing, which is contrary to what would be expected). The revised uncontrolled $PM_{2.5}$ emission factor is calculated by multiplying the existing primary crushing emission factor for PM_{10} with the ratio of $PM_{2.5}$ to PM_{10} emission factors from AP-42, Table 11.19.2-2 (08/04) for controlled tertiary crushing in crushed stone processing operations. This methodology is consistent with the methodology used to calculate the $PM_{2.5}$ emission factor for tertiary crushing at the RCP. Additionally, it leads to a worst case estimate of $PM_{2.5}$ emissions during primary crushing, as the fraction of $PM_{2.5}$ emissions is expected to be greatest during tertiary crushing operations and pollution control devices have a lower efficiency for smaller size particulates. The PM_6 emission factor for primary crushing is determined using the interpolation methodology, as described above. As extrapolation leads to a value less than zero, the PM_1 emission factor for primary crushing is calculated by applying the 1 micron particle size fraction for Category 3, material handling and processing of unprocessed ore, from AP-42, Appendix B.2 (09/96) to the existing PM emission factor.

An engineering analysis was conducted by Bionomic Industries for molybdenum drying operations at the RCP and the molybdenum scrubber and electrostatic precipitator that control emissions from the drying process. The analysis included determining parameters for the inlet exhaust gas to the molybdenum scrubber and electrostatic precipitator designed in series (dust concentrations, particle size distributions, gas volume, and gas temperature). The analysis also resulted in a reduced exhaust flow rate from the pollution control system that resulted in reduced emissions. Rather than using generic AP-42 emission factors, the inlet dust concentration and particle size distribution developed by Bionomic Industries are used to calculate uncontrolled emissions from the molybdenum concentrate dryer (Emission Unit MD02). The manufacturer's information regarding the engineering analysis is presented in Attachment B4. The inlet dust concentration is assumed to be equal to the PM emission factor and an interpolation analysis is used to generate PM_{10} , PM_6 , and $PM_{2.5}$ emission factors. The interpolation analysis is presented in Attachment B2.

3.2. STEP 2

Segregate uncontrolled PM, PM₁₀, PM₆, and PM_{2.5} emissions into the following size range categories:

- PM_{<1} (particulate matter less than 1 microns in aerodynamic diameter)
- PM_{1-2.5} (particulate matter between 1 and 2.5 microns in aerodynamic diameter)
- PM_{2.5-6} (particulate matter between 2.5 and 6 microns in aerodynamic diameter)
- PM₆₋₁₀ (particulate matter between 6 and 10 microns in aerodynamic diameter)
- PM_{>10} (particulate matter greater than 10 microns in aerodynamic diameter)

Uncontrolled emissions in each of the size fractions are calculated as follows: (a) uncontrolled hourly PM_{<1} emissions are assumed to be equal to uncontrolled hourly PM₁ emissions; (b) uncontrolled hourly PM_{1-2.5} emissions are calculated by subtracting the uncontrolled hourly PM_{<1} emissions from the uncontrolled hourly PM_{2.5} emissions; (c) uncontrolled hourly PM_{2.5-6} emissions are calculated by subtracting the uncontrolled hourly PM_{<1} and PM_{1-2.5} emissions from the uncontrolled hourly PM₆ emissions; (d) uncontrolled hourly PM₆₋₁₀ emissions are calculated by subtracting the uncontrolled hourly PM_{<1}, PM_{1-2.5}, and PM_{2.5-6} emissions from the uncontrolled hourly PM₁₀ emissions; and (e) uncontrolled hourly PM_{>10} emissions are calculated by subtracting the uncontrolled hourly PM_{<1}, PM_{1-2.5}, PM_{2.5-6}, and PM₆₋₁₀ emissions from the uncontrolled hourly PM emissions.

3.3. STEP 3

Apply the manufacturer's expected control efficiencies to the uncontrolled PM_{<1}, PM_{1-2.5}, PM_{2.5-6}, PM₆₋₁₀, and PM_{>10} emissions to calculate controlled PM_{<1}, PM_{1-2.5}, PM_{2.5-6}, PM₆₋₁₀, and PM_{>10} emissions.

The controlled hourly emission rates can be calculated using the following equation:

$$E_C = E_{UC} * (1 - CE)$$

where:

E _C	=	Controlled Emissions (lb/hour)
E _{UC}	=	Uncontrolled Emissions (lb/hour)
CE	=	Manufacturer's Expected Control Efficiency (%)

Manufacturer's information about the expected control efficiencies for each of the particulate matter pollution control devices is presented in Attachments B3 through B5. The manufacturer's information presents control efficiency information for distinct particle sizes. Since this methodology segregates emission into particle size ranges, it is necessary to obtain control efficiency information for each particle size range. However, since the control efficiencies vary for each particle size, this methodology uses a control efficiency for an intermediate particle size to approximate the control efficiency for the entire size range. The particle size ranges and associated intermediate particle sizes are presented in Table 3.1.

Table 3.1 Particle Size Ranges and Intermediate Particle Sizes

Particle Size Range	Intermediate Particle Size
< 1 µm	0.5 µm
1 - 2.5 µm	1.75 µm
2.5 - 6 µm	4.25 µm
6 - 10 µm	8 µm
> 10 µm	20 µm

When manufacturer's information is not available for the intermediate particle sizes, an interpolation analysis is completed to calculate the necessary control efficiencies. Results of the interpolation are presented in Attachment B.2. The expected control efficiencies for the different particle size ranges are presented in Table 3.2.

Table 3.2 Expected Control Efficiencies for the Particulate Matter Pollution Control Devices at the RCP

Unit ID	Pollution Control Device	Control Efficiencies				
		PM _{<1}	PM _{1-2.5}	PM _{2.5-6}	PM ₆₋₁₀	PM _{>10}
PCL01	Crushing Area Scrubber (PC-CAS)	88.065%	94.90%	99.495%	99.99%	99.99%
PCL02	Stockpile Area Scrubber (PC-SAS)	88.065%	94.90%	99.495%	99.99%	99.99%
PCL03	Reclaim Tunnel Scrubber (PC-RTS)	88.065%	94.90%	99.495%	99.99%	99.99%
PCL04	Pebble Crusher Area Scrubber (PC-PCAS)	88.065%	94.90%	99.495%	99.99%	99.99%
PCL05	Copper Concentrate Scrubber 1 (PC-CCS1)	88.615%	95.325%	99.67%	99.99%	99.99%
PCL06	Copper Concentrate Scrubber 2 (PC-CCS2)	88.615%	95.325%	99.67%	99.99%	99.99%
PCL07	Molybdenum Scrubber (PC-MS) / Electrostatic Precipitator (PC-EP)	98.30%	98.30%	99.90%	99.90%	99.90%
PCL08	Molybdenum Dust Collector (PC-MDC)	99.90%	99.90%	99.90%	99.90%	99.90%
PCL09	Laboratory Dust Collector 1 (PC-L1)	99.99%	99.99%	99.99%	99.99%	99.99%
PCL10	Laboratory Dust Collector 2 (PC-L2)	99.99%	99.99%	99.99%	99.99%	99.99%
PCL11	Laboratory Dust Collector 3 (PC-L3)	99.99%	99.99%	99.99%	99.99%	99.99%

3.4. STEP 4

Combine controlled $PM_{<1}$, $PM_{1-2.5}$, $PM_{2.5-6}$, PM_{6-10} , and $PM_{>10}$ emissions into controlled PM, PM_{10} , and $PM_{2.5}$ emissions for each emission unit controlled by the particulate matter pollution control device.

Similar to the segregation completed in Step 2, the combined controlled emissions are calculated as follows: (a) controlled hourly $PM_{2.5}$ emissions are calculated by summing the controlled hourly $PM_{<1}$ and $PM_{1-2.5}$ emissions; (b) controlled hourly PM_{10} emissions are calculated by summing the controlled hourly $PM_{<1}$, $PM_{1-2.5}$, $PM_{2.5-6}$, and PM_{6-10} emissions; and (c) controlled hourly PM emissions are calculated by summing the controlled hourly $PM_{<1}$, $PM_{1-2.5}$, $PM_{2.5-6}$, PM_{6-10} , and $PM_{>10}$ emissions.

3.5. STEP 5

Total controlled PM, PM_{10} , and $PM_{2.5}$ emissions for all emission units controlled by the particulate matter pollution control device.

If more than one emission unit at the RCP is controlled by the pollution control device, the controlled emissions of all of the emission units must be summed to determine the total controlled emissions that are expected to be exhausted from the pollution control device.

3.6. STEP 6

Compare the controlled PM_{10} emission total from the particulate matter pollution control device to the PM_{10} emission limit.

A comparison of the calculated controlled hourly emission total to the proposed PM_{10} emission limit demonstrates whether or not the particulate matter pollution control devices to be used at the RCP are designed in a manner such that the proposed PM_{10} emission limits can be achieved. If the calculated controlled hourly emission total is less than the proposed PM_{10} emission limit, the pollution control device at the RCP is expected to be in compliance with the proposed PM_{10} emission limit.

The molybdenum dust collector (PCL08) and the laboratory dust collectors (PCL09, PCL10, and PCL11) have proposed PM_{10} emission limits in units of grains/dscf. For these particulate matter pollution control devices, it is necessary to convert the calculated controlled hourly PM_{10} emission rates in lb/hour to units of grains/dscf to allow for a direct emission comparison. The conversion can be accomplished by using the following equation:

$$E_2 = E_1 * \frac{1}{FR} * \frac{1 \text{ hour}}{60 \text{ minutes}} * \frac{7,000 \text{ grains}}{\text{lb}}$$

where:

E_2	=	PM_{10} emissions (grains/dscf)
E_1	=	PM_{10} emissions (lb/hour)
FR	=	Exhaust Flow Rate of the Pollution Control Device (dscfm)

The exhaust flow rates in units of dscfm can be calculated using the methodology described in Appendix D, Section D.10 of the RCM's Class II Air Quality Permit Application and Attachment B, Section B.3 of the RCC's response to the PDEQ's request for additional information dated October 2010. The results of these calculations are presented in Table 3.3.

Table 3.3 Properties of the Pollution Control Devices with PM10 Emission Limits Expressed in Units of grains/dscf

Unit ID	Pollution Control Equipment	Exhaust Flow Rate	
		acfm	dscfm
PCL08	Molybdenum Dust Collector (PC-MDC)	1,500	1,244
PCL09	Laboratory Dust Collector 1 (PC-L1)	10,000	8,290
PCL10	Laboratory Dust Collector 2 (PC-L2)	10,000	8,290
PCL11	Laboratory Dust Collector 3 (PC-L3)	10,000	8,290

The results of Steps 1 through 6 for the pollution control devices at the RCP are presented in Tables B1.1 through B1.3 in Attachment B.1. A summary of the conclusions determined in Step 6 is presented in Section 4.

4. CONCLUSION

By applying the methodology described in Section 3, it is demonstrated that the particulate matter pollution control devices to be used at the RCP are designed in a manner that the PM₁₀ emission limits proposed in RCM's Class II Air Quality Permit Application can be achieved at the start-up of the mine. A summary of the results found using the methodology described in Section 3 is presented in the "Calculated Controlled PM₁₀ Emission" column in Table 4.1. Additionally, the proposed PM₁₀ emission limit for each pollution control device is reiterated in Table 4.1 to present a direct comparison of the expected emissions calculated for the RCP and the proposed emission limits. As shown in Table 4.1, the expected controlled emissions calculated for each pollution control device at the RCP will not exceed the corresponding proposed PM₁₀ emission limit.

In addition to the analysis included in this evaluation, compliance measurements made at similar processes with similar pollution control devices indicate that the voluntarily accepted emission limits proposed in the RCM's Class II Air Quality Permit Application can be readily attained. Attachment B6 provides a listing of compliance measurement of emissions from primary crushers and secondary/tertiary crushers controlled by wet scrubbers. All measurements were made using EPA Method 5/202, which includes all particulate matter rather than just PM₁₀. The measured outlet grain loadings and emission rates expressed in lb/hr are substantially less than those proposed in the RCM application. Although the pollution control devices and process rates may not be the same, the data

demonstrates that the proposed emission limits are readily achievable with pollution control devices similar to those that will be used by the RCP.

The measurements in Attachment B6 are for informational purposes to demonstrate that actual particulate matter emissions from controlled mining activities are usually much less than the accepted emission limits typically established from manufacturer's outlet grain loading information or calculated using emission factors and control efficiencies.

Table 4.1 Comparison of Proposed PM₁₀ Emission Limits and Calculated Controlled PM₁₀ Emissions

Unit ID	Pollution Control Device	Proposed PM ₁₀ Emissions Limit	Calculated Controlled PM ₁₀ Emissions
PCL01	Crushing Area Scrubber (PC-CAS)	1.28 lb/hour	1.11 lb/hr
PCL02	Stockpile Area Scrubber (PC-SAS)	2.59 lb/hour	0.012 lb/hr
PCL03	Reclaim Tunnel Scrubber (PC-RTS)	1.07 lb/hour	0.006 lb/hr
PCL04	Pebble Crusher Area Scrubber (PC-PCAS)	1.56 lb/hour	0.46 lb/hr
PCL05	Copper Concentrate Scrubber 1 (PC-CCS1)	3.55 lb/hour	0.00006 lb/hour total (combined emissions for PCL05 and PCL06)
PCL06	Copper Concentrate Scrubber 2 (PC-CCS2)	3.55 lb/hour	
PCL07	Molybdenum Scrubber (PC-MS) / Electrostatic Precipitator (PC-EP)	0.014 lb/hour	0.011 lb/hour
PCL08	Molybdenum Dust Collector (PC-MDC)	0.010 grains/dscf	0.0000003 lb/hour = 0.00000003 grains/dscf
PCL09	Laboratory Dust Collector 1 (PC-L1)	0.005 grains/dscf	
PCL10	Laboratory Dust Collector 2 (PC-L2)	0.005 grains/dscf	0.012 lb/hour total = 0.00006 grains/dscf total (combined emissions for PCL09, PCL10, and PCL11)
PCL11	Laboratory Dust Collector 3 (PC-L3)	0.005 grains/dscf	

5. DETAILED INFORMATION ABOUT THE AMENDMENT

As explained in Section 2, the RCP has updated the design of the molybdenum scrubber / electrostatic precipitator, which reduced the exhaust flow rate. Therefore, the PM₁₀ emission limit initially proposed for the molybdenum scrubber / electrostatic precipitator has been revised in order to accommodate the new exhaust flow rate. Additionally, the revision to the PM₁₀ emission limit affects the potential to emit (PTE) of the molybdenum scrubber / electrostatic precipitator as well as for the entire RCP. Compliance with the NSPS emission standard for PM is discussed in Section 5.1. The changes to the PTE are discussed in Section 5.2.

5.1. COMPLIANCE WITH NSPS

The RCP has revised the PM₁₀ emission limit for the molybdenum scrubber / electrostatic precipitator from 0.02 to 0.014 lb of PM₁₀/hour in order to accommodate the new flow rate. Per Request III in PDEQ's first request for additional information dated September 23, 2010, the revised emissions for the molybdenum scrubber / electrostatic precipitator based on both the NSPS emission standard for PM (0.022 grains/dscf) and the proposed PM₁₀ emission limit (0.014 lb/hr) are presented in Table 5.1.

The daily and annual emission calculations presented in Table 5.1 are based on continuous operation (24 hours/day and 8,760 hours/year). The particle size fractions used for the emission calculations are determined based on the ratios of controlled hourly PM, PM₁₀, and PM_{2.5} emissions from the molybdenum concentrate dryer (Emission Unit MD02), as calculated in Section 3 of this attachment.

For calculation of emissions using the NSPS emission standard for PM, the exhaust flow rate from the electrostatic precipitator is calculated to be 91 dscfm. The methodology used to determine the exhaust flow rate is described in Appendix D, Section D.10 of the RCM's Class II Air Quality Permit Application and Attachment B, Section B.3 of the RCC's response to the PDEQ's request for additional information dated October 2010.

Table 5.1 shows that the proposed PM₁₀ emission limit results in PM emissions that are less than those required by the NSPS emission standard.

5.2. CHANGE IN THE PTE

The revised PM₁₀ emission limit for the molybdenum scrubber / electrostatic precipitator changes the PTE for the individual emission unit as well as the PTE for the entire RCP. The changes to the PTE due to the revised PM₁₀ emission limit are presented in Table 5.2.

The PTE values in Table 5.2 that correspond to emissions before the revision to the PM₁₀ emission limit for the molybdenum scrubber / electrostatic precipitator are from RCC's response to the PDEQ's request for additional information dated October 2010. In this response, the PTE of the RCP was revised from the values presented in the RCM's Class II Air Quality Permit Application. The PTE of the molybdenum scrubber / electrostatic precipitator after the revision to the PM₁₀ emission limit is from Table 5.1. As shown in Table 5.2, the PTE of the molybdenum scrubber / electrostatic precipitator as well as the entire RCP decreases slightly due to the revision of the PM₁₀ emission limit.

Table 5.1 Emissions Analysis for the Molybdenum Scrubber / Electrostatic Precipitator

Emission Scenario	Flow Rate		Controlled Particle Size Fraction		Controlled Hourly Emissions (lb/hr)		Controlled Daily Emissions (tpd)		Controlled Annual Emissions (tpy)					
	acfm	dscfm	PM ₁₀	PM _{2.5}	PM	PM ₁₀	PM _{2.5}	PM	PM ₁₀	PM _{2.5}				
NSPS Limit PM = 0.022 grains/dscf	139	91	1.00	0.91	0.86	0.017	0.015	0.015	0.00020	0.00018	0.00017	0.074	0.068	0.064
Proposed PM ₁₀ Limit PM ₁₀ = 0.014 lb/hour	139	91	1.10	1.00	0.94	0.015	0.014	0.013	0.00019	0.00017	0.00016	0.068	0.061	0.058

Table 5.2 Change in the Potential to Emit

Category of Emission Source	PTE (tpy)	
	PM	PM _{2.5}
Molybdenum Scrubber / Electrostatic Precipitator (Before revision of the PM ₁₀ emission limit)	0.09	0.08
Molybdenum Scrubber / Electrostatic Precipitator (After revision of the PM ₁₀ emission limit)	0.07	0.06
Change in Emissions Due to the Revision of the PM ₁₀ Emission Limit	-0.02	-0.03
Potential to Emit of the RCP (Before revision of the PM ₁₀ emission limit)	88.06	67.62
Change in Emissions Due to the Revision of the PM ₁₀ Emission Limit	-0.02	-0.03
Revised Potential to Emit of the RCP (After revision of the PM₁₀ emission limit)	88.04	67.60

ATTACHMENT B1
EMISSION CALCULATIONS

Table B1.1 Particulate Matter Emission Factors

Process Code	Process Description	SCC Code	Emission Factors						Prod. Rate Units	Particulate Matter Emission Factor Inputs ^a					Reference
			PM	PM ₁₀	PM ₆	PM _{2.5}	PM ₁	Units		k (PM)	k (PM ₁₀)	k (PM _{2.5})	U (mph)	M (%)	
DTMlyCncPrt	Dried Moly Concentrate Transfer (Protected)	3-03-024-08	0.00004	0.00002	0.00001	0.000003	0.0000006	lb/ton	0.74	0.35	0.053	1.3	10	AP-42, Section 13.2.4, Expression 1 (11/06) and Interpolation	
DTMlyCnc	Dried Moly Concentrate Transfer (Unprotected)	3-03-024-08	0.0003	0.0002	0.0001	0.00002	0.000005	lb/ton	0.74	0.35	0.053	6.21	10	AP-42, Section 13.2.4, Expression 1 (11/06) and Interpolation	
TRCuCncPrt	Copper Concentrate Transfer (Protected)	3-03-024-08	0.00004	0.00002	0.00001	0.000003	0.0000006	lb/ton	0.74	0.35	0.053	1.3	10	AP-42, Section 13.2.4, Expression 1 (11/06) and Interpolation	
CrushP	Primary Crushing - High Moisture Ore	3-03-024-05	0.02	0.009	0.005	0.002	0.0008	lb/ton						AP-42, Section 11.24, Table 11.24-2 (09/82), 11.19.2-2 (08/04), and Appendix B.2 (09/96) and Interpolation	
CrushT	Tertiary Crushing - High Moisture Ore	3-03-024-07	0.06	0.02	0.011	0.004	0.0004	lb/ton						AP-42, Section 11.24, Table 11.24-2 (09/82) and 11.19.2-2 (08/04) and Interpolation	
Scrub/ESP	Inlet Dust Concentration to the Molybdenum Scrubber / Electrostatic Precipitator	3-03-024-11	3.00	1.56	1.16	0.77	0.60	gr/scf						Manufacturer's Information and Interpolation	
MolyDry	Drying of High Moisture Ore	3-03-024-11	19.70	12.00	8.97	5.91	4.48	lb/ton						AP-42, Section 11.24, Table 11.24-2 (09/82) and Appendix B.2 (09/96) and Interpolation	
TrSnPrt	Ore Material Transfer (Protected)	3-03-024-08	0.0002	0.00007	0.00004	0.00001	0.000002	lb/ton	0.74	0.35	0.053	1.3	4	AP-42, Section 13.2.4, Expression 1 (11/06) and Interpolation	
TrSnUnp	Ore Material Transfer (Unprotected)	3-03-024-08	0.001	0.0006	0.0003	0.00009	0.00002	lb/ton	0.74	0.35	0.053	6.21	4	AP-42, Section 13.2.4, Expression 1 (11/06) and Interpolation	

^a k = particle size multiplier, A = horizontal area of blasting surface, U = mean wind speed, M = material moisture content

Table B1.2 Particulate Matter Control Efficiencies

Control Code	Control Description	Control Efficiencies (%)						Reference
		> 10 µm	6 - 10 µm	2.5 - 6 µm	1 - 2.5 µm	< 1 µm		
CAS	Crushing Area Scrubber (PC-CAS)	99.99%	99.99%	99.495%	94.90%	88.065%	Manufacturer's Information and Interpolation Analysis	
SAS	Stockpile Area Scrubber (PC-SAS)	99.99%	99.99%	99.495%	94.90%	88.065%	Manufacturer's Information and Interpolation Analysis	
RTS	Reclaim Tunnel Scrubber (PC-RTS)	99.99%	99.99%	99.495%	94.90%	88.065%	Manufacturer's Information and Interpolation Analysis	
PCAS	Pebble Crusher Area Scrubber (PC-PCAS)	99.99%	99.99%	99.495%	94.90%	88.065%	Manufacturer's Information and Interpolation Analysis	
CCS	Copper Concentrate Scrubbers (PC-CCS1/CCS2)	99.99%	99.99%	99.67%	95.325%	88.615%	Manufacturer's Information and Interpolation Analysis	
MS/EP	Molybdenum Scrubber (PC-MS) / Electrostatic Precipitator (PC-EP)	99.90%	99.90%	99.90%	98.30%	98.30%	Manufacturer's Information and Interpolation Analysis	
MDC	Molybdenum Dust Collector (PC-MDC)	99.90%	99.90%	99.90%	99.90%	99.90%	Manufacturer's Information and Interpolation Analysis	
LDC	Laboratory Dust Collectors	99.99%	99.99%	99.99%	99.99%	99.99%	Manufacturer's Information and Interpolation Analysis	


Table B1.3 Hourly Particulate Matter Emissions for Emission Units Controlled by Pollution Control Devices at the RCP																												
Hourly Emission Rate	Rate Units	Emission Factors				EF Units	Control Code	Control Efficiencies (%)				Uncontrolled Emissions (lb/hr)					PM _{2.5-10} Emissions (lb/hr)				PM _{2.5-6.6} Emissions (lb/hr)				PM _{2.5-10} Emissions (lb/hr)			
		PM	PM ₁₀	PM _{2.5}	PM ₁			> 10 µm	6 - 10 µm	2.5 - 6 µm	1 - 2.5 µm	< 1 µm	PM	PM ₁₀	PM _{2.5}	PM ₁	Unctl.	Ctl.	Unctl.	Ctl.	Unctl.	Ctl.	Unctl.	Ctl.	Unctl.	Ctl.	Unctl.	Ctl.
5,950	tons	0.02	0.009	0.005	0.002	0.0008	CAS	99.99%	99.99%	99.50%	94.90%	88.07%	139.00	62.55	36.88	11.58	5.56	76.45	0.008	25.67	0.003	25.30	0.13	6.02	0.31			
5,950	tons	0.002	0.0007	0.0004	0.0001	0.00002	CAS	99.99%	99.99%	99.50%	94.90%	88.07%	1.08	0.51	0.31	0.08	0.02	0.57	0.0006	0.20	0.0002	0.23	0.001	0.06	0.001			
5,950	tons	0.002	0.0007	0.0004	0.0001	0.00002	CAS	99.99%	99.99%	99.50%	94.90%	88.07%	1.08	0.51	0.31	0.08	0.02	0.57	0.0006	0.20	0.0002	0.23	0.001	0.06	0.001			
5,950	tons	0.002	0.0007	0.0004	0.0001	0.00002	SAS	99.99%	99.99%	99.50%	94.90%	88.07%	1.08	0.51	0.31	0.08	0.02	0.57	0.0006	0.20	0.0002	0.23	0.001	0.06	0.001			
5,950	tons	0.002	0.0007	0.0004	0.0001	0.00002	SAS	99.99%	99.99%	99.50%	94.90%	88.07%	1.08	0.51	0.31	0.08	0.02	0.57	0.0006	0.20	0.0002	0.23	0.001	0.06	0.001			
5,950	tons	0.002	0.0007	0.0004	0.0001	0.00002	RTS	99.99%	99.99%	99.50%	94.90%	88.07%	1.08	0.51	0.31	0.08	0.02	0.57	0.0006	0.20	0.0002	0.23	0.001	0.06	0.001			
5,950	tons	0.002	0.0007	0.0004	0.0001	0.00002	PCAS	99.99%	99.99%	99.50%	94.90%	88.07%	1.08	0.51	0.31	0.08	0.02	0.57	0.0006	0.20	0.0002	0.23	0.001	0.06	0.001			
1,771	tons	0.002	0.0007	0.0004	0.0001	0.00002	PCAS	99.99%	99.99%	99.50%	94.90%	88.07%	0.28	0.13	0.08	0.02	0.04	0.15	0.0001	0.05	0.00005	0.06	0.0003	0.02	0.0001			
1,771	tons	0.002	0.0007	0.0004	0.0001	0.00002	PCAS	99.99%	99.99%	99.50%	94.90%	88.07%	0.28	0.13	0.08	0.02	0.04	0.15	0.0001	0.05	0.00005	0.06	0.0003	0.02	0.0001			
1,771	tons	0.002	0.0007	0.0004	0.0001	0.00002	PCAS	99.99%	99.99%	99.50%	94.90%	88.07%	0.28	0.13	0.08	0.02	0.04	0.15	0.0001	0.05	0.00005	0.06	0.0003	0.02	0.0001			
1,771	tons	0.06	0.02	0.01	0.004	0.0004	PCAS	99.99%	99.99%	99.50%	94.90%	88.07%	106.27	35.42	20.19	6.56	0.64	70.85	0.007	15.24	0.02	13.63	0.07	5.92	0.30			
1,771	tons	0.002	0.0007	0.0004	0.0001	0.00002	PCAS	99.99%	99.99%	99.50%	94.90%	88.07%	108.45	36.46	20.81	6.72	0.67	72.00	0.007	15.65	0.02	14.09	0.07	6.05	0.31			
138	tons	0.0004	0.0002	0.0001	0.00003	0.000006	CCS	99.99%	99.99%	99.67%	95.33%	88.62%	0.006	0.003	0.002	0.0004	0.00009	0.003	0.000003	0.001	0.000001	0.001	0.00004	0.0003	0.0001			
138	tons	0.0004	0.0002	0.0001	0.00003	0.000006	CCS	99.99%	99.99%	99.67%	95.33%	88.62%	0.006	0.003	0.002	0.0004	0.00009	0.003	0.000003	0.001	0.000001	0.001	0.00004	0.0003	0.0001			
the Electrostatic Precipitator)																												
5,460	scf	3.00	1.56	1.16	0.77	0.60	MS/EP	99.90%	99.90%	99.90%	98.30%	98.30%	2.34	1.22	0.90	0.60	0.47	1.12	0.001	0.31	0.003	0.30	0.003	0.14	0.001			
1.9	tons	0.0004	0.0002	0.0001	0.00003	0.000006	MDC	99.90%	99.90%	99.90%	99.90%	99.90%	0.0008	0.0004	0.0002	0.00006	0.00001	0.0004	0.000004	0.0002	0.000002	0.0002	0.000002	0.00005	0.00000002			
1.9	tons	0.0003	0.0002	0.00009	0.00002	0.000005	MDC	99.90%	99.90%	99.90%	99.90%	0.0006	0.0003	0.0002	0.00004	0.00009	0.00004	0.0003	0.000003	0.0001	0.000001	0.0001	0.000001	0.00004	0.00000001			
= 6,290 dscfm each)																												
10	tons	0.06	0.02	0.01	0.004	0.0004	LDC	99.99%	99.99%	99.99%	99.99%	0.60	0.20	0.11	0.04	0.04	0.40	0.0004	0.09	0.00009	0.08	0.00008	0.03	0.00008	0.0001			
10	tons	0.06	0.02	0.01	0.004	0.0004	LDC	99.99%	99.99%	99.99%	99.99%	0.60	0.20	0.11	0.04	0.04	0.40	0.0004	0.09	0.00009	0.08	0.00008	0.03	0.00008	0.0001			
10	tons	19.70	12.00	8.97	5.91	4.48	LDC	99.99%	99.99%	99.99%	99.99%	197.00	120.00	89.69	59.10	44.82	77.00	0.008	30.31	0.003	30.59	0.003	14.28	0.001	0.001			
= 6,290 dscfm each)																												
10	tons	0.06	0.02	0.01	0.004	0.0004	LDC	99.99%	99.99%	99.99%	99.99%	198.20	120.40	89.92	59.17	44.83	77.80	0.008	30.48	0.003	30.75	0.003	14.34	0.001	0.001			

ATTACHMENT B2

**INTERPOLATION/EXTRAPOLATION ANALYSIS FOR EMISSION FACTORS
AND PARTICULATE MATTER POLLUTION CONTROL DEVICES**


Dried Moly Concentrate Transfer (Protected) From AP-42, Section 13.2.4, Expression 1	
Particle Size	Emission Factor (lb/ton)
PM _{2.5}	0.000003
PM ₅	0.000012
PM ₁₀	0.000020
PM ₁₅	0.000028
PM ₃₀	0.000043

Calculated from Trendline	
Particle Size	Emission Factor (lb/ton)
PM ₆	0.000012
PM ₁	0.0000006




Dried Moly Concentrate Transfer (Unprotected) From AP-42, Section 13.2.4, Expression 1	
Particle Size	Emission Factor (lb/ton)
PM _{2.5}	0.00002
PM ₅	0.00009
PM ₁₀	0.00016
PM ₁₅	0.00021
PM ₃₀	0.00033

Calculated from Trendline	
Particle Size	Emission Factor (lb/ton)
PM ₆	0.00009
PM ₁	0.000005




Copper Concentrate Transfer (Protected) From AP-42, Section 13.2.4, Expression 1	
Particle Size	Emission Factor (lb/ton)
PM _{2.5}	0.000003
PM ₅	0.000012
PM ₁₀	0.000020
PM ₁₅	0.000028
PM ₃₀	0.000043

Calculated from Trendline	
Particle Size	Emission Factor (lb/ton)
PM ₆	0.000012
PM ₁	0.0000006




Primary Crushing - High Moisture Ore From AP-42, Section 11.24, Table 11.24-2 and Appendix B.2	
Particle Size	Emission Factor (lb/ton)
PM _{2.5}	0.002
PM ₁₀	0.009
PM ₃₀	0.020

Calculated from Trendline	
Particle Size	Emission Factor (lb/ton)
PM ₆	0.005




Tertiary Crushing - High Moisture Ore From AP-42, Section 11.24, Table 11.24-2 and 11.19.2-2	
Particle Size	Emission Factor (lb/ton)
PM _{2.5}	0.004
PM ₁₀	0.020
PM ₃₀	0.060

Calculated from Trendline	
Particle Size	Emission Factor (lb/ton)
PM ₆	0.011
PM ₁	0.0004




Inlet Dust Concentration to the Molybdenum Scrubber / Electrostatic Precipitator From Manufacturer's Information	
Particle Size	Emission Factor (gr/acf)
PM ₁	0.60
PM ₂₀	2.40
PM ₃₀	3.00

Calculated from Trendline	
Particle Size	Emission Factor (gr/acf)
PM _{2.5}	0.77
PM ₆	1.16
PM ₁₀	1.56




Drying of High Moisture Ore From AP-42, Section 11.24, Table 11.24-2 and Appendix B.2	
Particle Size	Emission Factor (lb/ton)
PM _{2.5}	5.91
PM ₁₀	12.00
PM ₃₀	19.70

Calculated from Trendline	
Particle Size	Emission Factor (lb/ton)
PM ₆	8.97
PM ₁	4.48




Ore Material Transfer (Protected)	
From AP-42, Section 13.2.4, Expression 1	
Particle Size	Emission Factor (lb/ton)
PM _{2.5}	0.00001
PM ₅	0.00004
PM ₁₀	0.00007
PM ₁₅	0.00010
PM ₃₀	0.00016

Calculated from Trendline	
Particle Size	Emission Factor (lb/ton)
PM ₆	0.00004
PM ₁	0.000002




Ore Material Transfer (Unprotected) From AP-42, Section 13.2.4, Expression 1	
Particle Size	Emission Factor (lb/ton)
PM _{2.5}	0.00009
PM ₅	0.00032
PM ₁₀	0.00056
PM ₁₅	0.00077
PM ₃₀	0.00119

Calculated from Trendline	
Particle Size	Emission Factor (lb/ton)
PM ₆	0.00034
PM ₁	0.00002



Ducon Scrubbers (PCL01, PCL02, PCL03, PCL04) From Manufacturer's Information	
Particle Size	Control Efficiency (%)
PM ₁	90.80%
PM _{2.5}	99.00%
PM ₆	99.99%
PM ₁₀	99.99%
PM ₃₀	99.99%


Calculated from Trendline	
Particle Size	Control Efficiency (%)
PM ₀	85.33%



Ducon Scrubbers (PCL01, PCL02, PCL03, PCL04) Interpolated Data		
Particle Size	Control Efficiency (%)	Applicable Particle Size Range
PM _{0.5}	88.065%	< 1 µm
PM _{1.75}	94.90%	1 - 2.5 µm
PM _{4.25}	99.495%	2.5 - 6 µm
PM ₈	99.99%	6 - 10 µm
PM ₂₀	99.99%	> 10 µm

Ducon Scrubbers (PCL05, PCL06) From Manufacturer's Information	
Particle Size	Control Efficiency (%)
PM ₁	91.30%
PM _{2.5}	99.35%
PM ₆	99.99%
PM ₁₀	99.99%
PM ₃₀	99.99%


Calculated from Trendline	
Particle Size	Control Efficiency (%)
PM ₀	85.93%



Ducon Scrubbers (PCL05, PCL06) Interpolated Data		
Particle Size	Control Efficiency (%)	Applicable Particle Size Range
PM _{0.5}	88.615%	< 1 µm
PM _{1.75}	95.325%	1 - 2.5 µm
PM _{4.25}	99.67%	2.5 - 6 µm
PM ₈	99.99%	6 - 10 µm
PM ₂₀	99.99%	> 10 µm

Molybdenum Scrubber / ESP (PCL07) From Manufacturer's Information	
Particle Size	Control Efficiency (%)
PM _{<2.5} ^a	98.30%
PM _{2.5}	99.90%
PM ₆	99.90%
PM ₁₀	99.90%
PM ₃₀	99.90%


^a Use this control efficiency for the particle size range < 1 µm and 1 - 2.5 µm.



Farr Baghouses (PCL09, PCL10, PCL11) Interpolated Data		
Particle Size	Control Efficiency (%)	Applicable Particle Size Range
PM _{4,25}	99.90%	2.5 - 6 µm
PM ₈	99.90%	6 - 10 µm
PM ₂₀	99.90%	> 10 µm

Ducon Baghouse (PCL08) From Manufacturer's Information	
Particle Size	Control Efficiency (%)
PM ₁	99.90%
PM _{2.5}	99.90%
PM ₆	99.90%
PM ₁₀	99.90%
PM ₃₀	99.90%


Calculated from Trendline	
Particle Size	Control Efficiency (%)
PM ₀	99.90%



Ducon Baghouse (PCL08) Interpolated Data		
Particle Size	Control Efficiency (%)	Applicable Particle Size Range
PM _{0.5}	99.90%	< 1 µm
PM _{1.75}	99.90%	1 - 2.5 µm
PM _{4.25}	99.90%	2.5 - 6 µm
PM ₈	99.90%	6 - 10 µm
PM ₂₀	99.90%	> 10 µm

Farr Baghouses (PCL09, PCL10, PCL11) From Manufacturer's Information	
Particle Size	Control Efficiency (%)
PM _{0.5} ^a	99.99%
PM ₁	99.99%
PM _{2.5}	99.99%
PM ₆	99.99%
PM ₁₀	99.99%
PM ₃₀	99.99%

^a Use this control efficiency for the particle size range < 1 µm.



Farr Baghouses (PCL09, PCL10, PCL11) Interpolated Data		
Particle Size	Control Efficiency (%)	Applicable Particle Size Range
PM _{1.75}	99.99%	1 - 2.5 µm
PM _{4.25}	99.99%	2.5 - 6 µm
PM ₈	99.99%	6 - 10 µm
PM ₂₀	99.99%	> 10 µm

ATTACHMENT B3

**MANUFACTURER'S INFORMATION FOR THE
DUCON SCRUBBERS AND BAGHOUSE**



DUCON TECHNOLOGIES INC.

"Serving the Industry Since 1938"

19 Engineers Lane

Farmingdale, NY 11735, USA

Tel: (516)694-1700 Fax: (516)420-4985

Project: Rosemont Copper C11-5095

May 24, 2011

Ducon Scrubber Size: 78 (Crushing Area Scrubber)

Operating Conditions

Gas Flow	18,000 acfm
Temperature	100 deg. F.
Plant Elevation	5,200 ft. a.s.l.
Atmospheric Pressure	12.1 psia.
Moisture Content	20 % R.H. (assumed)
Inlet Static	-8.0 " w.c.
Outlet Static	0.5 " w.c. (assumed)
Saturated Gas Flow	16,754 acfm
Saturated Temperature	68 deg. F.
Scrubbing Liquid Rate	51 gpm @ 15 to 20 psig.
Evaporative Loss	0.9 gpm
Fan RPM	1226
Fan BHP	85.4 @ conditions 102.1 @ standard
Efficiency	2.5 microns-99.0 % 6.0 microns-99.99 % 10.0 microns-99.99 % >10.0 microns-99.99 %

Ducon Scrubber Size: 108 (Stockpile Area Scrubber)

Operating Conditions

Gas Flow	36,500 acfm
Temperature	100 deg. F.
Plant Elevation	5,200 ft. a.s.l.
Atmospheric Pressure	12.1 psia.
Moisture Content	20 % R.H. (assumed)
Inlet Static	-8.0 " w.c.
Outlet Static	0.5 " w.c. (assumed)
Saturated Gas Flow	33,974 acfm
Saturated Temperature	68 deg. F.
Scrubbing Liquid Rate	102 gpm @ 15 to 20 psig.
Evaporative Loss	1.8 gpm
Fan RPM	873
Fan BHP	179.3 @ conditions 214.4 @ standard
Efficiency	2.5 microns-99.0 % 6.0 microns-99.99 % 10.0 microns-99.99 % >10.0 microns-99.99 %

Ducon Scrubber Size: 72 (Reclaim Tunnel Scrubber)

Operating Conditions

Gas Flow	15,000 acfm
Temperature	100 deg. F.
Plant Elevation	5,200 ft. a.s.l.
Atmospheric Pressure	12.1 psia.
Moisture Content	20 % R.H. (assumed)
Inlet Static	-8.0 " w.c.
Outlet Static	0.5 " w.c. (assumed)
Saturated Gas Flow	13,961 acfm
Saturated Temperature	68 deg. F.

Scrubbing Liquid Rate	42 gpm @ 15 to 20 psig.
Evaporative Loss	0.8 gpm
Fan RPM	1199
Fan BHP	70.3 @ conditions 84.1 @ standard
Efficiency	2.5 microns-99.0 %
	6.0 microns-99.99 %
	10.0 microns-99.99 %
	>10.0 microns-99.99 %

Ducon Scrubber Size: 84 (Pebble Area Crusher Scrubber)

Operating Conditions

Gas Flow	22,000 acfm
Temperature	100 deg. F.
Plant Elevation	5,200 ft. a.s.l.
Atmospheric Pressure	12.1 psia.
Moisture Content	20 % R.H. (assumed)
Inlet Static	-8.0 " w.c.
Outlet Static	0.5 " w.c. (assumed)
Saturated Gas Flow	20,477 acfm
Saturated Temperature	68 deg. F.
Scrubbing Liquid Rate	62 gpm @ 15 to 20 psig.
Evaporative Loss	1.1 gpm
Fan RPM	1108
Fan BHP	107.6 @ conditions 128.7 @ standard
Efficiency	2.5 microns-99.0 %
	6.0 microns-99.99%
	10.0 microns-99.99 %
	>10.0 microns-99.99 %

Ducon Scrubber Size: 126 (Copper Concentrate Scrubber 1 & 2)

<u>Operating Conditions</u>	<u>Each Unit</u>
Gas Flow	50,000 acfm
Temperature	100 deg. F.
Plant Elevation	5,200 ft. a.s.l.
Atmospheric Pressure	12.1 psia.
Moisture Content	20 % R.H. (assumed)
Inlet Static	-8.0 " w.c.
Outlet Static	0.5 " w.c. (assumed)
Saturated Gas Flow	46,540 acfm
Saturated Temperature	68 deg. F.
Scrubbing Liquid Rate	140 gpm @ 15 to 20 psig.
Evaporative Loss	2.5 gpm
Fan RPM	803
Fan BHP	250.5 @ conditions 299.6 @ standard
Efficiency	2.5 microns-99.35 % 6.0 microns-99.99 % 10.0 microns-99.99 % >10.0 microns-99.99%

Ducon Baghouse Size: 20/314 (Moly Dust Collector)

DESIGN DATA

Gas Flow	1,500 acfm
Temperature	100 deg. F.
Plant Elevation	5,200 ft. a.s.l.
Atmospheric Pressure	12.1 psia.
Pressure Drop	4.0 – 6.0" W.C.
Compressed Air Requirement	8 scfm @ 80 - 100 psig.
Housing Design Pressure	+/-17.0 " w.c.
Total Cloth Area	314 sq. ft.
Air-to-Cloth Ratio	4.78:1
Bag Removal	Top thru walk-in-plenum
Efficiency: 2.5 microns-99.9 %	10.0 microns-99.9 %
6.0 microns-99.9 %	>10.0 microns-99.9 %

Amber Summers

From: Stephen Michalowski [smichalowski@ducon.com]
Sent: Thursday, May 26, 2011 10:27 AM
To: Amber Summers
Cc: Anthony Maccari; Berrin Citak
Subject: RE: Ducon Scrubber/Baghouse Information for Rosemont Copper Company

Hello Amber

For the Crushing, Stockpile, Reclaim and Pebble scrubbers the expected efficiency at 1 micron is 90.8%. This is at 2.85 S.G

For the Copper Concentrate scrubber the expected efficiency at 1 micron is 91.3% This is at 3.62 S.G.

For the Moly Dust Baghouse the expected efficiency at 1 micron is 99.9 %. This is at 4.36 S.G.

Kindest Regards

Stephen J. Michalowski
Project Engineer
Ducon Environmental Systems
631-694-1700 x 109
stevem@ducon.com

From: Amber Summers [<mailto:asummers@jbrenv.com>]
Sent: Tuesday, May 24, 2011 6:54 PM
To: Stephen Michalowski
Subject: Ducon Scrubber/Baghouse Information for Rosemont Copper Company

Steve,

I work for Applied Environmental Consultants, an air quality consultant for the Rosemont Copper Company and have been working on a response to the local agency. Rosemont had provided the attached information to us regarding control efficiencies for the Ducon scrubbers and baghouse to be used at the Rosemont Copper Mine. Is there any additional information about the control efficiencies for particles in the size range of 0-2.5 microns? A control efficiency for particulates at 0.5 microns or 1 micron would be extremely helpful. On the other hand, if this information is not available, please let us know.

Thanks,
Amber

Amber Summers
Scientist II
Applied Environmental Consultants
a JBR company
1553 W. Elna Rae
Tempe, Arizona 85281
[p] 480.829.0457 [f] 480.829.8985

ATTACHMENT B4

**MANUFACTURER'S INFORMATION FOR THE BIONOMIC
INDUSTRIES SCRUBBER AND ELECTROSTATIC PRECIPITATOR**



BIONOMIC INDUSTRIES

"Superior Engineered Pollution Control Systems With Unequaled Performance"

May 24, 2011

Subject: Bionomic Industries- Molybdenum Scrubber/Wet Electrostatic Precipitator

The expected collection efficiency for the design airflow (attached drawing)of the 2.5, 6 and 10 micron particles should exceed 99.9%. The expected collection efficiency of the particles less than 2.5 microns needs to be approximately 98.3% to meet the 0.01 gr/scf outlet emission.

This design is based on the following:

Inlet Exhaust Gas

Plant elevation	5200	ft. (asl)
Gas Volume (design basis)	139	acfm
Gas Temperature (design basis)	202	degree, F
Dust Concentration (assumed)	3	gr/scf
Particle Size Distribution (assumed)		
Micron size, greater than 20	20	%
Micron size, greater than 1(assumed)	80	%
Pressure	-2	inch w.c.

Performance Criteria (at WESP outlet):

Dust Concentration, max	0.01	gr/scf
Dust collection efficiency	99.7	%
Opacity	≤5	%
Scrubber pressure drop	15	in. w.c.

TYPICAL PERFORMANCE GUARANTEE

Bionomic Industries Inc. guarantees that the equipment system supplied, when operated in accordance with the Operating Conditions specified in this document and Bionomic's Operating & Maintenance Manual, will meet the following performance:

System's particulate inlet emissions shall be reduced by 99.7% or will not exceed 0.01 gr/scf whichever is less stringent, at a system pressure drop not to exceed 10" w.c.

System's outlet opacity will not exceed 5%.

The above performance is based on the Performance inlet conditions in the data section included in this proposal. This guarantee is based on the Terms and Conditions attached. The guarantee is for the specific items listed above and does not extend to any other items.

Should you require additional information,

Please feel free to contact me.

Regards,

Dave Meier

ATTACHMENT B5

**MANUFACTURER'S INFORMATION FOR
THE FARR DUST COLLECTORS**



FARR
Air Pollution Control

Tag No. 200-DC-001

ROSEMONT COPPER PROJECT

Description	Vendor Data
Manufacturer	FARR Air Pollution Control (APC)
Model	Gold Series Cartridge Filter
Size	GS36/30
Capacity	10,000 CFM
Efficiency %@micron	99.99% down to .5 micron
Air to Cloth Ratio	1.54:1
Bags/Cartridges	Cartridges
Diameter	15" OD
Length Ft.	39.5" Long
Total Number	30 Cartridges
Total Area ft.2	9750 Sq. ft
Filter Material	85% Cellulosic 15% Polyester
Face Velocity	1.54 ft per minute
Pressure Drop (Average dirty bags) in W.G.	1.5" to 2.5 normal operating range with 5" maximum normal operating range
Housing	
Length ft.	126"
Width ft.	126"
Height Bottom of hopper to top of unit	192-3/16" from hopper discharge to top of collector add 57-1/8" for top mounted fan
Material	Carbon Steel
Gauge	10 gauge
Tube Sheet	
Material (tube sheet)	Carbon Steel
Gauge (tube sheet)	7 gauge
Hopper	Pyramid Hopper
Gauge (Hopper)	7 gauge
Side Slope	60 degree minimum slope
Inlet Diffuser	Slanted Channel Baffles - Rhino Lined (Abrasion Resistant)
Inspection Door	QUICK OPEN VIEWPORT 6" DIA GLASS
Platform	318" X 50" Wrap Around
Ladder	Carbon Steel
Legs	6X6X3/8" Structural Steel
Cleaning Cycle Control	FARR Controller
dP Gauges	FARR Controller
dP Transmitter	FARR Controller
Timers	FARR Controller
Slide Gate	N/A
Rotary Airlock	12" X 12" MEYER HDX - Mill/Chem Chrome Bore
Duct between housing and fan	
Compressed Air requirements CFM @ psig	30CFM @ 90 PSI
Paint System	Powder Coat collector housing/Enamel Paint Hopper
Weight:	15,955 Lbs Total Weight of Dust Collector

ATTACHMENT B6

**PRIOR EMISSIONS TEST DATA AT
COPPER MINING OPERATIONS**

Results of Compliance Testing for Similar Processes and Control Devices						
Emission Source	Description	Pollution Control Device	Process Rate (tph)	Date Tested	PM Emission Rate ^a (grains/dscf)	PM Emission Rate ^a (lb/hour)
Primary Crushers:						
Copper Mine	Primary Crusher	Rotoclone, Size 12, Type N	7,450	8/21/2003	0.0051	0.4993
Copper Mine	Primary Crusher	Ducon UW-4	5,362	9/28/2006	0.0016	0.2328
Copper Mine	Primary Crusher	Ducon UW-4	4,544	11/17/2010	0.0026	0.37
Secondary/Tertiary Crushers that process ore similar in size to that of the Pebble Crusher:						
Copper Mine	Secondary/Tertiary Crusher	Ducon UW-4, Type UW-4, Size 66	755	8/07/2003	0.0025	0.1899
Copper Mine	Secondary/Tertiary Crusher	Ducon UW-4, Type UW-4, Size 66	640	8/07/2003	0.0020	0.2064
Copper Mine	Secondary/Tertiary Crusher	Ducon UW-4, Type UW-4, Size 66	693	8/20/2003	0.0015	0.1891
Copper Mine	Secondary/Tertiary Crusher	Emtrol W-40, Size 66	694	8/20/2003	0.0024	0.4792
Copper Mine	Secondary/Tertiary Crusher	Ducon UW-4, Type UW-4, Size 66	789	3/06/2006	0.022	0.4613
Copper Mine	Secondary/Tertiary Crusher	Emtrol W-40, Size 66	727	3/06/2006	0.0023	0.4353
Copper Mine	Secondary/Tertiary Crusher	Ducon UW-4, Type UW-4, Size 66	676	3/10/2006	0.0006	0.1138

Results of Compliance Testing for Similar Processes and Control Devices						
Emission Source	Description	Pollution Control Device	Process Rate (tph)	Date Tested	PM Emission Rate ^a (grains/dscf)	PM Emission Rate ^a (lb/hour)
Copper Mine	Secondary/Tertiary Crusher	Ducon UW-4, Type UW-4, Size 66	629	3/10/2006	0.0011	0.1648
Copper Mine	Secondary/Tertiary Crusher	Ducon UW-4, Type UW-4, Size 66	1,182	6/24/2008	0.0032	0.248
Copper Mine	Secondary/Tertiary Crusher	Ducon UW-4, Type UW-4, Size 66	803	9/25/2008	0.0024	0.22
Copper Mine	Secondary/Tertiary Crusher	Ducon UW-4, Type UW-4, Size 66	749	9/26/2008	0.0025	0.237
Copper Mine	Secondary/Tertiary Crusher	Ducon UW-4, Type UW-4, Size 66	711	7/08/2010	0.0052	0.39
Copper Mine	Secondary/Tertiary Crusher	Ducon UW-4, Type UW-4, Size 66	707	7/13/2010	0.0052	0.49
Copper Mine	Secondary/Tertiary Crusher	Ducon UW-4, Type UW-4, Size 66	736	7/15/2010	0.0018	0.14
Copper Mine	Secondary/Tertiary Crusher	Ducon UW-4, Type UW-4, Size 66	749	7/16/2010	0.0015	0.17
Copper Mine	Secondary/Tertiary Crusher	Emtrol W-40, Size 66	716	11/04/2010	0.0028	0.28

^a Emission rate was measured using EPA Method 5/202, i.e. total filterable particulate + condensables.